




Project Name	LANCO HILLS RESIDENTIAL PROJECT- LH 10 ,HYDERABAD		
Client	LANCO HILLS TECHNOLOGY PARK PRIVATE LIMITED		
PMC	SAVILLS PROPERTY SERVICES (INDIA) PRIVATE LIMITED		
Main Contractor	BCIM ENGINEERING PVT LIMITED		
REVISION HISTORY			
REV.NO	DATE	DETAILS OF REVISION	
R0	21.05.2026	Initial Issue for review and approval	
R1	25.05.2026	Groove Thickness	
PREPARED BY BCIM		REVIEWED BY BCIM	REVIEWED & APPROVED BY PMC/Client
			

 Lanco Hills a world within 	BCIM ENGINEERING PVT LTD METHOD STATEMENT FOR WATERPROOFING WORKS	 BCIM

1. WATERPROOFING FOR EDECK LEVEL RCC WALL @ EXPANSION JOINT AREA

1. Objective

The Objective of this Method statement is to carryout Waterproofing Treatment for EDECK level Expansion Joint locations by meeting the contract documents, Technical Data Sheet and Approved Drawings.

2. Scope of Work

Providing and applying waterproofing treatment of RCC walls at the expansion joint area at Edeck level using K10 PU Plus twocomponent polyurethane coating with LANKO 162 primer, including all crack and joint repairs.

3. Reference


- Approved Drawings
- Approved Materials

4. Materials Used

S.No	Material/Product	Purpose
1	K10 PU Plus	Two Component Polyurethane waterproof coating
2	LANKO 162	Primer coat (1coat)
3	Fosroc Thioflex 600	PU sealant for cracks and construction joints
4	Fosroc Conbextra GP2	Cementitious grout for porous area grouting

5. Surface Preparation

- Clean the RCC wall surface and make it free from all loose particles and dust.
- Provide coves/fillets of 50 mm × 50 mm at all wall-floor junctions using CM 1:4 mortar admixed with Conbextra GP2
- Repair all cracks and cold/construction joints, cut a 10 mm × 10 mm using pressure grouting (Conbextra GP2) and seal joints with Fosroc Thioflex 600 PU sealant


 Babu Subramanyam
 25/05/26


 Rafi
 25/05/26

 Lanco Hills a word setting  savills	BCIM ENGINEERING PVT LTD METHOD STATEMENT FOR WATERPROOFING WORKS	 BCIM
--	--	---

6. Application Procedure

- Apply one coat of LANKO 162 primer as per manufacturer's Specification.
- Apply TWO coats of K10 PU Plus over the primed surface as per manufacturer's specification
- Apply protective cement plaster coat as the final finishing layer.

Instruments:

- Grinding Machine with accessories
- Hammer and Chisel
- Roller and Paint Brush
- Drilling machine and bits
- Injection Grouting Machine
- Slow Speed Mixer
- Spatula
- Coir Cleaning Brush.

ATTACHMENT

1. Check list for Waterproofing

Bala
 Bala Subramaniam
 25/05/26

Heli
 25/05/26