System works at 50 Hz.
Load is balanced by generation.

Load increases and frequency drops.

Primary control of generator 1 and battery act to contain frequency at 49,8 Hz.

Secondary control decides to start generator 2

Primary control of generator 1 and battery are relieved
Frequency back at 50 Hz!