

PACKAGE AIR CONDITIONING UNIT - COOLING ONLY																																				
TAG	LOCATION	MANUFACTURER & MODEL No.	SERVING	OCC MIN. OSA CFM	DCV MIN. OSA CFM	SUPPLY FAN				DX COOLING				COMPR		FILTER MEDIA DEPTH	EXH. FAN				SINGLE POINT POWER				FACTORY RDS	RATED EFF. @ AHRI		VIB. ISO	WEIGHTS (lbs)				REMARKS			
						CFM	E.S.P. (in w.c.)	FRPM	BHP	HP	REF. TYPE	TOTAL BHP	SENSIBLE BHP	EDB/EWB (°F)	LDB/LWB (°F)		AMB (°F)	QTY.	# OF CIRCUITS	CFM	E.S.P. (in w.c.)	BHP	HP	MCA		MFA/MOCP	VOLTAGE		EMERGENCY POWER	COOLING		UNIT		CURB	PE	TOTAL
																														IEER	IEER					
AC-1	ROOF	FRASER-JOHNSTON FV50C0DW4K1CDF14B1	WAREHOUSE	0	N/A	18,000	0.60	790	11.4	20	R-454B	580	540	87/65	64.2/56.3	105	3	-	15,000	0.2	-	2	142	175	460V-3ø	NO	NO	10.9	16.9	NO	7,000	870	N/A	7,870	COOLING ONLY PACKAGE UNIT, EQUIPPED WITH DIFFERENTIAL TEMPERATURE ECONOMIZER W/ MODULATING POWER EXHAUST, EQUIPPED WITH DSD, EQUIPPED WITH CONVENIENCE OUTLET, EQUIPPED WITH CURB (CAL5480600), POWER BY ELECTRICIAN	
AC-2	ROOF	FRASER-JOHNSTON FV50C0DW4K1CDF14B1	WAREHOUSE	0	N/A	18,000	0.60	790	11.4	20	R-454B	580	540	87/65	64.2/56.3	105	3	-	15,000	0.2	-	2	142	175	460V-3ø	NO	NO	10.9	16.9	NO	7,000	870	N/A	7,870	COOLING ONLY PACKAGE UNIT, EQUIPPED WITH DIFFERENTIAL TEMPERATURE ECONOMIZER W/ MODULATING POWER EXHAUST, EQUIPPED WITH DSD, EQUIPPED WITH CONVENIENCE OUTLET, EQUIPPED WITH CURB (CAL5480600), POWER BY ELECTRICIAN	
AC-3	ROOF	FRASER-JOHNSTON FV50C0DW4K1CDF14B1	WAREHOUSE	0	N/A	18,000	0.60	790	11.4	20	R-454B	580	540	87/65	64.2/56.3	105	3	-	15,000	0.2	-	2	142	175	460V-3ø	NO	NO	10.9	16.9	NO	7,000	870	N/A	7,870	COOLING ONLY PACKAGE UNIT, EQUIPPED WITH DIFFERENTIAL TEMPERATURE ECONOMIZER W/ MODULATING POWER EXHAUST, EQUIPPED WITH DSD, EQUIPPED WITH CONVENIENCE OUTLET, EQUIPPED WITH CURB (CAL5480600), POWER BY ELECTRICIAN	
AC-4	ROOF	FRASER-JOHNSTON FV50C0DW4K1CDF14B1	WAREHOUSE	0	N/A	18,000	0.60	790	11.4	20	R-454B	580	540	87/65	64.2/56.3	105	3	-	15,000	0.2	-	2	142	175	460V-3ø	NO	NO	10.9	16.9	NO	7,000	870	N/A	7,870	COOLING ONLY PACKAGE UNIT, EQUIPPED WITH DIFFERENTIAL TEMPERATURE ECONOMIZER W/ MODULATING POWER EXHAUST, EQUIPPED WITH DSD, EQUIPPED WITH CONVENIENCE OUTLET, EQUIPPED WITH CURB (CAL5480600), POWER BY ELECTRICIAN	
AC-5	ROOF	FRASER-JOHNSTON LD25C0C04L1CAF4B1	WAREHOUSE	0	N/A	10,000	0.75	1,025	5.9	7.5	R-454B	290	210	87/65	63.8/56.0	105	3	-	SEE PE-5				65	80	460V-3ø	NO	NO	10.2	14.4	NO	2,400	500	400	3,300	COOLING ONLY PACKAGE UNIT, EQUIPPED WITH DOWN DISCHARGE MODULATING CENTRIFUGAL POWER EXHAUST (PEDCSAV252846MS) SEE PE-5, CURB (CAL5240300), DIFFERENTIAL TEMPERATURE ECONOMIZER, POWER BY ELECTRICIAN	
AC-6	ROOF	FRASER-JOHNSTON LD25C0C04L1CAF4B1	WAREHOUSE	0	N/A	10,000	0.75	1,025	5.9	7.5	R-454B	290	210	87/65	63.8/56.0	105	3	-	SEE PE-6				65	80	460V-3ø	NO	NO	10.2	14.4	NO	2,400	500	400	3,300	COOLING ONLY PACKAGE UNIT, EQUIPPED WITH DOWN DISCHARGE MODULATING CENTRIFUGAL POWER EXHAUST (PEDCSAV252846MS) SEE PE-5, CURB (CAL5240300), DIFFERENTIAL TEMPERATURE ECONOMIZER, POWER BY ELECTRICIAN	

DISTRIBUTION FAN																
TAG	LOCATION	MANUFACTURER & MODEL No.	SERVING	QUANTITY	CFM	T.S.P. (in w.c.)	FRPM	HP	FEI	VOLTAGE	EMERGENCY POWER	VFD (Y/N)	VIB. ISO	WEIGHT (lbs)	dBA	REMARKS
DF-#-#	WAREHOUSE	MACROAIR AIRPOWER 14 YM	PICK MOD AREA	48	2,690	N/A	1,725	1/2	N/A	277V-1ϕ	NO	N	NO	45	-	12" AIRPOWER, 60" THROW, POWER BY ELECTRICIAN

POWER EXHAUST/ECONOMIZER											
TAG	LOCATION	MANUFACTURER & MODEL No.	SERVING	CFM	E.S.P. (in w.c.)	HP	VOLTAGE	EMERGENCY POWER	FLA	WEIGHT (lbs)	REMARKS
PE-5	ROOF	FRASER-JOHNSTON PEDCSA/V252846MS	AC-5	10,000	0.25	2 (QTY: 2)	460V-3ø	NO	5.6	SEE AC-5	DOWN DISCHARGE CENTRIFUGAL POWER EXHAUST, POWERED THROUGH UNIT, POWER BY ELECTRICIAN
PE-6	ROOF	FRASER-JOHNSTON PEDCSA/V252846MS	AC-6	10,000	0.25	2 (QTY: 2)	460V-3ø	NO	5.6	SEE AC-6	DOWN DISCHARGE CENTRIFUGAL POWER EXHAUST, POWERED THROUGH UNIT, POWER BY ELECTRICIAN


GRILLES & DIFFUSERS										
TAG	TYPE	MANUFACTURER & MODEL No.	MODULE SIZE	BORDER TYPE	MATERIAL	FACE TYPE	COLOR	RAPID MOUNT FRAME	OBD	REMARKS
DL-1	SUPPLY	TITUS S-DL	SEE PLANS	DUCT MOUNTED	ALUMINUM	DRUM	-	NO	NO	ROUND DUCT DRUM LOUVER, AIR SCOOP (AS)

ROOFTOP PACKAGE UNITS																													
PLAN MARK	MANUFACTURER	MODEL	NOMINAL TONS	LOCATION	GSA CFM	SUPPLY FAN			COOLING COIL					ELECTRIC HEAT			GAS HEAT			ELECTRICAL			MIN OA CFM	WEIGHT (LBS)	REMARKS				
						TSP (BHP)	BHP	HP	TOTAL MBH	SENS MBH	ENT DBWB	LVG DBWB	AMB TEMP	EER	IEER	KW	STAGES	INPUT MBH	OUTPUT MBH	EFF.	MAX. PRESS.	MCA				MOP	VOLTS/PH		
RTU-1	FRASER-JOHNSTON	XANS24ABSA3ADEE1B	40.0	OFFICE	(E)	2.5/1.5	13.33	25.0	465.9	363.9	83.8/66.0	58.3/53.8	95.0	10.7	13.5	N/A	N/A	330.0	450.0	80%	1/2 PSIG	139.0	150.0	4600	4,140	7,900	1, 2, 3, 5, 6, 7, 8, 9, 10, 11		
RTU-2	FRASER-JOHNSTON	ZW-18N09P9NB6ACAC1	17.5	OFFICE BRK RM	(E)	1.1/1.0	3.30	5.0	204.2	166.8	85.6/67.0	56.2/55.2	95.0	12.1	13.5	N/A	N/A	300.0	240.0	80%	1/2 PSIG	43.4	45.0	4600	2,300	3,500	1, 2, 4, 5, 7, 9, 10, 11, 12, 14		
RTU-3	FRASER-JOHNSTON	ZW-12N18G4DB8CDCA1	12.5	RECEIVING	(E)	2.0/1.5	3.43	5.0	155.2	119.5	82.1/65.4	54.4/52.3	95.0	12.0	13.5	N/A	N/A	180.0	144.0	80%	1/2 PSIG	44.1	50.0	4600	1,220	2,000	1, 2, 4, 5, 6, 7, 9, 10, 11		
RTU-4	FRASER-JOHNSTON	ZW-25N40P9NB6ACAC1	25	WAREHOUSE	(E)	0.63/0.5	8.67	10.0	297.0	256.1	76.5/61.7	52.8/51.5	95.0	10.6	12.1	N/A	N/A	400.0	320.0	80%	1/2 PSIG	67.4	70.0	4600	3,950	3,800	1, 2, 4, 5, 7, 9, 10, 11, 12, 13		
RTU-5	FRASER-JOHNSTON	ZW-25N40P9NB6ACAC1	25	WAREHOUSE	(E)	0.63/0.5	8.67	10.0	293.7	275.0	83.9/63.5	58.4/53.4	95.0	10.6	12.1	N/A	N/A	400.0	320.0	80%	1/2 PSIG	67.4	70.0	4600	3,640	3,800	1, 2, 4, 5, 7, 9, 10, 11, 12		
RTU-6	FRASER-JOHNSTON	ZW-25N40P9NB6ACAC1	25	WAREHOUSE	(E)	0.63/0.5	8.67	10.0	297.0	256.1	76.5/61.7	52.8/51.5	95.0	10.6	12.1	N/A	N/A	400.0	320.0	80%	1/2 PSIG	67.4	70.0	4600	3,950	3,800	1, 2, 4, 5, 7, 9, 10, 11, 12, 13		
RTU-7	FRASER-JOHNSTON	ZW-25N40P9NB6ACAC1	25	WAREHOUSE	(E)	0.63/0.5	8.67	10.0	293.7	275.0	83.9/63.5	58.4/53.4	95.0	10.6	12.1	N/A	N/A	400.0	320.0	80%	1/2 PSIG	67.4	70.0	4600	3,640	3,800	1, 2, 4, 5, 7, 9, 10, 11, 12		
RTU-8	FRASER-JOHNSTON	ZW-25N40P9NB6ACAC1	25	WAREHOUSE	(E)	0.63/0.5	8.67	10.0	297.0	256.1	76.5/61.7	52.8/51.5	95.0	10.6	12.1	N/A	N/A	400.0	320.0	80%	1/2 PSIG	67.4	70.0	4600	3,950	3,800	1, 2, 4, 5, 7, 9, 10, 11, 12, 13		
RTU-9	FRASER-JOHNSTON	ZW-25N40P9NB6ACAC1	25	WAREHOUSE	(E)	0.63/0.5	8.67	10.0	293.7	275.0	83.9/63.5	58.4/53.4	95.0	10.6	12.1	N/A	N/A	400.0	320.0	80%	1/2 PSIG	67.4	70.0	4600	3,640	3,800	1, 2, 4, 5, 7, 9, 10, 11, 12		
RTU-10	FRASER-JOHNSTON	ZW-25N40P9NB6ACAC1	25	WAREHOUSE	(E)	0.63/0.5	8.67	10.0	297.0	256.1	76.5/61.7	52.8/51.5	95.0	10.6	12.1	N/A	N/A	400.0	320.0	80%	1/2 PSIG	67.4	70.0	4600	3,950	3,800	1, 2, 4, 5, 7, 9, 10, 11, 12, 13		
RTU-11	FRASER-JOHNSTON	ZW-25N40P9NB6ACAC1	25	WAREHOUSE	(E)	0.63/0.5	8.67	10.0	293.7	275.0	83.9/63.5	58.4/53.4	95.0	10.6	12.1	N/A	N/A	400.0	320.0	80%	1/2 PSIG	67.4	70.0	4600	3,640	3,800	1, 2, 4, 5, 7, 9, 10, 11, 12		
RTU-12	FRASER-JOHNSTON	ZW-12N18G4DB8CDCA1	12.5	PICK MOD	(E)	0.8/0.5	3.06	5.0	153.4	130.0	83.9/63.5	54.5/51.3	95.0	12.0	13.5	N/A	N/A	180.0	144.0	80%	1/2 PSIG	46.3	50.0	4600	1,820	2,000	1, 2, 4, 5, 7, 9, 10, 11, 12, 13		
RTU-13	FRASER-JOHNSTON	ZW-12N18G4DB8CDCA1	12.5	PICK MOD	(E)	0.8/0.5	3.06	5.0	153.4	130.0	83.9/63.5	54.5/51.3	95.0	12.0	13.5	N/A	N/A	180.0	144.0	80%	1/2 PSIG	46.3	50.0	4600	1,820	2,000	1, 2, 4, 5, 7, 9, 10, 11, 12, 13		
RTU-14	FRASER-JOHNSTON	ZW-12N18G4DB8CDCA1	12.5	PICK MOD	(E)	0.8/0.5	3.06	5.0	153.4	130.0	83.9/63.5	54.5/51.3	95.0	12.0	13.5	N/A	N/A	180.0	144.0	80%	1/2 PSIG	46.3	50.0	4600	1,820	2,000	1, 2, 4, 5, 7, 9, 10, 11, 12, 13		
RTU-15	FRASER-JOHNSTON	ZW-12N18G4DB8CDCA1	12.5	PICK MOD	(E)	0.8/0.5	3.06	5.0	153.4	130.0	83.9/63.5	54.5/51.3	95.0	12.0	13.5	N/A	N/A	180.0	144.0	80%	1/2 PSIG	46.3	50.0	4600	1,820	2,000	1, 2, 4, 5, 7, 9, 10, 11, 12, 13		
GENERAL NOTES: 1. EXTERNAL STATIC PRESSURE INCLUDES LOSSES DUE TO DUCTWORK, AIR DEVICES, VOLUME DAMPERS AND DUCT MOUNTED COILS. 2. MAINTAIN MANUFACTURER'S RECOMMENDED SERVICE CLEARANCE AS TO ALLOW PROPER AIR FLOW TO CONDENSER, OPEN ACCESS AND CONTROL DOORS FOR SERVICE, MAINTENANCE, AND INSPECTIONS. 3. MAINTAIN MINIMUM ELECTRICAL CLEARANCE AS REQUIRED BY NEC. 4. FULL LOCK-UP STYLE GAS PRESSURE REGULATOR WITH MINIMUM 40 PSI EMERGENCY INLET PRESSURE BY M.C.															REMARKS: 1. FURNISHED WITH NON-FUSED DISCONNECT WITH THROUGH-THE-BASE ELECTRICAL ACCESS 2. FURNISHED WITH 1" FLAT ROOF CURB, SEISMIC RATED 3. CALIFORNIA TITLE 24 COMPLIANT ECONOMIZER, ULTRA LOW LEAKAGE DAMPERS, DRY BULB CONTROL 4. CALIFORNIA TITLE 24 COMPLIANT ECONOMIZER, LOW LEAKAGE DAMPERS, DRY BULB CONTROL, BAROMETRIC RELIEF 5. ECONOMIZER FAULT DETECTION AND DIAGNOSTICS 6. VARIABLE AIR VOLUME UNIT 7. FURNISHED WITH HINGED ACCESS DOORS 8. MODULATING 100% POWERED EXHAUST WITH STATITRAC CONTROL, ULTRA LOW LEAK EXHAUST DAMPER, FACTORY INSTALLED VFD 9. THROUGH-THE-BASE GAS PIPING 10. FURNISHED WITH FACTORY POWERED GFG CONVENIENCE OUTLET 11. FURNISHED WITH BACNET DDC COMMUNICATIONS INTERFACE 12. FURNISHED WITH TWO SPEED FAN MOTOR 13. FURNISHED WITH POWERED EXHAUST 14. CO2 SENSOR WITH DEMAND CONTROL VENTILATION														



10590 ARMSTRONG AVENUE
MATHER, CALIFORNIA 95655
(916) 520-2100

THE PLANS AND SPECIFICATIONS HEREIN
ARE OWNED BY AND FOR THE SOLE USE OF
ACCO ENGINEERED SYSTEMS, INC.
("ACCO") THE "DESIGN BUILDER", AND MAY
NOT BE REPRODUCED OR USED
BY OTHERS FOR ANY PURPOSE UNLESS
AUTHORIZED BY ACCO IN WRITING. ACCO
CANNOT ACCEPT ANY LIABILITY, WARRANTY, OR
OBLIGATION IN THE EVENT OF UNAUTHORIZED USE



B	01-12-2026	PLAN CHECK 1	AJR
A	12-10-2025	ISSUED FOR PERMIT	AJR
No.	Date	Description	By
Revisions			

Project

**ULTA BEAUTY
WAREHOUSE**

**850 EAST CENTRAL AVE
FRESNO, CA 93706**

Title	
EQUIPMENT SCHEDULES	
A. ROMERO	M. HOLEMAN
Designed By	Checked By
A. ROMERO	K. DUNN
Drawn By	Project Manager
70981292	NONE
Job Number	Scale

MO.10