

DRAWING TITLE DESIGNATION

SECTION KEY DESIGNATION



TYPICAL BEAM DESIGNATION



TYPICAL JOIST GIRDER DESIGNATION



TYPICAL JOIST DESIGNATION



REVISION DESIGNATION



COLUMN GRID DESIGNATION

NORTH ARROW DESIGNATION



MATERIALS DESIGNATION



KEY PLAN DESIGNATION

STANDARD ABBREVIATIONS

ADD	ADDEMDUM
ADDNL	ADDITIONAL
AGG	AGGREGATE
ALUM	ALUMINUM
AB	ANCHOR BOLT
L	ANGLE
ARCH	ARCHITECTURAL
@	AT
BSMT	BASEMENT
BP	BASE PLATE
BM	BEAM
BMS	BEAMS
BRG	BEARING
BTWN	BETWEEN
BLK	BLOCK
BD	BOARD
BOT	BOTTOM
B/FACE	BOTTOM FACE
BMD	BOTTOM OF METAL DECK
B/	BOTTOM OF
B/FTG	BOTTOM OF FOTTING
B/W	BOTTOM OF WALL
BRK	BRICK
BRDG	BRIDGING
BLDG	BUILDING
CANTL	CANTILEVER
CIP	CAST IN PLACE
CAT	CATEGORY
CLG	CEILING
CEM	CEMENT
CL	CENTERLINE
CC	CENTER TO CENTER
CTRD	CENTERED
CLR	CLEAR
CONC	CONCRETE
COL	COLUMN
CJP	COMPLETE JOINT PENETRATION
CONN	CONNECTION
CJ	CONTROL JOINT
CONSTR JT	CONSTRUCTION JOINT
CONT	CONTINUOUS
CONTR	CONTRACTOR
DL	DEAD LOAD
DK	DECK
DEFL	DEFLECTION
DTL	DETAIL
LD	DEVELOPMENT LENGTH
DIAG	DIAGONAL
DIA	DIAMETER
DIM	DIMENSION
DWLS	DOWELS
DN	DOWN
DWGS	DRAWINGS
EA	EACH
EF	EACH FACE
EW	EACH WAY
EOD	EDGE OF DECK
ELEC	ELECTRICAL
EL	ELEVATION
ELEV	ELEVATOR
EMBED	EMBEDDED
EQ	EQUAL
EQUIP	EQUIPMENT
EXIST	EXISITING
EJ	EXPANSION JOINT
EXT	EXTERIOR
FF	FAR FACE
FV	FIELD VERIFY
FIN	FINISH
FIN FLR	FINISHED FLOOR
FFL	FINISHED FLOOR LEVEL
FFS	FINISHED FLOOR SLAB
FL	FLOOR
FTG	FOOTING
FND	FOUNDATION
FRMG	FRAMING
GALV	GALVANIZED
GA	GAUGE
GC	GENERAL CONTRACTOR
GIR	GIRDER
GR	GRADE
GT	GROUT
GYP	GYPSUM
HS	HEADED STUD
HT	HEIGHT
HP	HIGH POINT
HC	HOLLOW CORE
HORIZ	HORIZONTAL
HEF	HORIZONTAL EACH FACE
ID	INSIDE DIAMETER
IF	INSIDE FACE
INT	INTERIOR
JT	JOINT
JST	JOIST
K	KIP = 100 lbs
KSF	KIPS PER SQUARE FOOT
KSI	KIPS PER SQAURE INCH
KO	KNOCKOUT
LTW	LIGHT WEIGHT
LWC	LIGHT WEIGHT CONCRETE
LTL	LINTEL
LL	LIVE LOAD
LG	LONG
LONG	LONGITUDINAL
LLBB	LONG LEG BACK TO BACK
LLH	LONG LEG HORIZONTAL
LLV	LONG LEG VERTICAL
LD	LONG DIRECTION
LSH	LONG SIDE HORIZONTAL
LSV	LONG SIDE VERTICAL
LP	LOW POINT
MFG	MANUFACTURER
MFG	MANUFACTURING
MK	MARK
MAS	MASONRY
MO	MASONRY OPENING
MATL	MATERIAL
MAX	MAXIMUM
MECH	MECHANICAL
MEPF	MECHANICAL / ELECTRICAL / PLUMBING / FIRE PROTECTION
MTL	METAL
MS	MILD STEEL
MIN	MINUMUM
MISC	MISCELLANEOUS
MC	MOMENT CONNECTION
NF	NEAR FACE
NOM	NOMINAL
NWT	NORMAL WEIGHT CONCRETE
NIC	NOT IN CONTRACT
NTS	NOT TO SCALE
OC	ON CENTER
OPNG	OPENING
OPP	OPPOSITE
OH	OPPOSITE HAND
OD	OUTSIDE DIAMETER
OF	OUTSIDE FACE
OVS	OVERSIDED HOLE
PNL	PANEL
PJP	PARTIAL JOINT PENETRATION
PH	PENTHOUSE
PL	PLATE
PL/THK	PLATE THICKNESS
PLBG	PLUMBING
PWD	PLYWOOD
PC	PILE CAP
PCKT	POCKET
PT	POST TENSION
LBS	POUNDS
PCF	POUNDS PER CUBIC FOOT
PSF	POUNDS PER SQUARE FOOT
PSI	POUNDS PER SQUARE INCH
PAF	POWER/POWDER ACTUATED FASTENER
PJF	PREMOLDED JOINT FILLER
RAD	RADIUS
RECT	RECTANGLE
REF	REFERENCE
RE	REFER TO
RC	REINFORCED CONCRETE
REINF	REINFORCED
R/	REMAINDER
REQ'D	REQUIRED
REV	REVISION
R	RISER
RF	ROOF
RTU	ROOF TOP UNITS
RM	ROOM
SCHED	SCHEDULE
SECT	SECTION
SC	SHEAR CONNECTORS
SW	SHEAR WALL
SD	SHORT DIRECTION
SLBB	SHORT LEG BACK TO BACK
SIM	SIMILAR
SL	SLAB
SOG	SLAB ON GRADE
SC	SLIP CRITICAL
SPA	SPACE, SPACING, SPACES
SPECS	SPECIFICATIONS
SQ	SQAURE
STD	STANDARD
STL	STEEL
STIF	STIFFENER
STRUCT	STRUCTURAL
SYMM	SYMMETRICAL
THK	THICKNESS
T&B	TOP AND BOTTOM
T/FACE	TOP FACE
TF	TOP OF FOOTING
TC	TOP OF CONCRETE
TJ	TOP OF JOIST
TL	TOP OF LEDGE
TPC	TOP OF PILE CAP
TP	TOP OF PILASTER
TSTL	TOP OF STEEL
TW	TOP OF WALL
TYP	TYPICAL
UNO	UNLESS NOTED OTHERWISE
VB	VAPOR BARRIER
VERT	VERTICAL
VEF	VERTICAL EACH FACE
WB	WIND BRACE
WWR	WELDED WIRE REINFORCING
W/	WITH
W/O	WITHOUT
WS	WATER STOP
WT	WEIGHT
WP	WORK POINT

STRUCTURAL SHEET LIST

SHEET NUMBER	SHEET NAME
S0.00	STRUCTURAL COVER SHEET
S0.01	GENERAL NOTES
S1.00	TYPICAL JOIST REINFORCEMENT
S2.00	EXISTING ROOF REINFORCING PLAN

DESIGN CRITERIA:

A. CODES AND STANDARDS:

2025 CALIFORNIA BUILDING CODE (IBC 2024)
RISK CATEGORY: II

2025 CALIFORNIA EXISTING BUILDING CODE (CEBC)

1. IN REFERENCE TO THE REQUIREMENTS OF SECTIONS 502.4 AND 503.3 OF THE 2018 INTERNATIONAL EXISTING BUILDING CODE. EXISTING STRUCTURAL MEMBERS SUPPORTING GRAVITY LOADS WERE CHECKED FOR THE NEW APPLIED LOADS. WHERE FORCES EXCEEDED A 5% THRESHOLD, THE EXISTING MEMBER EITHER HAD RESERVE CAPACITY TO SUPPORT THE ADDITIONAL FORCES OR THE EXISTING MEMBER WAS REINFORCED TO CONFORM TO THE REQUIREMENTS FOR NEW STRUCTURES.

2. IN REFERENCE TO THE REQUIREMENTS OF SECTIONS 502.5 AND 503.4 OF THE 2018 INTERNATIONAL EXISTING BUILDING CODE. ANY PROPOSED CHANGES TO THE EXISTING BUILDING DO NOT INCREASE THE SEISMIC FORCES IN ANY STRUCTURAL ELEMENT OR REDUCE THE SEISMIC RESISTANCE OF ANY ELEMENTS BY MORE THAN 10%. THEREFORE, NO MODIFICATIONS ARE REQUIRED TO BE MADE TO THE STRUCTURAL ELEMENTS RESISTING SEISMIC FORCES.

B. DESIGN LOADS:

ROOF:
MINIMUM ROOF LIVE LOAD: 20 P.S.F.

SNOW LOADS:
SNOW LOAD IMPORTANCE FACTOR: 1.0
GROUND SNOW LOAD: Pg = 5 P.S.F.
FLAT ROOF SNOW LOAD: Pf = 3.5 P.S.F.
RAIN ON SNOW: = 5 P.S.F.
SNOW EXPOSURE FACTOR: Ce = 1.0
THERMAL FACTOR: Ct = 1.0
MINIMUM SNOW LOAD: Pmin = 5 P.S.F.

DESIGN DEAD LOADS:
ROOF DEAD LOADS (PER EXISTING DRAWINGS)

ROOFING AND INSULATION	1.0
METAL ROOF DECK	2.0
STEEL JOISTS	1.5
M.E.P. AND SPRINKLERS	5.0
FUTURE SOLAR PANELS	0.0 (AREA UNDER PANELS MUST BE INACCESIBLE PER CBC 1607)
TOTAL ROOF DEAD LOAD	9.5 PSF

WIND LOADS:
BASIC WIND SPEED: 94 M.P.H. (72.8 M.P.H. NOMINAL)
WIND LOAD IMPORTANCE FACTOR: I = 1.0
WIND EXPOSURE: C
INTERNAL PRESSURE COEFFICIENT: GCpi = +/- 0.18

SEISMIC DESIGN DATA:
SEISMIC IMPORTANCE FACTOR: I = 1.0
MAPPED SPECTRAL RESPONSE ACCELERATIONS: Ss = 0.75 / S1 = 0.24
SPECTRAL RESPONSE COEFFICIENTS: Sds = 0.68 / Sd1 = 0.43
SITE CLASS D
SEISMIC DESIGN CATEGORY: D

STRUCTURAL STEEL:

1. STEEL SHALL CONFORM TO THE FOLLOWING GRADES:

   A. ALL WIDE FLANGE AND CHANNELS (UNO): A992 GRADE 50 (Fy=50 KSI)
   B. ALL ANGLES, BASE PLATES, CONNECTION PLATES (UNO): A572 GRADE 50 (Fy=50 KSI)
   C. STRUCTURAL PIPE: A53 GRADE B (Fy=35 KSI)
   D. STRUCTURAL HSS RECTANGULAR TUBE: A500 GRADE C (Fy=50 KSI)
   E. STRUCTURAL HSS ROUND TUBE: A500 GRADE C (Fy=50 KSI)

2. ALL STRUCTURAL STEEL SHALL BE DETAILED, FABRICATED AND ERECTED IN ACCORDANCE WITH THE LATEST EDITION OF THE AISC CODE OF STANDARD PRACTICE, EXCEPT AS MODIFIED IN THESE NOTES AND THE PROJECT SPECIFICATIONS.

3. CONNECTIONS MAY BE BOLTED OR WELDED. THE FABRICATOR IS RESPONSIBLE FOR THE DESIGN OF ANY AND ALL CONNECTIONS NOT SPECIFICALLY DESIGNED ON THE STRUCTURAL DRAWINGS. GENERALLY, CONNECTIONS SHOWN ON THE STRUCTURAL DRAWINGS ARE SCHEMATIC AND ARE ONLY INTENDED TO SHOW THE RELATIONSHIP OF MEMBERS CONNECTED. ANY CONNECTION THAT IS NOT SHOWN OR THAT IS NOT COMPLETELY DETAILED ON THE STRUCTURAL DRAWINGS SHALL BE DESIGNED BY A REGISTERED PROFESSIONAL ENGINEER (MUST BE REGISTERED IN THE STATE OF THE PROJECT). THAT PROFESSIONAL ENGINEER MUST PROVIDE PROOF OF PROFESSIONAL LIABIITY INSURANCE WITH COVERAGE TERMS AND LIMITS THAT, AT MINIMUM, ARE EQUAL TO THE PROFESSIONAL LIABILITY INSURANCE REQUIRED OF THE PROJECT ARCHITECT AND PROJECT STRUCTURAL ENGINEER. COMPLETELY DETAILED MEANS THE FOLLOWING INFORMATION IS SHOWN ON THE DETAIL:

   A. ALL PLATE DIMENSIONS AND GRADES.
   B. ALL WELD SIZES, LENGTHS, PITCHES, AND RETURNS.
   C. ALL HOLE SIZES AND SPACINGS.
   D. NUMBER AND TYPES OF BOLTS: WHERE BOLTS ARE SHOWN BUT NO NUMBER IS GIVEN, THE CONNECTION HAS NOT BEEN COMPLETELY DETAILED.
   E. WHERE PARTIAL INFORMATION IS GIVEN, IT SHALL BE THE MINIMUM REQUIREMENT FOR THE CONNECTION.

   PRIOR TO FABRICATION, DESIGN CALCULATIONS FOR TYPICAL BEAM CONNECTIONS, AND ALL PRIMARY BRACING AND HANGER CONNECTIONS, THAT HAVE BEEN SIGNED AND SEALED BY THE DESIGNING PROFESSIONAL ENGINEER SHALL BE SUBMITTED TO THE STRUCTURAL ENGINEER FOR DOCUMENTATION PURPOSES ONLY.

4. CONNECTION DESIGN FORCES:

   1. BEAMS, GREATER OF:

      a. 55% OF TOTAL ALLOWABLE UNIFORM LOAD CAPACITY FROM AISC 13TH EDITION TABLES FOR ALLOWABLE LOADS ON BEAMS, Wc/L.
      b. REACTIONS SHOWN ON DRAWINGS.
      c. 10 KIPS.

   2. MOMENT CONNECTIONS INDICATED ON THE DRAWINGS THUS: ▬◀H▶▬ DESIGN FOR MOMENT SHOWN OR, IF NOT SHOWN, DEVELOP MOMENT CAPACITY OF MEMBER WITH fb = 0.66 Fy.
   3. MAINTAIN TENSION CAPACITY OF COLUMNS, DIAGONALS AND MEMBERS SUBJECT TO TENSION AT BOLT HOLES, NOTCHES, OR COPES.
   4. CONNECTION FORCE NOTATION (STRENGTH LEVEL UNO):

      a. P = AXIAL FORCE IN KIPS: (+) TENSION, (-) COMPRESSION
      b. Ps = AXIAL SEISMIC FORCE
      c. Pw = AXIAL WIND FORCE
      d. V OR [ ] = SHEAR IN KIPS
      e. M = MOMENT IN FOOT KIPS
      f. T = TORSION IN FOOT KIPS

5. WELDED CONNECTIONS:

   A. WELDS ARE CONTINUOUS UNLESS NOTED OTHERWISE.
   B. ALL FILLET WELDS: AISC MINIMUM BUT NOT LESS THAN 1/4" UNLESS NOTED OTHERWISE.
   C. ALL WELDING SHALL BE IN ACCORDANCE WITH THE CURRENT "STRUCTURAL WELDING CODE" (AWS D1.1) PUBLISHED BY THE AMERICAN WELDING SOCIETY. ELECTRODES FOR WELDING SHALL COMPLY WITH THE REQUIREMENTS OF TABLE 3.1 OF (AWS D1.1).
   D. ALL WELDING FOR THE SEISMIC LATERAL FORCE RESISTING SYSTEM INDICATED WITH A "R" GREATER THAN 3 SHALL ALSO MEET THE REQUIREMENTS OF AWS D1.8 WITH FILLER METAL MEETING THE REQUIREMENTS OF AWS AS STANDARDS WITH A MINIMUM CVN TOUGHNESS OF 20 FT.-LBS. AT 0 DEGREES F.
   E. ALL GROOVE WELDS SHALL BE COMPLETE PENETRATION UNLESS NOTED OTHERWISE

6. SPLICING OF STEEL MEMBERS, UNLESS SHOWN ON THE DRAWINGS, IS PROHIBITED WITHOUT WRITTEN APPROVAL OF THE STRUCTURAL ENGINEER.

7. NO CHANGE IN SIZE OR POSITION OF THE STRUCTURAL ELEMENTS SHALL BE MADE AND HOLES, SLOTS, CUTS, ETC., ARE NOT PERMITTED THROUGH ANY MEMBER WITHOUT THE ENGINEER'S APPROVAL AND UNLESS THEY ARE DETAILED ON THE APPROVED SHOP DRAWINGS.

8. NO FINAL BOLTING OR WELDING SHALL BE MADE UNTIL AS MUCH OF THE STRUCTURE AS WILL BE STIFFENED THEREBY HAS BEEN PROPERLY ALIGNED.

9. UNLESS NOTED OTHERWISE, BEAMS SHALL BEAR 8" MINIMUM ON CONCRETE OR MASONRY. ANCHOR BEAMS TO MASONRY OR CONCRETE WITH 2-3/4" DIA ANCHOR BOLTS OR WELDED TO EMBED PLATE.

10. FABRICATE ALL BEAMS WITH THE MILL CAMBER UP.

11. SHEAR STUDS: CONFORM TO AWS D1.1, SHOP WELD EXCEPT WHERE APPLIED THROUGH METAL DECK.

12. HEADED STUDS SHALL CONFORM TO ASTM A108, GRADE 1015, WELDABLE (Fy = 65 KSI).

13. TOP OF ALL TUBES AND PIPES SHALL HAVE A CAP PLATE 1/4", SEAL WELDED ALL AROUND, UNLESS LARGER CAP PLATE AND / OR WELD IS NOTED. THIS DOES NOT APPLY TO DIAGONAL / SLOPING TUBES OR PIPES.

14. WHERE FIREPROOFING IS REQUIRED, ADJUST FIREPROOFING THICKNESS BASED ON MEMBER SIZES. SEE ARCHITECTURAL DRAWINGS FOR FIREPROOFING REQUIREMENTS AND THICKNESS.

15. THE FABRICATOR IS RESPONSIBLE FOR THE DESIGN AND DETAILING OF STEEL STAIRS. STAIRS SHOWN ON THE STRUCTURAL DRAWINGS ARE SCHEMATIC AND ARE ONLY INTENDED TO SHOW THE RELATIONSHIP OF MEMBERS CONNECTED. STAIRS SHALL BE DESIGNED BY A PROFESSIONAL ENGINEER REGISTERED IN THE STATE OF THE PROJECT, RETAINED BY THE FABRICATOR.

16. ALL EXPOSED EXTERIOR STEEL SHALL HAVE A GALVANIZED FINISH, UNLESS NOTED OTHERWISE.

EXISTING CONSTRUCTION:

1. ALL DIMENSIONS AND ELEVATIONS TO EXISTING CONSTRUCTION ARE FOR REFERENCE ONLY. FIELD VERIFY DIMENSIONS AND ELEVATIONS PRIOR TO PREPARING SHOP DRAWINGS, FABRICATING MEMBERS (STRUCTURAL ITEMS), AND INSTALLATION.

2. DO NOT CUT ANY REINFORCING STEEL WHILE DRILLING INTO EXISTING CONCRETE.

3. NOTIFY STRUCTURAL ENGINEER OF ANY DISCREPANCIES OF EXISTING CONDITIONS WITH THE STRUCTURAL DRAWINGS.

MEANS AND METHODS:

1. ALPER AUDI, INC. SHALL NOT BE RESPONSIBLE IN ANY WAY FOR CONSTRUCTION MEANS AND METHODS, SEQUENCES, TECHNIQUES OR PROCEDURES.

2. ALPER AUDI, INC. SHALL NOT BE RESPONSIBLE FOR CONTRACTOR'S SCHEDULE OR CONTRACTOR'S FAILURE TO COMPLY WITH CONTRACT DOCUMENTS.

3. ALPER AUDI, INC. SHALL NOT HAVE CONTROL OVER ACTIONS OF CONTRACTOR, SUBCONTRACTOR, AND ANY OF THEIR AGENTS/EMPLOYEES PERFORMING ANY CONSTRUCTION ACTIVITIES.

MISCELLANEOUS:

1. STRUCTURAL DRAWINGS ARE INTENDED TO BE USED WITH ARCHITECTURAL AND MECHANICAL DRAWINGS. CONTRACTOR IS RESPONSIBLE FOR COORDINATING SUCH REQUIREMENTS INTO THEIR SHOP DRAWINGS AND WORK.

2. NO OPENING SHALL BE MADE IN ANY STRUCTURAL MEMBER WITHOUT THE WRITTEN APPROVAL OF THE STRUCTURAL ENGINEER.

3. NO CHANGE IN SIZE OR DIMENSION OF STRUCTURAL MEMBERS SHALL BE MADE WITHOUT THE WRITTEN APPROVAL OF THE STRUCTURAL ENGINEER.

4. DO NOT SCALE THESE DRAWINGS, USE DIMENSIONS.

5. THE CONTRACTOR SHALL INFORM THE ARCHITECT & STRUCTURAL ENGINEER IN WRITING OF ANY DEVIATION FROM THE CONTRACT DOCUMENTS. THE CONTRACTOR SHALL NOT BE RELIEVED OF THE RESPONSIBILITY FOR SUCH DEVIATION BY THE ARCHITECT'S & STRUCTURAL ENGINEER'S APPROVAL OF SHOP DRAWINGS, PRODUCT DATA, ETC., UNLESS HE HAS SPECIFICALLY INFORMED THE ARCHITECT & STRUCTURAL ENGINEER OF SUCH DEVIATION AT THE TIME OF SUBMISSION, AND THE ARCHITECT & STRUCTURAL ENGINEER HAS GIVEN WRITTEN APPROVAL TO THE SPECIFIC DEVIATION.

6. ALL THINGS WHICH, IN THE OPINION OF THE CONTRACTOR, APPEAR TO BE DEFICIENCIES, OMISSIONS, CONTRADICTIONS, OR AMBIGUITIES, IN THE PLANS AND SPECIFICATIONS SHALL BE BROUGHT TO THE ATTENTION OF THE ARCHITECT & STRUCTURAL ENGINEER. PLANS AND/OR SPECIFICATIONS WILL BE CORRECTED, OR WRITTEN INTERPRETATION OF THE ALLEGED DEFICIENCY, OMISSION, CONTRADICTION OR AMBIGUITY WILL BE MADE BY THE ARCHITECT & STRUCTURAL ENGINEER BEFORE THE AFFECTED WORK PROCEEDS.

7. CHECK ALL DIMENSIONS AGAINST REQUIREMENTS OF OTHER CONTRACT DOCUMENTS. FIELD VERIFY DIMENSIONS RELATING TO EXISTING CONDITIONS PRIOR TO ORDERING MATERIALS AND FABRICATION.

8. WHERE DIMENSIONS OR WEIGHTS OF EQUIPMENT OR SYSTEMS ARE VARIABLE FROM MANUFACTURER TO MANUFACTURER, VERIFY DIMENSIONS AND WEIGHTS SHOWN ON DRAWINGS WITH SELECTED MANUFACTURER PRIOR TO ORDERING MATERIALS. NOTIFY STRUCTURAL ENGINEER OF DISCREPANCIES.

9. DO NOT PLACE EQUIPMENT WHEN SHIPPING OR OPERATING WEIGHT EXCEEDS WEIGHT INDICATED ON STRUCTURAL DRAWINGS.

10. NO MODIFICATION, ALTERATION OR REPAIR SHALL BE MADE WITHOUT PRIOR REVIEW BY STRUCTURAL ENGINEER. SUBMIT DETAILS AND CALCULATIONS PREPARED BY A PROFESSIONAL ENGINEER REGISTERED IN STATE WHERE PROJECT IS LOCATED AND EMPLOYED BY CONTRACTORS.

DEFERRED SUBMITTALS:

1. THE FOLLOWING PROJECT COMPONENTS REQUIRE DESIGN TO BE PROVIDED BY A QUALIFIED PROFESSIONAL ENGINEER, LICENSED IN THE STATE OF THE PROJECT:

   A. ROOFTOP EQUIPMENT CURBS/RAILS AND THEIR CONNECTION TO SUPPORTING STRUCTURE.
   B. ANCHORAGE AND BRACING OF INTERIOR AND EXTERIOR MEP EQUIPMENT.

2. ALL DESIGNS MUST INCLUDE SIGNED AND SEALED CALCULATIONS SUBMITTED AT THE SAME TIME THE SHOP DRAWINGS ARE SUBMITTED. THE CALCULATIONS MUST INCLUDE A STATEMENT THAT THE SHOP DRAWINGS HAVE BEEN REVIEWED BY THE ENGINEER AND THAT THE SHOP DRAWINGS REFLECT THEIR DESIGN INTENT. SHOP DRAWINGS SUBMITTED WITHOUT SIGNED AND SEALED CALCULATIONS AND A STATEMENT THAT THEY HAVE BEEN REVIEWED BY THE ENGINEER WILL BE REJECTED.

3. DEFERRED SUBMITTAL BUILDING COMPONENETS SHALL ACCOMMODATE ALLOWABLE BUILDING DEFLECTIONS AND DRIFT AS SET FORTH BY THE BUILDING CODE AND CONSTRUCTION TOLERANCES AS DEFINED BY THE AISC "CODE OF STANDARD PRACTICE FOR STEEL BUILDINGS AND BRIDGES" AND ACI "SPECIFICATION FOR TOLERANCES FOR CONCRETE CONSTRUCTION AND MATERIALS".

PROFESSIONAL ENGINEER
MICHAEL C. LUBKEMAN
6960
STRUCTURAL
STATE OF CALIFORNIA
11/20/2025

REVISIONS		
No.	Description	Date

ALPER ▪ AUDI
STRUCTURAL ENGINEERS
6 Cityplace Drive Suite 1025 | St. Louis, MO 63141
phone 314.432.8600 | www.alperaudi.com

ULTA BEAUTY WAREHOUSE
850 EAST CENTRAL AVE
FRESNO, CA 93706

Sheet Name:
STRUCTURAL COVER SHEET

Project Number:	25093
Date:	11/20/2025
Drawn By:	DMM
Checked By:	MCL

Sheet Number:
S0.00

11/20/2025 3:14:24 PM
Autodesk Docs://25093 Ulta Fresno New RTUs/25093 Ulta Fresno New RTUs_RS23_Central.rvt