

P&PS Pressure Test	Document No: IB-HS-WI-0338-IB-F-01 Rev 1	
	Project No:	
Risk Assessment Form		

This form MUST be completed prior to each and every test

Permit No:

System on Test				
Location of Test		Start Point		End Point
Date/Time of Test				

On the questions below, tick the appropriate box, then add up the score to give the total.
The total score will indicate the level of risk associated with each test.

			Score			Score			Score
Is the test medium	Hydrostatic		1				Pneumatic		3
Is the line to be tested	Stainless Steel		1	Carbon St./Copper		2	Plastic		3
Is the length of the line	0m – 50m		1	51m – 250m		2	Over 251m		3
Is the diameter of the line	Under 1½” (38mm)		1	1½” - 2½” (38-63.5mm)		2	Over 2½” (63.5mm)		3
Is the test pressure	Under 100psi		1	101 – 180 psi		2	Over 180psi		3
Is the test duration	0 – 8 hrs		1	9 – 24 hrs		2	Over 24 hrs		3
Is the line to be tested	Fully welded		1	Mechanically fixed		2	Glued		3
Is the line to be tested	Underground		1	Outside buildings		2	Inside buildings		3

Total Score (max 24)	
----------------------	--

Score	Risk	Minimum Requirements
8 - 10	LOW	SSoW, line walk by test crew foreman, contractor supervisor, Jacobs DS.
11 - 15	MEDIUM	SSoW, line walk by test crew foreman, contractor supervisor, Jacobs DS, Jacobs Safety, and JHA (final signature by Jacobs CS)
>16	HIGH	SSoW, line walk by test crew foreman, contractor supervisor, Jacobs DS, Jacobs Safety, and JHA (final signature by Jacobs CM). May require out of hours work.

Crew Forman (Name)		Contact Number	
Tick when complete			
☐	System has correct service labels adequately located	☐	Security notified of 24 hour test (as applicable)
☐	Pressure test signage is in place every 5m	☐	Clearance required around equipment (electrical, Iss, etc.) verified with system owner
☐	Signage is dated and contact information shown	☐	Dedicated test crew available to patrol line

P&PS Pressure Test	Document No: IB-HS-WI-0338-IB-F-01 Rev 1	Jacobs
Risk Assessment Form	Project No:	Page: 3 of 3

--	--	--	--

Approval / Sign Off

LOW RISK	SIGNATURE	MED RISK	SIGNATURE	HIGH RISK	SIGNATURE
Test Crew Foreman		Test Crew Foreman		Test Crew Foreman	
Contractor Supervisor		Contractor Supervisor		Contractor Supervisor	
Jacobs Discipline Superintendent		Jacobs Discipline Superintendent		Jacobs DS	
		Jacobs HSE		Jacobs HSE	
		Jacobs CS		Jacobs CS	
				Jacobs CM	