XY Diameter Profile Report

Site ID	OTEST	Asset No.	MH A - MH B	Date	31/03/2026
City	TEST 02			Material	uPVC
Start No	MH A	Finish No	MH B	Pipeline Length	78.60 m
Location	TOP MH	Location	BOTTOM MH	Internal Diameter	200 mm



Limit Lines

Upper = 5

Lower = -5

Horizontal	True
198.9mm -0.5%	198.2mm
Vertical	**Ovality**
198.5mm -0.7%	1.5%
Capacity	
-6.75cm^2 -2.1%	
Max	
200.6mm 0.3%	
Min	
195.1mm -2.5%	

m 13.0m



90% - Fractile: (X) 1.0% : (Y) -0.8%, Exceeded limits: 0.2%

Comments