Service Bulletin SB-P-017: Mechanical Seal Upgrade for P-100/250

1. Summary

Pumps of type P-100/250 built before 2023 were delivered with a carbon / silicon carbide mechanical seal with EPDM elastomers. On sites with liquid temperatures close to 90 °C, early seal wear has been reported after 6,000 to 9,000 operating hours.

An upgraded seal with silicon carbide / silicon carbide faces and FKM elastomers is now available as kit **SK-250-SIC**. The upgraded seal is recommended at the next scheduled seal replacement.

2. Affected equipment

- All P-100/250 pumps with serial numbers below 23-0000.
- P-80/200 pumps are not affected.

3. Instructions

1 Order kit SK-250-SIC for each affected pump.

2 Replace the seal following P-MT-02 section 5. The fitting dimensions are unchanged.

3 Use only water or the seal lubricant from the kit on FKM elastomers.

4 Record the seal type change in the maintenance ticket and on the pump record card.

4. Technical notes

Item	Original seal	Upgraded seal SK-250-SIC
Faces	Carbon / SiC	SiC / SiC
Elastomers	EPDM	FKM
Max liquid temperature	90 °C	120 °C
Expected life at 85 °C	about 8,000 h	about 16,000 h

The upgraded seal is more sensitive to dry running than the carbon seal. Always fill and vent the pump completely before start-up.