

Laporan Prediksi Dosis CL-80

Waktu prediksi: 2027-01-01 12:00 | Model: XGBoost

Prediksi dosis CL-80: 1.9430 ppm

Fitur	Nilai
Inlet TSS (mg/L)	650.0000
Inlet pH	7.2000
Outlet TSS (mg/L)	105.0000
Outlet pH	7.4000
Inlet Disch (m3/s)	1.7000
Kolom T1	1.0929
Kolom T2	1.0929
Kolom T3	1.0929
Efisiensi_TSS	83.8462
Delta_pH	0.2000
Beban_TSS	1105.0000

Interpretasi lokal: LOCO-based reference-value perturbation. Nilai ini merupakan perubahan prediksi diagnostik, bukan efek kausal.

Fitur	Kontribusi LOCO (ppm)
Inlet TSS (mg/L)	0.0804
Inlet pH	-0.0736
Outlet TSS (mg/L)	-0.0106
Outlet pH	-0.0378
Inlet Disch (m3/s)	0.0398
Kolom T1	-0.1704
Kolom T2	-0.0315
Kolom T3	0.0016
Efisiensi_TSS	0.0681
Delta_pH	0.0171
Beban_TSS	-0.0088