

Laporan Exploratory Data Analysis (EDA) CL-80


Dataset aktif tersanitasi untuk kondisi tanpa Alum dan Lime. Visualisasi menggunakan data hasil prapemrosesan dan 11 prediktor final.

Statistik Deskriptif


Variabel	Count	Mean	Std	Min	Q1	Median	Q3	Max
Inlet TSS (mg/L)	2531	604.4	291.9	127	373.5	527	723	1872
Inlet pH	2531	7.756	0.2367	7	7.6	7.74	7.92	8.64
Outlet TSS (mg/L)	2531	129.2	47.73	23	95	126	160	352
Outlet pH	2531	7.71	0.3565	6.32	7.5	7.75	7.97	8.68
Inlet Disch (m3/s)	2531	2.068	0.4533	0.542	1.81	2.046	2.29	8.9
Kolom T1	2531	2.463	1.392	0.3483	1.362	2.118	3.332	8.92
Kolom T2	2531	2.464	1.391	0.3483	1.362	2.118	3.332	8.92
Kolom T3	2531	2.464	1.391	0.3483	1.362	2.118	3.332	8.92
Efisiensi_TSS	2531	74.36	13.58	-55.91	65.65	76.47	84.81	97.84
Delta_pH	2531	-0.04652	0.2563	-1.26	-0.17	-0.01	0.11	1.25
Beban_TSS	2531	1323	884.9	186.4	697	1093	1681	1.335e+04
Dosis CL-80 (ppm)	2531	2.462	1.392	0.3483	1.362	2.118	3.332	8.92

Distribusi Target


Distribusi Target Dosis CL-80




Boxplot Inlet TSS




Heatmap Korelasi




Korelasi terhadap Target




Trend Dosis CL-80




Trend TSS




Trend pH



Trend Debit



Variance Inflation Factor



Estimasi Densitas Kernel (KDE) Target Dosis CL-80

