

SYNTHETIC DOCUMENT — NOT A REAL RFP OR PROPOSAL. Customers, procurement identifiers, personnel, metrics, references, outcomes and pricing here are invented for a training exercise. Nothing in this document describes Bell's actual capabilities, certifications, staffing, or commercial terms. Do not quote, forward, or reuse it in any customer-facing material.

Tender KBH-2026-CN-441 — Fibre Optic Cable Plant Construction, Transmission Corridors

Issued by: Kittiwake Bay Hydro Corporation, Supply Chain and Contracts

Issue date: 27 July 2026

Mandatory site meeting: 13 August 2026 at 9:00 a.m., Corrieburn Generating Station, visitor gate

Closing date and time: 11 September 2026 at 11:00 a.m. local time

Contract period: From notice to proceed to substantial performance of the Work, which must be achieved not later than 30 November 2027, followed by a two-year warranty period on the completed Work.

Enquiries: Enquiries must be submitted in writing through the Corporation's supplier portal not later than ten calendar days before the closing time. The Corporation answers enquiries of general application by numbered addendum issued to every registered Bidder. No statement by any employee, engineer, inspector or agent of the Corporation, whether made at the site meeting or otherwise, varies this tender unless it is issued by addendum.

1. Invitation to Bid

Kittiwake Bay Hydro Corporation invites bids for the construction of fibre optic cable plant along the transmission corridors described in section 3. The Work is a construction contract for the supply of labour, equipment, materials and incidentals, and for the execution of aerial and underground cable plant installation, splicing, testing, restoration and as-built documentation, to be performed on and adjacent to energised transmission and switching assets owned and operated by the Corporation.

The Corporation is procuring constructed plant, which it will own, operate and maintain itself on completion. This tender is not a procurement of a telecommunications service, a managed service, capacity, or any ongoing operation of the completed plant. No part of the completed Work will be operated by the successful Bidder, and the Corporation will entertain no bid that proposes to retain title to any part of the installed plant or to charge for its use.

The completed plant will carry teleprotection, control and telemetry traffic between the Corporation's generating stations and switching stations. It forms part of the Corporation's operational technology estate and is separated by the Corporation's own operating procedures from its administrative network, which is not touched by this Work.

2. Instructions to Bidders

Site meeting. Attendance at the site meeting on the date stated on the first page of this tender is mandatory. The meeting proceeds to the Corrieburn and Redmarsh corridor segments, and attendance requires safety footwear, high-visibility apparel, eye protection and a hard hat. A Bidder that does not attend and sign the attendance register in person is not eligible to bid, and its bid will be returned unopened. Attendance by a proposed subcontractor does not satisfy this requirement on behalf of the Bidder.

Submission. Bids are submitted through the Corporation's supplier portal as two separate uploads: the technical submission required by sections 4 and 5, and the priced bid form required by section 6. A bid that places any price, rate or contract value in the technical submission will be found non-compliant and given no further consideration.

Bid security. Each bid must be accompanied by a bid bond in the amount of ten percent of the total bid price, issued by a surety licensed to transact business in the province, together with a consent of surety to issue a performance bond and a labour and material payment bond, each in the amount of fifty percent of the contract price, within fifteen days of notice of award.

Irrevocability. Each bid remains open for acceptance for ninety days from the closing time. Bidders must acknowledge every addendum on the bid form; a bid that fails to acknowledge an addendum affecting price or scope may be rejected.

3. Description of the Work

3.1 Extent. The Work comprises 184 route kilometres of fibre optic cable plant in four corridor segments: Corrieburn to Redmarsh Switching Station, Redmarsh to Auldmere Generating Station, Auldmere to Fenwick Switching Station, and the Blackthorn Falls spur. Of that extent, 138 kilometres is aerial construction on existing transmission structures and 46 kilometres is underground construction. The plant terminates at three generating stations, two switching stations, the Saltbank thermal standby plant and fourteen distribution and switching sites along the corridors.

3.2 Aerial construction. All-dielectric self-supporting cable is to be installed on existing steel lattice and tubular steel transmission structures, using attachment hardware supplied under the contract and approved by the Corporation's engineer before installation. The Work includes structure attachment, stringing under controlled tension, sag and tension verification against the issued tables, vibration damping where the design requires it, and bonding and grounding of hardware. Sixty-one kilometres of the aerial extent lies inside corridors that will remain energised throughout construction, and stringing in those segments must be executed by methods that maintain the minimum approach distances stated in the Corporation's Work Protection Code at all times, including under conductor sway and under cable pull failure.

3.3 Underground construction. Underground construction comprises open trenching, horizontal directional boring, installation of duct and innerduct, and the supply and installation of thirty-eight splice vaults and one hundred and nine handholes. Three crossings require directional boring: two watercourse crossings requiring approval from the provincial environment authority, and one railway crossing requiring a crossing agreement. Existing duct is to be proofed and rodded before cable installation, and the Bidder is responsible for locating and protecting all buried plant, whether or not it is shown on the drawings.

3.4 Splicing, testing and acceptance. The Work includes fusion splicing of all fibres at every splice point, installation and sealing of splice closures, and end-to-end acceptance testing of every fibre: bidirectional optical time domain reflectometer traces at two wavelengths, insertion loss measurement against the issued loss budget, and optical return loss at every termination. Acceptance requires the submission of complete test records, splice loss records, and as-built drawings sealed by a Professional Engineer licensed in the province, in the Corporation's drawing standard and in its records format.

3.5 Constraints. No trenching or boring may be performed between 1 December and 15 April. Corridor access is by permit issued per segment per day, and work inside a fenced switching or distribution compound is a scheduled event requiring a Corporation site authority in attendance. Work requiring a transmission line outage must be requested against the Corporation's annual outage plan not less than one hundred and twenty days in advance, and the Corporation gives no assurance that any requested outage will be granted. Traffic control on provincial highways and municipal roads is the Bidder's responsibility, under permits the Bidder obtains in its own name.

3.6 Excluded. Design of the cable plant, which is issued for construction with this tender; supply of the optical cable itself, which is free-issued by the Corporation to the Bidder at the Corrieburn store; the optical transmission and teleprotection equipment terminating the plant; and all structural reinforcement of transmission structures, which is under separate contract.

4. Bidder Qualification Requirements

Each requirement below is assessed on a pass or fail basis before any bid is scored under section 5. A bid that fails any one of them will be given no further consideration, and the Corporation will not waive a qualification requirement. Bidders must complete the Compliance column and cite the part of the technical submission in which each requirement is evidenced.

Ref	Requirement	Compliance
Q1	The Bidder is prequalified as a Class 1 telecommunications plant constructor under the Corporation's Contractor Qualification Programme at the closing time, and states its programme registration number.	
Q2	The Bidder holds a Certificate of Recognition under a provincially approved safety certification programme, current at the closing time, and states its lost-time injury frequency for each of the last three calendar years.	
Q3	The Bidder provides bid security and consent of surety in the amounts required by section 2.	
Q4	The Bidder names the Professional Engineer, licensed to practise in the province, who will seal the construction and as-built drawings, and provides that engineer's licence number.	
Q5	The Bidder names a Utility Work Protection Coordinator and confirms that every worker assigned inside an energised corridor is qualified under the Corporation's Work Protection Code, or will be so qualified before mobilisation.	
Q6	The Bidder has completed, as prime contractor, three fibre optic cable plant construction contracts of not less than forty route kilometres each within the last five years, and provides for each the owner, the extent constructed and the date of substantial performance.	

5. Technical Submission Requirements

Bids that pass every qualification requirement are scored against the requirements below, out of a total of sixty points allocated as shown. Each requirement is scored on the material in the technical submission itself. The evaluation committee will not infer an answer from another part of the submission, from the Bidder's prior dealings with the Corporation, or from work the Bidder has performed on the Corporation's administrative estate.

Ref	Requirement	Points
-----	-------------	--------

T1	Construction methodology for the aerial extent: structure attachment, tensioning and stringing method, sag and tension verification, and the method by which minimum approach distances are maintained in energised segments.	12
T2	Construction methodology for the underground extent: trenching, directional boring, bore profile and entry and exit control, duct and vault installation, buried plant locating, and duct proofing.	10
T3	Splicing, testing and acceptance method, including the test regime proposed against section 3.4 and the form in which test records and sealed as-built drawings will be submitted.	8
T4	Corridor access, outage coordination and work protection: how permits, site authority attendance and outage requests are planned and sequenced, and how the Bidder proceeds when a requested outage is refused.	8
T5	Permits, third-party approvals and traffic control: the approvals the Bidder will obtain in its own name, the sequence in which it will obtain them, and the traffic control plans proposed for the highway and municipal segments.	6
T6	Environmental protection and restoration: erosion and sediment control, watercourse crossing protection, spill response, and restoration of ground disturbed by trenching to the standard of the affected land authority.	8
T7	Construction schedule, crews and equipment: crew composition and number, boring and stringing equipment committed to the Work, the sequence of the four corridor segments against the seasonal constraint in section 3.5, and the monthly schedule update the Bidder will submit.	8

6. Bid Price

Price is submitted on the bid form issued with this tender, uploaded separately from the technical submission, and is worth forty points. The bid form requires a unit price for each item in the schedule of quantities — including aerial

cable installation per route kilometre by structure type, trenching and boring per metre, vault and handhole installation per unit, splicing per fibre, and acceptance testing per span — extended against the Corporation's stated quantities to a total bid price. Unit prices are stated in Canadian dollars, exclusive of applicable taxes and inclusive of all labour, equipment, hardware, consumables, permits, traffic control, restoration, mobilisation and demobilisation. Unit prices govern in the event of an arithmetic discrepancy, and apply without adjustment to any variation in quantity ordered under the contract.

Out of scope for this exercise. The bid form and schedule of quantities are not reproduced or populated in this synthetic corpus, and no rate, unit price or contract value appears in it.

7. Evaluation and Award

Evaluation proceeds in three stages, and a bid must clear each stage to reach the next. At the first stage the committee confirms attendance at the mandatory site meeting and assesses each bid against the qualification requirements at section 4 on a pass or fail basis. At the second stage each remaining bid is scored against the technical submission requirements at section 5, out of sixty points, each requirement scored independently by every committee member and then agreed as a single consensus score with reasons recorded. At the third stage the priced bid forms of the remaining bids are opened and scored out of forty points, the lowest compliant total bid price receiving the full allocation and every other bid a proportion of it.

The technical and price scores are added to give a total out of one hundred. A bid scoring fewer than thirty-six of the sixty technical points is found technically non-compliant and its priced bid form is not opened, whatever its price. The Corporation intends to recommend award to the Bidder with the highest total, but reserves the right to accept or reject any bid, to cancel this tender at any time, and to require a Bidder to demonstrate its stringing method on a test span before award. The Corporation is not liable for any cost of preparing a bid.