



GENERAL NOTES:

NOTES:

- SDV TO BE LOCATED AS CLOSE TO VESSEL AS PRATICABLE.
- PROVISION FOR CORROSION INHIBITOR INJECTION.
- VIA COMPRESSOR PACKAGE UCP.
- 2X100%.
- RODDING OUT POINT.
- DISSIMILAR TYPE.
- LAHH-1341 IS A CRITICAL ALARM AT LEAST 10 MINUTES FOR OPERATING TIME.

HOLDS:

- SEPARATOR INLET DEVICE, INTERNAL DEVICE AND NOZZLE SIZE.
- DELETED
- DELETED
- % C-C
- REDUNDANCY FOR LEVEL INSTRUMENT.
- DELETED
- DELETED
- INSULATION THICKNESS.
- CHECK VALVE TYPE.
- AMOUNT OF DRAIN HUB HAZARDOUS.

VALVE NUMBER  
USED ON  
THIS DRAWING  
10901-10939

REFERENCE DRAWING:

| NO. | DATE     | REVISION                  |
|-----|----------|---------------------------|
| H01 | 14/03/18 | ISSUED FOR DESIGN         |
| F02 | 29/01/18 | ISSUED POST-HAZOP         |
| F01 | 13/11/17 | ISSUED FOR HAZOP          |
| E01 | 09/10/17 | ISSUED FOR COMPANY REVIEW |
| D01 | 22/09/17 | ISSUED FOR IDC            |

|     |     |     |     |
|-----|-----|-----|-----|
| WCT | NAK | WEK | THS |
| PBU | NAK | WEK | THS |
| PBU | NAK | WEK | THS |
| PBU | NAK | WEK | THS |
| PBU | NAK | WEK | THS |
| PBU | NAK | WEK | THS |



THE ORIGINAL AND ALL COPIES OF THIS DRAWING, INCLUDING ALL INFORMATION ON THIS DRAWING, ARE SOLE PROPERTY OF CHEVRON THAILAND

PROJECT:

UBON PROJECT

TITLE:

PIPING AND INSTRUMENTATION DIAGRAM  
2nd STAGE PRODUCTION COMPRESSOR  
SUCTION SCRUBBER

SCALE:

NTS

DRAWING No:

UBO-UBPG-PRO-PID-WPT-0000-00109-01

PLATFORM:

UBCPP

REVISION:

H01