

Year	Scenario A: Full replacement	Scenario B: Component repair and replacement	Notes
0	Initial VELFAC 200 ENERGY window installed	Initial VELFAC 200 ENERGY window installed	Same starting point for both scenarios
5	No major intervention assumed	Inspection, cleaning, adjustment or minor maintenance	Maintenance timing is illustrative and should be treated as an assumption
10	No major intervention assumed	Possible hardware adjustment, seal inspection or minor component service	Based on interview evidence that mechanisms and handles may wear before the full frame
15	No major intervention assumed	Possible hardware, handle or fitting replacement	Timing will be tested in Step 12 assumption table
20	No major intervention assumed	Possible gasket, seal or glazing-performance inspection	Use as qualitative scenario, not exact prediction
25	Complete window replacement may occur in this scenario	Possible glazing unit replacement or larger component intervention while frame is retained	25 years is used as a plausible comparison point because spare-part problems may become more relevant in older systems
30	Newer full replacement window continues in use	Continued maintenance, adjustment or component replacement as needed	Scenario B depends on continued component access and compatible spare parts
35	No major intervention assumed	Possible second repair or replacement event for shorter-life components	Repair frequency remains uncertain
40	No major intervention assumed	Long-life frame retained if performance and condition remain acceptable	Frame retention is the central logic of Scenario B
45	No major intervention assumed	Final inspection or minor intervention before end of study period	Exact intervention depends on assumptions
50	End of study period; scenario includes one initial window and one full replacement	End of study period; scenario includes retained frame and multiple component-level interventions	Compare likely burden categories rather than exact impact values