

Electrical Installation Certificate

Sample certificate for platform testing

BUILDING

ZE15 Rueil

CERTIFICATE NO.

ELC-DUMMY-ZE15-2026

POSTAL ADDRESS

34 test street
762536 City

COUNTRY

FR

Inspection summary

Installation type: Low-voltage residential / mixed-use building

Nominal voltage: 230/400 V | Frequency: 50 Hz

Earthing system: TT | Main protective device: 40 A / 30 mA RCD

Scope: Incoming supply, main board, circuits, and equipotential bonding

RESULT: SATISFACTORY

Issued: 20 September 2026

Valid until: 20 September 2031

Findings

1. Main switchgear labelled and accessible.
2. RCD trip time within 40 ms at rated residual current.
3. Insulation resistance above 1 megohm on tested circuits.
4. Protective bonding present at water and gas services.
5. No dangerous defects recorded. Dummy observations only.

Issued by

Demo Issuer Co | Accreditation 001 | Inspector: A. Sample

This PDF is a placeholder for hashing and upload tests. It has no legal value.