

Property Condition Assessment

Rivergate Apartments | Condensed capital needs memo

Inspection Date: February 10, 2026
Inspector: West Ridge Building Analytics
Report Type: Summary memorandum for underwriting and valuation support

Summary of Findings

The subject property is in generally good condition for its age. No life-safety deficiencies requiring immediate shutdown were observed. Deferred items are concentrated in exterior sealants, parking lot striping, stair nosings, and selected HVAC units nearing end of useful life.

A near-term reserve of approximately \$214,000 is recommended over the next 24 months. Roughly \$78,000 of that total should be considered immediate or year-one work. Unit interiors renovated in 2019 remain competitive and do not require broad replacement.

Capital Items

System	Condition	Recommended Action	Budget	Timing
Roofing	Fair	Localized membrane repairs; monitor drains	\$22,000	12 months
Parking Lot	Fair	Seal coat and restripe	\$18,500	12 months
HVAC	Mixed	Replace 6 aging condensers	\$54,000	6-18 months
Stairs / Railings	Good/Fair	Replace worn stair nosings in two buildings	\$9,500	Immediate
Exterior Paint	Good	Touch-up only	\$7,000	As needed
Landscaping / Drainage	Fair	Regrade minor ponding near Building C	\$13,000	6 months

Valuation Relevance

Condition does not support a major downward value adjustment beyond ordinary reserves. However, any valuation narrative should acknowledge the 24-month reserve schedule and the concentration of HVAC replacements. Because the renovation program is still perceived as current by tenants, the property remains competitive without a major capex reset.

Header artifact example for parser testing: Rivergate Apartments - PCA Summary - Confidential - 2026