Date of Request: April 9, 2021 Request No. SANE-31
Due Date: April 19, 2021 NG Request No. NG-1541

KEYSPAN GAS EAST CORPORATION d/b/a NATIONAL GRID
THE BROOKLYN UNION GAS COMPANY d/b/a NATIONAL GRID NY
Case Nos. 19-G-0309 & 19-G-0310
Gas Utilities Rates

Request for Information

FROM: Kim Fraczek

TO: National Grid

SUBJECT: Gas Infrastructure

Request:

1.In response to Sane IR-30, when asked about cost recovery for $749,000 spent on the Greenpoint CNG Off Loading Facility, the Company said "These costs are not in KEDNY's revenue requirement."
a. Does this mean shareholders will be paying those costs?
b. Does this mean these costs will not be recovered from ratepayers?

2. In response to Sane IR-30 the Company said $4,167,000 spent on KEDNY CNG Facility Site1 "was a blanket program covering all CNG projects under development until a site was selected. These costs, which includes the costs of the CNG skids, have since been allocated to the CNG projects in KEDLI's service territory."
a. To clarify, will KEDNY or KEDLI customers be paying the $4,167,000 costs?
b. How much money was spent on CNG skids? And where will those CNG skids be used now?

3. In response to DPS-1091 9(b), referring to Phase 5 of the MRI Pipeline, the Company said that "The loop created by Phase 5 addresses the flow constraint that increasing CNG and LNG gas supplies from Greenpoint back to the system via the existing 16-inch steel main will otherwise create."
a. Please describe the flow constraints presented by the existing 16-inch main including pressure and capacity constraints.

4.What percentage of gas stored in the LNG tanks at the Company's Greenpoint facility was used during Winter 2020/2021?

Response:

1.

a. No.
b. No.

2.

a. Project costs will be included in rate base and recovered through KEDLI's rates.
b. The cost is approximately $4.11M per site (skids, header and truck modules). The skids will be used in KEDLI's territory.

3. Gas traveling via the existing Greenpoint Spur 16-inch main between Greenpoint and the rest of the transmission system must travel through the spur and the backbone line because there is no other path. Thus, the flow path is constrained currently. The loop created by MRI Phase 5 provides a path for the gas to flow between Greenpoint and the system that does not require it to flow through the spur and backbone line first. By removing the current path constraint, the efficiency and reliability of existing flow will improve.

4. The Company utilized 12% of the available tank volume during the 2020-2021 winter.

Name of Respondent:	Date of Reply:
Christopher Connolly	April 19, 2021