

Council Request for Further Information

Project: Proposed Mixed-Use Development

Address: 24-28 Wattle Street, Marrickville NSW

DA Reference: DA/2026/0417

Date: 21 April 2026

Attention: Planning Consultant / Applicant

Council has reviewed the submitted development application material, including the architectural drawings and services markups. The proposal includes rooftop mechanical plant serving the ground-floor commercial tenancies and upper-level residential apartments.

Council requires further information to assess potential acoustic impacts from the proposed rooftop plant on nearby residential receivers.

Please provide the following:

1. A rooftop mechanical plant acoustic assessment prepared by a suitably qualified acoustic consultant or mechanical/acoustic engineer.
2. Confirmation that cumulative noise from all proposed rooftop mechanical equipment, including condensers, exhaust fans, supply air fans, and any future commercial kitchen exhaust equipment, will not exceed:
 - 35 dB(A) LAeq, 15 min at the nearest residential receiver during the night period, being 10:00 pm to 7:00 am, and
 - background noise level + 5 dB(A) at the nearest affected residential receiver during the day and evening periods.
3. Identification of the nearest affected residential receivers, including residential properties to the north and east of the site.
4. Details of any proposed acoustic mitigation measures, such as plant screening, acoustic louvres, attenuators, vibration isolation, barriers, or operational restrictions.
5. Updated rooftop plant layout drawings showing the location of all proposed mechanical equipment and any associated acoustic treatment.

Council cannot complete its assessment of the application until the above information has been provided.

Megan Ellis
Senior Development Assessment Planner
Inner West Council