

SECTION 34 11 00

RAILROAD TRACK AND ACCESSORIES
04/08

PART 1 GENERAL

1.1 UNIT PRICES

Each bid item will be measured by the unit listed in the Bid Schedule. Materials must be actually used or installed in the completed work. No measurement will be made for wasted materials or materials used for the convenience of the Contractor. The quantities thus determined will be paid for at their respective unit prices as shown in the Unit Price Schedule. This payment will constitute full compensation for furnishing materials, equipment, and labor and incidentals necessary to complete the work required, and for removing and properly disposing of replaced materials. Any required work or materials, such as lubricants and creosote, which are not listed on the Unit Price Schedule, are considered subsidiary to the items listed, and include their cost in the costs for the listed items. Bid items are self-explanatory except as described below.

1.1.1 Rail

Rail will be paid for on a unit price per linear meter of rail weight shown in the Unit Price Schedule. Stock rails and closure rails will be included for payment in the turnout unit price. The rails in road crossings will be included for payment for rail. Payment [will] [will not] include such items as [furnishing the rail,] [cutting and drilling the rail,] [installing the rail,] [and] [delivering the old rail removed from track to the designated storage area].

1.1.1.1 Out-of-Face Rail Replacement

Measurement will be by the linear meter of 25 m or more of contiguous replacement rail acceptably installed. Payment will be at the contract unit price per linear meter for "Out-of-Face Rail Replacement".

1.1.1.2 Spot Rail Replacement

Measurement will be by the linear meter of less than 25 m of contiguous replacement rail acceptably installed. Existing rails which are adjusted in the track during spot rail replacement will not be measured for payment. Existing rails which must be transposed or exchanged during spot rail replacement, as determined by the Contracting Officer, [will] [will not] be measured for payment. Payment will be at the contract unit price per linear meter for "Spot Rail Replacement".

1.1.2 Joint Bars

Joint bars will be paid for at the unit price per pair under "Furnish Joint Bars" for the following items: [_____].

1.1.3 Compromise Joints

Compromise joints will be paid for at the contract unit price per joint for "Furnish Compromise Joint".

1.1.4 Turnouts

1.1.4.1 New Turnouts

Turnout construction will be measured and paid for at the contract unit price for "Furnish and Install New Turnouts". Include the complete switch, switch stand, connecting rod, switch rods, attachments, switch points, slide plates, rail braces, frog, fillers, joint bars and track bolts for the switch and frog, switch ties, and all other required items, including rail, rail anchors, standard tie plates, and spikes. Ballast will be paid for at the unit price for ballast. The pay limit for turnout construction begins at the center of the No. "0" tie at the front of the turnout to the last long switch tie of the rear of the turnout.

1.1.4.2 Turnout Repair

The following are turnout and track crossing unit price pay items:

1.1.4.2.1 "Switch Repair"

- (1) "Replace Switch Stand" - Each
- (2) "Replace Switch Points" - Each
- (3) "Install or Replace Heel Fillers" - Each
- (4) "Install or Replace Heel Filler Bolt Assembly" - Each
- (5) "Install or Replace Switch Plates" - Each
- (6) "Install or Replace Switch Braces" - Each
- (7) "Remove and Respike Braces and Plates" - Each
- (8) "Adjust Adjustable Braces" - Each
- (9) "Install or Replace Switch Rods and Clips" - Each
- (10) "Replace Connecting Rod" - Each
- (11) "Grind and Dress Switch Point and Adjacent Stockrail" - Each
- (12) "Clean, Adjust, and Lubricate Switch" - Each
- (13) "Rebuild Switch Point Protector" - Each
- (14) "Rebuild Switch Point" - Each
- (15) "Paint Switch Stand" - Each

1.1.4.2.2 "Frog Repair"

- (1) "Replace Frog" - Each
- (2) "Install or Replace Frog Plates or Hook Plates" - Each
- (3) "Rebuild Frog" - Each
- (4) "Grind and Dress Frog, Install or Replace Frog Bolt Assembly" - Each

1.1.4.2.3 "Guard Rail Repair"

- (1) "Replace Guard Rail" - Each
- (2) "Install or Replace Guard Rail Plates" - Each
- (3) "Install or Replace Guard Rail Bolt Assembly" - Each
- (4) "Install or Replace Guard Rail Fillers" - Each
- (5) "Install or Replace Clamp Assembly including Fillers and Wedges" - Each
- (6) "Tighten all Bolts in Turnouts" - Each

1.1.5 Track Crossing

Track crossings will be paid for at the contract unit price for "Furnish and Install Track Crossing".

1.1.6 Crossties and Switch Ties

Crossties will be measured for each defective crosstie removed and for each new crosstie acceptably furnished and installed as indicated. Switch ties will be measured for each length of defective switch tie removed and for each length of new switch tie acceptably furnished and installed as indicated. Defective crossties and switch ties removed become the property of the Contractor. Crossties will be paid for at the contract unit price for each type listed below:

"140 by 230 mm Grade Crosstie"
"140 by 280 mm Grade Crosstie"

Switch ties will be paid for at the contract unit price each for the length of switch tie listed below:

"2 m Switch Tie"
"2.2 m Switch Tie"
"2.4 m Switch Tie"
"2.6 m Switch Tie"
"2.8 m Switch Tie"
"3 m Switch Tie"
"3.2 m Switch Tie"
"3.4 m Switch Tie"
"3.6 m Switch Tie"
"3.8 m Switch Tie"
"4 m Switch Tie"
"4.2 m Switch Tie"
"4.4 m Switch Tie"
"4.6 m Switch Tie"
"4.8 m Switch Tie"
"5.0 m Switch Tie"
"5.2 m Switch Tie"
"5.4 m Switch Tie"
"5.6 m Switch Tie"
"5.8 m Switch Tie"
"6 m Switch Tie"
"6.2 m Switch Tie"
"6.4 m Switch Tie"
"6.6 m Switch Tie"
"6.8 m Switch Tie"
"7 m Switch Tie"

1.1.7 Geotextiles

Geotextile quantities will be paid for at the unit price as shown on the Unit Price Schedule. Payment for material used in laps, seams, or extra lengths such as anchorage and for associated equipment such as securing pins along with the associated materials, equipment, labor, and operations is included in the contract unit price for "geotextile" and do not pay for separately. For payment purposes, installed geotextile will be measured in place to the nearest square meter of placement area. Only material must be actually used or installed in the completed work will be paid for.

1.1.8 Ballast, Out-of-Face Surface and Aligning

Measure ballast based upon certified scale tickets for railcars or other delivery vehicles. Payment for ballast material will be made at the

contract unit price per net metric ton of each gradation acceptably furnished and placed in track for "Furnish and Place Ballast". Submit copies of waybills and delivery tickets during the progress of work. Before the final statement is allowed, file certified waybills and delivery tickets for ballast actually used. Out-of-Face Surface and Aligning will be measured by the unit track-meter for each track-meter of raise of each type or fraction thereof, acceptably performed. Payment will be at the contract unit price per track meter for each item given below:

"Out-of-Face Surface and Aligning - skin Lift"
 "Out-of-Face Surface and Aligning - 50 mm Raise"
 "Out-of-Face Surface and Aligning - 100 mm Raise"
 "Out-of-Face Surface and Aligning - 150 mm Raise"
 "Out-of-Face Surface and Aligning - [_____] mm Raise"

1.1.9 Subballast

Measure subballast based upon certified scale tickets. Payment for subballast material will be made at the contract unit price per net metric ton of each gradation acceptably furnished and placed and compacted on the track bed for "Furnish, Place, and Compact Subballast." Submit copies of waybills and delivery tickets during the progress of work. Before the final statement is allowed, file certified waybills and delivery tickets for subballast actually used.

1.1.10 Bridge Work

The following items relating to bridge repair will be measured separately for payment and are described under other sections of these specifications.

ITEM DESCRIPTION	UNIT
Timber Pile Repair	Linear m
Timber Pile Replacement	Linear m
Shotcrete Repair	Square m
Bridge Tie Replacement (Open-deck)	Each
Rivet Replacement	Each
Gabion and Gabion Mattress	Cubic m

All other work relating to bridge repairs will not be measured but will be paid for under the contract lump sum prices listed below for work at the following locations: [_____].

1.1.10.1 Lump Sum Payment

Payment for each lump sum is full compensation for all material, labor, equipment, and incidentals necessary to complete the work as shown on the drawings and as specified herein. Lump sum payment will be exclusive of those items specifically covered by the unit prices referenced above. The lump sum payment items include, but are not limited to, permitting,

traffic maintenance, demolition, excavation, excavation supports, backfill, clearing, grubbing, protection of utilities and signals, timber repairs, temporary supports, jacking bridges, concrete construction, ballast retaining walls, pipe, end walls, removal and reinstallation of existing track, surface preparation, and painting.

1.1.10.2 Track over Ballasted-deck Bridges

Repair of track over ballasted-deck bridges will be measured and paid for at the contract unit price for the applicable repair item. Removal of track over ballasted-deck bridges which are to be repaired is considered incidental to the bridge repair. Reconstruction of track over open deck bridges will be measured per track meter and paid for at the contract unit price for TRACK CONSTRUCTION AND OUT-OF-FACE RELAY.

1.1.11 Track Spikes

Measurement will be by the unit keg for each keg of spikes acceptably furnished. Payment will be at the contract unit price per keg under "Furnished Track Spikes". Payment [will] [will not] be made for installation incidental to tie replacement or rail relay.

1.1.12 Track Bolt Assemblies

Track bolt assemblies include bolt, spring washer (nutlock and nut). Measurement will be for each bolt furnished of the following sizes: [____]. Payment will be at the contract unit price per each "Furnished Track Bolt Assembly". Payment [will] [will not] be made for installation incidental to rail joint repair or rail relay.

1.1.13 Tie Plates

Measurement will be for each tie plate acceptably furnished of the following size: [____]. Payment will be at the contract unit price per each under "Furnish Tie Plates". Payment [will] [will not] be made for installation incidental to tie replacement or rail relay.

1.1.14 Rail Anchors

Measurement will be for each anchor of the following weight [____] and section [____] acceptably furnished and installed. Payment will be at the contract unit price for "Furnish and Install Rail Anchors".

1.1.15 Insulated Joints

Insulated joints will be measured for each insulated joint acceptably furnished and installed and will be paid for at the contract unit price for "Furnished and Installed Insulated Joints". Insulated joints will be required for the following rail weight [____] and section [____].

1.1.16 New Bumpers

New bumpers of [____] type will be measured for each bumper acceptably furnished and installed. Payment for furnishing and installing new bumpers will be at the contract unit price per each under "Furnish and Install New Bumpers".

1.1.17 New Wheelstops

New wheelstops of [_____] type will be measured by the unit pair for each pair of wheelstops acceptably furnished and installed. Payment for furnishing and installing new wheelstops will be at the contract unit price for each pair for "Furnish and Install New Wheelstops".

1.1.18 Salvaged Bumpers and Wheelstops

Salvage of existing track bumpers and wheelstops will be measured and paid for each bumper or pair of wheel stops salvaged.

1.1.19 Install Bumpers

Installation of salvaged bumpers will be measured for each bumper under "Install Track Bumper".

1.1.20 Install Wheelstops

Installation of salvaged wheelstops will be measured for each pair of wheelstops acceptably installed and will be paid for at the contract unit price for "Install Wheelstops".

1.1.21 Cushion Head for Bumper

Payment for furnishing and installing cushion head will be at the contract unit price per each new cushion bumper head.

1.1.22 Fastenings

Payment for fastenings used in the installation or reinstallation of bumping post, wheelstops, or cushion head for bumpers are considered incidental and included in the installation pay item for each.

1.1.23 Inner Guard Rail

Inner guard rail will be measured by the linear meter of rail acceptably furnished and installed and will be paid for at the contract unit price for furnished and installed "Inner Guard Rail". Each rail of dual guard rail installations will be measured separately. The other track materials (OTM, i.e., joint bars, bolt assemblies, tie plates and spikes) will be included with the guard rail.

1.1.24 Adjusted gage Rods

Readjusting existing gage rods, as designated by the Contracting Officer, will be measured for each and be paid for at the contract unit price per each under "Adjust gage Rods".

1.1.25 New gage Rods

New gage rods will be measured for each gage rod acceptably furnished and installed and will be paid for at the contract unit price for "Furnish and Install gage Rods".

1.1.26 Salvaged gage Rods

Removal and salvage of existing gage rods will be measured and paid for at the contract unit price for each under "Salvage gage Rod".

1.1.27 Installed Salvaged gage Rods

Installation of salvaged gage rods will be measured for each gauge rod acceptably installed and will be paid for at the contract unit price for each under "Install Salvaged gage Rods".

1.1.28 New Derails

New derails will be measured and paid for at the contract unit price per each new derail acceptably furnished and installed under the bid item "Furnish and Install New Derail".

1.1.29 Installed Derails

Installation of salvaged derails will be measured for each derail acceptably installed and will be paid for at the contract unit price for each under "Install Derail".

1.1.30 Rail Welding

1.1.30.1 Rail Welding Thermite

Thermite rail welding to eliminate joints will be measured for payment based upon the number of rails welded and accepted by the Contracting Officer. Payment will be made for costs associated with rail welding of Government furnished and Contractor furnished rails. No payment will be made for replacement welds found unacceptable by ultrasonic testing.

1.1.30.2 Rail Welding Electric Arc

Electric Arc rail welding of [rebuilt rail ends] [engine burns] [_____] will be measured for payment based upon the number of rails welded and accepted by the Contracting Officer. Payment will be made for costs associated with rail welding of Government furnished and Contractor furnished rails. No payment will be made for replacement rails or replacement welds found unacceptable by ultrasonic testing.

1.1.31 Rail Joint Gap Adjustment

Measurement will be by the unit for each rail gap acceptably adjusted by replacing rail. Rail gaps which are created by rail adjusting (pulling or bumping) operations will not be measured for payment. Payment will be at the contract unit price per each under "Spot Rail Replacement".

1.1.32 Rail Joint Repair

Measurement will be by the unit for each joint acceptably repaired (disassembly, cleaning, inspection, repairing any rail end mismatch, and reassembly with new bolt assemblies). Joints which are repaired coincident with adjacent other repair work, such as spot rail replacement, will not be measured for payment. Payment will be at the contract unit price per each under "Rail Joint Repair".

1.1.33 Respiking

Measurement will be by the unit for each 90.7 kg keg utilized in track respiking. Respiking of joints located in a rail which is being shifted as part of a regaging operation will not be measured for payment. Spiking

of ties installed under this contract will not be measured for payment. Respiking of ties in areas of "Rail Joint Repair" will not be measured for payment. Payment will be made at the contract unit price per tie under "Respiking".

1.1.34 Rail Cropping

Measurement will be by the unit for each rail end acceptably cropped and redrilled. Payment will be at the contract unit price for "Rail Cropping".

1.1.35 Tighten Bolts

Measurement will be made by the track kilometer of bolts tightened, or removing and installing bolts that cannot be tightened, or replacing bolts that are missing. Payment will be made at the contract unit price for kilometer or portion thereof under "Tighten Bolts".

1.1.36 Bolt Assembly Replacement

Measurement will be by the unit for each bolt assembly acceptably replaced. Payment will be at the contract unit price for "Bolt Assembly Replacement".

1.1.37 Track Construction

Track construction is defined as the initial construction of track or total reconstruction of track from the subgrade up. The pay item "Track Construction" includes all plant, equipment, and labor necessary to install rail, ties, and track materials and construct the track in accordance with this specification. Furnish track materials under their respective pay items in the contract Unit Price Schedule. Track construction will be measured and paid for by the track meter for construction acceptably performed at the contract unit price for "Track Construction".

- a. Reconstruction of track through grade crossings and between points 6 meters beyond the outside limits of the crossing surface as shown will be considered to be track construction.
- b. Track relocation or realignment of existing track by more than 1 meter when associated with the relocation of turnouts or other work will be measured and paid for as "Track Construction".
- c. Minor shifting of existing track associated with the replacement of turnouts, or any shifting less than 1 meter is considered to be minor work incidental to related lining and surfacing work.
- d. Where track construction abuts a turnout, the pay limit for construction of various items will be the center of the No. "0" tie in front of the turnout and the last long switch tie at the rear of the turnout and does not include turnout.
- e. Rail, ties, and other track materials for use in track construction will be included for measurement and payment under the respective contract unit prices for furnishing that material. Ballast and subballast will be measured and paid for at the contract unit prices for "Furnish and Install Ballast" and "Furnish, Place, and Compact Subballast". Costs for surfacing and alignment will be included in the contract unit price for "Track Construction".

1.1.138 Track Removal and Salvage

Removal of track will be measured by the track meter, acceptably removed, and materials salvaged, inspected, inventoried, marked, stacked, and transported to designated storage sites. Track removal and salvage will be paid at the contract unit price per track meter under "Track Removal and Salvage".

1.1.139 Track Removal and Scrap

Track removal and scrap will be measured by the track meter of track acceptably removed and all of the scrap materials removed from the installation. Track removal and scrap will be paid for at the contract unit price per track meter of "Track Removed and Scraped".

1.1.140 Turnout Removal and Salvage

Turnout removal and salvage consist of removing all turnout materials, including switch ties. Limits of the turnout removal and salvage will be from the switch point to the last long switch tie. Also, included is the transportation of the materials to the designated storage site. The removal and salvage will be measured for each turnout removed and turnout material salvaged.

1.1.141 Straight Rail Turnout

Straight rail turnout consists of installing crossties in place of switch ties and replacing the previously removed switch and frog with rail and other track materials. The straight rail turnout will be measured for each turnout removed.

1.1.142 Rail Bonds

Rail bonds will be measured for each bond acceptably furnished and installed and will be paid for at the contract unit price for each of the following:

- a. "Furnish and Install Railhead Bonds"
- b. "Furnish and Install Duplex Web Bonds"

1.1.143 Rail Grounds

Rail grounds, including grounding rods, connecting cables, and hardware will be measured by the unit for each rail ground assembly acceptably furnished and installed and will be paid for at the contract unit price for each "Ground Assembly" furnished and installed.

1.1.144 Removal of Existing Crossing Surfaces

Removal and disposal of existing crossing surfaces and adjacent pavements will be measured by the square meter of surface or pavement acceptably removed and will be paid for at the contract unit price for "Pavement Removal". Removal of aggregate crossings will not be measured for payment as this work is considered incidental to "Track Construction".

1.1.145 Salvage of Grade Crossing Panel

Salvage of existing grade crossing panels and other materials will be

measured by the track meter of crossing surface acceptably salvaged and will be paid for at the contract unit price per track meter under "Grade Crossing Panel Salvage".

1.1.146 Track Removal and Track Construction Through Crossings

Track removal through crossings will be measured by the track meter and paid for as "Track Removal". Track construction using existing rail through crossings will be measured and paid for at the contract unit prices as specified in the appropriate sections of this specification. Track construction furnishing rail and other track material will be measured and paid for at the unit prices as specified in the appropriate sections of this specification.

1.1.147 Grade Crossing Surface Installation

Grade crossing surface installation will be measured by the track meter of crossing surface acceptably installed and paid for at the contract unit prices for the items listed below:

TYPE	DESCRIPTION
1	GRAVEL: (SEMI-PERMANENT)
1A	GRAVEL: WITH TIMBER HEADERS
2	TIMBER: FULL DEPTH
2A	TIMBER: FULL DEPTH, PREFABRICATED TIMBER SECTIONAL
3	ASPHALT: FULL-DEPTH WITH TIMBER HEADERS
4	CONCRETE: CAST-IN-PLACE
4A	CONCRETE: PRECAST CROSSING PANELS/SYSTEMS
5	RUBBER (ELASTOMERIC)

1.1.148 Subdrains

Subdrains acceptably installed will be measured and paid for by the linear meter at the contract unit price for "Grade Crossing Subdrains".

1.1.149 Conduit

PVC cable conduit of 100 mm diameter acceptably installed will be measured and paid for by the linear meter at the contract unit price for "Grade Crossing Conduit".

1.1.150 Cleaning Flangeways

Cleaning the gage side flangeways in grade crossings are considered incidental work.

1.1.51 Ultrasonic Testing of Rail

Ultrasonic testing will be measured by the track meter and will be paid for as "Ultrasonic Testing".

1.1.52 Electric Arc Welding

Electric arc welding will be measured and paid for by the item, rebuilt in the track or in the shop and installed in the track. Items to be included are as follows:

- a. "Switch point", each.
- b. "Frog", each.
- c. "Batter rail end", each.
- d. "Guard rail", each.
- e. "Engine burn", each.
- f. "Railroad crossing", each.

1.2 REFERENCES

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by the basic designation only.

AMERICAN ASSOCIATION OF STATE HIGHWAY AND TRANSPORTATION OFFICIALS
(AASHTO)

AASHTO HB-17 (2002; Errata 2003; Errata 2005, 17th Edition) Standard Specifications for Highway Bridges

AASHTO M 288 (2021) Standard Specification for Geosynthetic Specification for Highway Applications

AMERICAN RAILWAY ENGINEERING AND MAINTENANCE-OF-WAY ASSOCIATION
(AREMA)

AREMA Eng Man (2017) Manual for Railway Engineering

AMERICAN SOCIETY FOR NONDESTRUCTIVE TESTING (ASNT)

ANSI/ASNT CP-189 (2020) ASNT Standard for Qualification and Certification of Nondestructive Testing Personnel

AMERICAN WELDING SOCIETY (AWS)

AWS D1.1/D1.1M (2020; Errata 1 2021) Structural Welding Code - Steel

AMERICAN WOOD PROTECTION ASSOCIATION (AWPA)

AWPA U1 (2023) Use Category System: User Specification for Treated Wood

ASTM INTERNATIONAL (ASTM)

ASTM C88 (2018) Standard Test Method for Soundness

	of Aggregates by Use of Sodium Sulfate or Magnesium Sulfate
ASTM C117	(2023) Standard Test Method for Materials Finer than 75-um (No. 200) Sieve in Mineral Aggregates by Washing
ASTM C127	(2015) Standard Test Method for Density, Relative Density (Specific Gravity), and Absorption of Coarse Aggregate
ASTM C131/C131M	(2020) Standard Test Method for Resistance to Degradation of Small-Size Coarse Aggregate by Abrasion and Impact in the Los Angeles Machine
ASTM C136/C136M	(2019) Standard Test Method for Sieve Analysis of Fine and Coarse Aggregates
ASTM C142/C142M	(2017; R 2023) Standard Test Method for Clay Lumps and Friable Particles in Aggregates
ASTM C535	(2016) Standard Test Method for Resistance to Degradation of Large-Size Coarse Aggregate by Abrasion and Impact in the Los Angeles Machine
ASTM C702/C702M	(2018) Standard Practice for Reducing Samples of Aggregate to Testing Size
ASTM D75/D75M	(2019) Standard Practice for Sampling Aggregates
ASTM D217	(2021a) Standard Test Methods for Cone Penetration of Lubricating Grease
ASTM D402/D402M	(2014) Distillation of Cut-Back Asphaltic (Bituminous) Products
ASTM D566	(2017) Standard Test Method for Dropping Point of Lubricating Grease
ASTM D1241	(2015) Materials for Soil-Aggregate Subbase, Base, and Surface Courses
ASTM D1310	(2014) Flash Point and Fire Point of Liquids by Tag Open-Cup Apparatus
ASTM D1556/D1556M	(2015; E 2016) Standard Test Method for Density and Unit Weight of Soil in Place by Sand-Cone Method
ASTM D1557	(2012; E 2015) Standard Test Methods for Laboratory Compaction Characteristics of Soil Using Modified Effort (56,000 ft-lbf/ft ³) (2700 kN-m/m ³)
ASTM D2171/D2171M	(2018) Standard Test Method for Viscosity

	of Asphalts by Vacuum Capillary Viscometer
ASTM D3740	(2019) Minimum Requirements for Agencies Engaged in the Testing and/or Inspection of Soil and Rock as Used in Engineering Design and Construction
ASTM D3776/D3776M	(2009a; R 2017) Standard Test Methods for Mass Per Unit Area (Weight) of Fabric
ASTM D4354	(2012; R 2020) Sampling of Geosynthetics for Testing
ASTM D4355/D4355M	(2014) Deterioration of Geotextiles from Exposure to Light, Moisture and Heat in a Xenon-Arc Type Apparatus
ASTM D4491/D4491M	(2017) Standard Test Methods for Water Permeability of Geotextiles by Permittivity
ASTM D4595	(2017) Standard Test Method for Tensile Properties of Geotextiles by the Wide-Width Strip Method
ASTM D4751	(2020) Standard Test Method for Determining Apparent Opening Size of a Geotextile
ASTM D4759	(2011; R 2018) Standard Practice for Determining the Specification Conformance of Geosynthetics
ASTM D4791	(2019) Flat Particles, Elongated Particles, or Flat and Elongated Particles in Coarse Aggregate
ASTM D6938	(2017a) Standard Test Method for In-Place Density and Water Content of Soil and Soil-Aggregate by Nuclear Methods (Shallow Depth)
ASTM E11	(2022) Standard Specification for Woven Wire Test Sieve Cloth and Test Sieves
ASTM F667/F667M	(2016; R 2021) Standard Specification for 3 through 24 in. Corrugated Polyethylene Pipe and Fittings

INTERNATIONAL ORGANIZATION FOR STANDARDIZATION (ISO)

ISO 6305-3	(1983) Railway Components - Technical Delivery Requirements - Part 3: Steel Sleepers
------------	--

JAPAN ROAD ASSOCIATION (JARA)

JARA Handbook	Japan Road Association Handbook of Pavement Survey and Testing Methods
---------------	--

Japanese Standards Association (JSA)

JIS E 1101	Flat Bottom Railway Rails and Special Rails for Switches and Crossings of Non-treated Steel
JIS A 1102	(2014) Method of Test for Sieve Analysis of Aggregates
JIS A 1110	(2006) Methods of Test for Density and Water Absorption of Coarse Aggregates
JIS A 1121	(2007) Method of Test for Resistance to Abrasion of Coarse Aggregate by Use of the Los Angeles Machine
JIS A 1122	(2014) Method of Test for Soundness of Aggregate by Use of Sodium Sulfate
JIS A 1137	(2014) Method of Test for Clay Lumps Contained in Aggregates
JIS A 1201	(2009) Practise for Preparing Disturbed Soil Samples for Soil Testing
JIS A 1210	(2009) Test Method for Soil Compaction Using a Rammer
JIS B 1186	(2013) Sets of High Strength Hexagon Bolt, Hexagon Nut and Plain Washers for Friction Grip Joints
JIS C 3102	(1984) Annealed Copper Wires for Electrical Purposes
JIS E 1102	Fish Plates for Rails
JIS E 1107	Steel Bolts and Nuts for Fish Plates and Fastenings
JIS E 1108	Rail Spikes
JIS E 1109	Screw Spikes
JIS E 1110	Carbon Steel Tie-Plates
JIS E 1111	Anti-Creepers
JIS E 1115	Spring Washers for Fish Plates
JIS E 1116	Compromise Fish Plates for Rails
JIS E 1120	Head Hardened Rails
JIS E 1122	Compromise Rails
JIS E 1123	End Hardened Rails
JIS E 1125	Glued Insulated Rails

JIS E 1201	Prestressed Concrete Sleepers - Pretensioned Type
JIS E 1202	Prestressed Concrete Sleepers - Post-Tensioned Type
JIS E 1203	Synthetic Sleepers - Made from Fiber Reinforced Foamed Urethane
JIS E 1301	Turnout Number
JIS E 1303	Railway Turnouts and Crossings
JIS E 1304	Geometry of Turnouts and Crossings
JIS E 1305	Railway Switches - Shape and Dimensions
JIS E 1306	Railway Crossings - Shape and Dimensions
JIS E 1307	Guards for Turnouts and Crossings - Shapes and Dimensions
JIS E 3601	Rail Bonds
JIS G 3101	(2020) Rolled Steels for General Structure
JIS G 3106	(2020) Rolled Steels for Welded Structure
JIS K 2207	(2006) Petroleum Asphalts
JIS K 2220	Lubricating Grease
JIS K 2265-1	(2007) Determination of flash point - Part 1: Tag closed cup method
JIS K 2283	Crude Petroleum and Petroleum Products - Determination of Kinematic Viscosity and Calculation of Viscosity Index from Kinematic Viscosity
JIS Z 8801	(2006) Test Sieves Part 1: Test Sieves of Metal Wire Cloth

Japanese Society of Steel Construction (JSS)

JSS II 09	(2015) Sets of Torshear Type High Strength Bolt, Hexagonal Nut and Plain Washer for Structural Joints
-----------	---

U.S. FEDERAL HIGHWAY ADMINISTRATION (FHWA)

MUTCD	(2009; Rev 2012) Manual on Uniform Traffic Control Devices
-------	---

UNDERWRITERS LABORATORIES (UL)

UL 651	(2011; Reprint May 2022) UL Standard for Safety Schedule 40, 80, Type EB and A
--------	---

Rigid PVC Conduit and Fittings

1.3 SUBMITTALS

Government approval is required for submittals with a "G" or "S" classification. Submittals not having a "G" or "S" classification are [for Contractor Quality Control approval.][for information only. When used, a code following the "G" classification identifies the office that will review the submittal for the Government.] Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-02 Shop Drawings

Bridge Repair; G[, [_____]]

SD-03 Product Data

Steel Ties

Concrete Ties

New Jointed Rail; G[, [_____]]

Relay Rail; G[, [_____]]

Joint Bars

Compromise Joint Bars

Miscellaneous Track Materials

Crossing Material or Surface

Acceptable Replacement Materials; G[, [_____]]

Traffic Maintenance and Detour Plans; G[, [_____]]

Thermite Welding Procedures; G[, [_____]]

Electric Arc Welding

Materials and Samples

Synthetic Ties

SD-04 Samples

Geotextile

Ballast

Subballast

SD-06 Test Reports

Sampling and Testing

Concrete Ties

Geotextiles

Ultrasonic Test

Synthetic Ties

SD-07 Certificates

Ballast

Subballast

Materials and Samples

Synthetic Ties

SD-10 Operation and Maintenance Data

Rail; G[, [_____]]

Turnouts and Track Crossings; G[, [_____]]

Switches; G[, [_____]]

Grade Crossings; G[, [_____]]

SD-11 Closeout Submittals

As-Built Drawings; G[, [_____]]

1.4 QUALITY ASSURANCE

1.4.1 Track Construction

All work associated with the railroad must be performed by Contractor or Subcontractor qualified to work on Japan Rail lines. Submit evidence of Rail Construction Manager License, certified by Japan Railways Engineers' Association (JREA).

Contractor must obtain approval from Japan Freight Railway Company (JR Kamotsu) prior to returning the tracks to active service.

Perform track construction under the direction of qualified and competent supervisory personnel experienced in Japanese railroad construction.

1.4.2 Welding

Perform welding under the direct supervision of an experienced welding supervisor or foreman.

1.5 DELIVERY, STORAGE, AND HANDLING

1.5.1 Materials and Samples

Submit a complete schedule of the materials proposed for installation within 60 days of receipt of notice to proceed, and before installation of the materials; include a list of equipment proposed for the work. The Contracting Officer will notify the Contractor of the materials approved or disapproved. Promptly segregate disapproved materials that have

already been delivered to the project site from the approved materials and remove from the premises. If materials are disapproved, provide acceptable replacement materials at no additional cost to the Government. Submit performance data for components or products proposed as an equivalent to those specified. The Contracting Officer's written approval is required for any such equivalent type component or product proposed to be used. Initial approval by the Contracting Officer will not prevent the removal and replacement of materials that are materially defective or materials not meeting this specification that are discovered during construction and/or routine quality control/quality assurance operations. Submit manufacturer's certificates of conformance for the following materials:

- a. Rail.
- b. Tie plates.
- c. Track bolts, nuts, and spring washers.
- d. Joint bars.
- e. Rail anchors.
- f. Track spikes.
- g. Turnouts.
- h. Rail welding process.
- i. Premanufactured car bumpers.
- j. Premanufactured road crossings and/or crossing surfaces.

1.5.2 Geotextiles

Ship and store geotextiles in their original ultraviolet resistant cover until the day of installation. Protect geotextiles from vandalism, temperatures greater than 60 degrees C, dirt, dust, mud, debris, moisture, sunlight, and ultraviolet rays. Clearly label geotextiles delivered to the project site on the material cover to show the manufacturer's name, brand name, fabric type, location and date manufactured, lot identification, width, and length. Submit independent testing laboratory's certified test reports for geotextiles, including necessary analysis and interpretation. Provide results of the laboratory testing performed on samples of the geotextile material delivered to the jobsite. Submit test reports at least [5] [_____] working days prior to the installation of the geotextile.

1.6 PROJECT/SITE CONDITIONS

1.6.1 Temporary Work

Provide, during construction, suitable roads and crossings with all necessary lights, signs, drainage, and other appurtenances required for safe public and local travel. Erect and maintain suitable temporary fences where required to prevent trespass upon work or damage to adjoining property. Maintain drainage, and the accumulation of water that might affect the stability of the roadbed is not permitted.

1.6.2 Traffic Control

Provide traffic control that comply with MUTCD. Place suitable warning signs near the beginning of the work site and well ahead of the work site for alerting approaching traffic from both directions. Place small markers along newly painted lines or freshly placed raised markers to control traffic and prevent damage to newly painted surfaces or displacement of raised pavement markers. Mark painting equipment with large warning signs indicating slow-moving painting equipment in operation.

1.6.3 Welding

Do not perform welding in rain, snow, or other inclement weather without adequately protecting the weld from the elements.

1.6.4 License Agreement

The work under this contract is being accomplished under a license agreement between the [_____] RAIL CORPORATION (hereinafter referred to as the Railroad Company) and the UNITED STATES OF AMERICA executed on [_____].

1.6.4.1 Provisions and Requirements

The following provisions and requirements are made a part of this contract in order for the UNITED STATES OF AMERICA to perform its obligations under the License agreement:

- a. Perform the work in conformance with the standards of care and practice appropriate to the nature of the work.
- b. Allow the Railroad Company to view and inspect the work at any time.
- c. Do not enter the Railroad Company's premises until specifically authorized by the Contracting Officer. Notify the Contracting Officer at least 7 days prior to the planned date for entering the premises of the Railroad Company.
- d. Take any safety precautions that the Railroad Company deems necessary. Do not locate equipment, unless being utilized to perform work on the railroad track, within 3.5 m of the centerline of the nearest railroad track. Attend such equipment allowed within 3.5 m of the centerline of the nearest railroad track at all times.
- e. Furnish evidence of Workmen's Compensation coverage for both itself and for all subcontractors.
- f. Maintain at all times during any construction, maintenance, or removal work, the following insurance coverages:
 - (1) Contractor's Public Liability and Property Damage Liability Insurance, including automobile coverage, with a combined single limit of \$2,000,000 per occurrence;
 - (2) For each subcontractor, Contractor's Protective Public Liability and Property Damage Liability Insurance, including automobile coverage, with a combined single limit of \$2,000,000 per occurrence;
 - (3) Railroad Protective Public Liability and Property Damage Liability Insurance with a combined single limit of \$2,000,000 per occurrence.

1.6.4.2 Insurance Policy Requirements

The Railroad Protective Liability policy must name the [_____] Rail Corporation, [_____] Corporation, and [_____] as the named insureds and include an endorsement in the form appearing in the Standard Provisions of the contract documents. Furnish to the Railroad Company, the Railroad

Protective Liability policy and the certificates evidencing the other insurance coverage required in this section. Each policy and/or certificate must provide that cancellation of the insurance cannot be accomplished unless at least ten (10) days notice is given to the Railroad Company.

PART 2 PRODUCTS

2.1 BALLAST

Submit samples of the ballast [and subballast] material for testing. Submit samples a minimum of [30] [60] [90] [_____] days prior to the installation of the material. Obtain samples from the quarry, supplier, or other source that will be used to provide the ballast [and subballast] materials for this project using the methods described in ASTM D75/D75M or JIS A 1201. [Submit one representative sample no less than 100 kg of ballast material for each 9000 metric tons of ballast to be installed.] [Submit one representative sample no less than 100 kg of subballast material for each 9000 metric tons of subballast to be installed.] Prepared ballast must be crushed stone, [crushed air-cooled blast-furnace slag,] [or] [crushed steel furnace slag] Size No. [4,] [4A,] [or] [5] conforming to Chapter 1, Part 2, of AREMA Eng Man for quality, soundness and gradation. In the portion retained on each sieve specified, the crushed gravel must contain at least 90 percent by weight of crushed pieces having two or more freshly fractured faces with the area of each face being at least equal to 75 percent of the smallest midsectional area of the plane. When two fractures are contiguous, ensure the angle between planes of the fractures is at least 30 degrees in order to count as two fractured faces. Flat and elongated particle dimension ratio used in ASTM D4791 or per JARA Handbook [2]-24 must be 1:3. Submit certificates of Compliance for the ballast [and] [subballast] materials to be installed in this project. Ballast materials must meet the property requirements shown in TABLE I.

TABLE I. MINIMUM PROPERTY REQUIREMENTS - BALLAST			
Property	Maximum Value	Minimum Value	Test Method
Percent passing 0.075 mm sieve	1.0 percent	--	ASTM C136/C136M ASTM C117 or JIS A 1102
Bulk specific gravity			
Rock	--	2.60	ASTM C127 or JIS A 1110
Blast furnace slag	--	2.30	
Absorption			
Rock	2.0 percent	--	ASTM C127 or JIS A 1110
Blast furnace slag	5.0 percent	--	
Clay lumps and friable particles	0.5 percent	--	ASTM C142/C142M
Degradation Soundness	35 percent	--	ASTM C535

TABLE I. MINIMUM PROPERTY REQUIREMENTS - BALLAST			
Property	Maximum Value	Minimum Value	Test Method
Sodium sulfate - 5 cycles	10 percent	--	ASTM C88 or JIS A 1122
Flat or elongated particles	5 percent	--	ASTM D4791 or JARA Handbook [2]-24

2.2 SUBBALLAST

Provide subballast consisting of aggregate-soil materials conforming to an ASTM D1241 Type I, Gradation [A] [B] [C] [D] mixture.

2.3 GEOTEXTILE

Submit geotextile samples for testing. Submit samples a minimum of [30] [60] [90] [_____] days prior to the beginning of installation of the geotextiles. Provide one sample for each 20 units (rolls, panels, etc.) of geotextile to be used in the contract. Ensure all samples are from the same production lot as will be supplied for the contract. Identify samples by the manufacturer's name, brand name, lot designation, and project name. Ensure the minimum size of sample submitted for testing is the full width of the geotextile by [1.7] [9] [_____] m.

2.3.1 Physical Property Requirements

Provide a nonwoven, pervious sheet of polymeric material consisting of long-chain synthetic polymers composed of at least 95 percent by weight polyolefins, polyesters, or polyamides. The use of woven slit film geotextiles (i.e. geotextiles made from yarns of a flat, tape-like character) will not be allowed. Provide geotextile that contains stabilizers and/or inhibitors as necessary to make the filaments resistant to deterioration from ultraviolet light and heat exposure, particularly prior to placement and coverage. Ensure the fibers are formed into a network which is dimensionally stable. Finish the edges of the geotextile in a way to prevent the outer fibers from being pulled away from the geotextile. Provide geotextile that exceeds the applicability property requirements stated in TABLE II.

TABLE II - PROPERTY REQUIREMENTS-GEOTEXTILE		
PROPERTY	MINIMUM REQUIREMENTS*	TEST METHOD
Weight**	0.57 kg/0.836 sq m	ASTM D3776/D3776M Option B
Color	Grey or tinted	--
Strength	Class 1	AASHTO M 288
Apparent opening size (AOS) (maximum required valve)	Less than 0.22 mm sieve	ASTM D4751

TABLE II - PROPERTY REQUIREMENTS-GEOTEXTILE		
PROPERTY	MINIMUM REQUIREMENTS*	TEST METHOD
Permittivity	0.1 per sec	ASTM D4491/D4491M
Ultraviolet degradation at 500 hours	50 percent strength retained	ASTM D4355/D4355M
*These property requirements are Minimum Average Roll Values in the weaker principal direction.		
**Do not limit geotextile selection by the minimum weight shown. Base selection on the other property requirements listed. Heavier geotextiles have shown greater resistance to abrasion.		

2.3.2 Dimensional Requirements

Match each roll of geotextile to the roadbed width. Ensure each roll of geotextile is at least 3.6 m.

2.4 JOINT BARS

Provide joint bars of the size, shape, and punching pattern to fit the rail being joined.

2.4.1 New Joint Bars

Use new joint bars with new rail. Use joint bars to match rail section. Ensure new joint bars conform to the requirements of JIS E 1102, or JIS E 1125 at glued insulated joints.

2.4.2 Compromise Joint Bars

Ensure compromise joint bars are of the size, shape, and punching pattern to fit the rail sizes and sections being joined. Use only factory designed and constructed (forged or cast) compromise joint bars to join rails of different sizes.

2.4.2.1 New Compromise Joint Bars

Provide compromise joint bars conforming to the requirements of JIS E 1116.

2.5 GREASE

Use grease for lubricating moving parts in turnouts and other trackwork with the following typical characteristics:

Calcium Soap, percent	9.0
Solid Additive (Graphite), percent	11.5

Penetration, ASTM D217 or JIS K 2220 at 25 degrees C worked	340
Dropping Point ASTM D566 or JIS K 2220 at 25 degrees C	101/214
Oil Viscosity, square mm/record at 40 degrees C	81.8

Other types of grease or lubricating oil may be used provided that the grease or oil has been used successfully by local commercial railroads and has the approval of the Contracting Officer.

2.6 OIL FOR CORROSION PROTECTION

Provide oil for protecting rail and other track materials from corrosion, except joints, conforming to the following general specification:

(Cutback) Asphalt, 100 penetration minimum 45 percent	ASTM D402/D402M or JIS K 2207
Flash point, minimum 55 degrees C	ASTM D1310 or JIS K 2265-1
Viscosity, kinematic, 60 degrees C 480 to 700 sq mm/s	ASTM D2171/D2171M or JIS K 2283

2.7 RAIL

Submit manufacturer's data on new rail including: rail weight, rail section, drilling, rail length, date rolled, and the name of the mill where the rail was rolled. Include chemical analysis. Also provide the design of the joint bars and compromise joint bars proposed to be furnished with each rail section.

2.7.1 New Jointed Rail

2.7.1.1 General Requirements

Comply with the following:

2.7.1.1.1 Rail Lengths

Provide new rail consisting of a [50N][60] kg/m section or heavier and conforming to the specifications in JIS E 1101 for common, switch and crossing rails; JIS E 1120 at head-hardened rails; JIS E 1123 for end-hardened rails; or JIS E 1122 at compromise rails, that were in effect at the time of its manufacture. Provide new rail in [25] m lengths.

2.7.1.2 New Rail

Produce all steel in an electric furnace. Ensure steel is continuous cast and free of hydrogen. Cull out and eliminate all injurious hot marks, or surface imperfections. Control cool rail to JIS specifications. Provide rolled rail in accordance with the general physical dimensional requirements of JIS design and meeting the Section tolerances and Chemical Composition specified in the JIS standards.

2.7.1.2.1 Testing

Test rail ultrasonically to the following calibration guidelines:

CALIBRATION GUIDELINES	
Head	2.4 mm Flat bottom Hole
Web	3.2 mm Flat Bottom Hole
Base	3.2 mm X 12.7 mm Slot

2.7.1.2.2 Straightness

Straighten rail for line in a press or roller straightener. End straightness must meet the following guidelines:

Droop	1.0 mm Maximum
Dip	1.0 mm Maximum
Hook	1.0 mm Maximum

2.7.2 Welded Rail

Provide new rail consisting of, [50N][60] kg/m section and conforming to JIS E 1101. Mingling of new and relay rail will not be permitted.

2.8 TIE PLATES

2.8.1 General

Provide new tie plates, with dimensions, punching pattern, and cant conforming to JIS E 1110 with new rail. Use canted tie plates in all new rail.

2.9 SYNTHETIC TIES

Submit name of the tie manufacturer, dimensions, and the pre-drill size as recommended by the tie manufacturer for the type and size fastening system being used. Use synthetic ties conforming to JIS E 1203. Incorporate a surface pattern to provide a minimum single tie lateral push result of 11.1 kN after no more than 100,000 gross metric tons of accumulated traffic. Submit certified test reports for crossties and switch ties, a minimum of seven calendar days prior to any ties being installed in track.

2.9.1 Crossties

2.9.1.1 Except at Road Crossings

Provide synthetic crossties, except at road crossings, which are no less than [140] mm thick and [200] mm wide, with a length of [2.1][2.6] m.

2.9.1.2 At Road Crossings

Provide synthetic crossties at road crossings which are no less than 140 mm thick and 200 mm wide. Use a length of 2.6 m, unless recommended otherwise by the manufacturer of the crossing surface materials.

2.9.2 Switch Ties

Provide switch ties that are 140 mm thick and 230 mm wide. Provide length and quantities as shown.

2.9.3 Ballasted-Deck Bridge Ties

Synthetic ties for use in track over ballasted deck bridges must be standard crossties.

2.10 STEEL TIES

Submit name of the tie manufacturer, dimensions, type of fixation and the chemical analysis of the steel. Provide steel ties conforming to ISO 6305-3 meeting the minimum properties listed in the Table below. Construct steel ties with hook-in shoulders of a 178 mm minimum spade; Contractor to coordinate with manufacturer based on fixation system selected. Design and furnish ties with elastic type rail fixation system. Provide ties with a brand rolled into the material indicating the section and manufacturer. Provide steel ties with the following minimum section:

Steel Ties	
Length	1850 mm
Width	280 mm
Thickness	10 mm
Section Depth	118 mm
Moment of Inertia	610 cm ⁴

Manufacture ties from steel free of injurious segregation with a minimum tensile strength of 400 MPa. Use steel with the chemical composition conforming to JIS G 3101 (Grade SS400) or JIS G 3106 (Grade SM490).

2.11 CONCRETE TIES

Submit name of the tie manufacturer, dimensions, type of fixation and the chemical analysis of the concrete mix. Provide concrete ties and fastening system complying with the material and strength requirements specified in JIS E 1201 or JIS E 1202. Ensure concrete ties are a minimum of 2 m in length, width of [220][240][300] mm, and height of [174] mm. Furnish concrete with dual durometer rubber pads, which have 50 to 60 shore A durometer on the bottom surface and 75 to 85 Shore A durometer reinforced rubber on the top surface. Submit certified test reports for ties and fastening system, a minimum of seven calendar days prior to any ties being installed in track. Document the testing required by JIS E 1201 or JIS E 1202.

Provide hook-in sholders to be cast in the ties at the time of manufacturer for elastic spring clip fixation system. Contractor must coordinate the selected fixation system with the concrete tie manufacturer.

2.12 TURNOUTS AND TRACK CROSSINGS

Ensure component parts of the turnouts to be furnished are the products of manufacturers regularly engaged in the manufacture of such products which essentially duplicate items that have been in satisfactory use at least 2 years prior to bid opening. The parts need not all be made by the same manufacturer, but ensure each turnout is the product of a single firm. Provide switch assemblies, stands, frogs, and guardrails assemblies conforming to the requirements of JIS E 1301, JIS E 1303, and JIS E 1304.

2.12.1 Rail and Joint Bars

Furnish and install rail, joint bars, and miscellaneous track materials used in turnout and track crossing construction as part of the complete turnout or crossing. Use rail and miscellaneous track materials in turnout and track crossing construction of the the weight and section [shown on the contract drawings] [as listed:

TURNOUT TRACK OR CROSSING ID	TURNOUT GEOMETRY DESIGNATION (JIS E 1304)
[_____]	[_____]

]

2.12.2 Maximum Wear Used Rails Installed in Turnouts

[The average top (vertical) wear must be 3 mm or less. Gage side head wear must not exceed 3 mm.

2.12.3 Frogs, Switches, Guardrails and Appurtenances

Provide frogs, switches, guardrails and appurtenances consisting of materials suitable for use in heavy tonnage main track. Ensure used turnout materials are fully reconditioned and within plus or minus 3 mm of the original specification for that turnout design. Use materials in the turnout of the same weight and section. Provide materials in good condition and free from excessive rust, dirt, and other foreign materials. Provide rail weight and section as specified.

2.12.3.1 Switches

Use switches for new turnout construction or complete turnout replacement consisting of 5029 mm reinforced straight split switches with graduated risers generally conforming to JIS E 1305. Use switch materials to replace defective materials as indicated.

- a. Ensure switch points are new. [Ensure one switch point in each turnout is manganese tipped in accordance with JIS E 1305 installed on the side opposite the turnout side of the switch (example the right switch point is manganese tipped on a left hand turnout).]

- b. Provide new switch rods and connecting rods.
- c. Provide new or used gage plates, switch plates, slide plates, and heel plates in good condition and not worn or corroded. Provide either rigid or adjustable rail braces. For a given turnout all rail braces must be of the same design.
- d. Provide heel blocks that are either cast or forged steel, either new or used, and in good condition. Provide new, heat treated heel block bolt assemblies. Provide either new or used heel joint bars good condition which are manufactured for the purpose. If floating heel blocks are used, use special no. 5 double shoulder plates to maintain 160 mm heel spread.

2.12.3.2 Frogs

Provide [bolted rail] [railbound manganese] [solid manganese self-guarded] frogs in the sizes indicated.

- a. Provide [new] [remanufactured] frogs. Do not use cracked or broken used frog castings. Cracked or broken frog castings that have been repaired by welding are not acceptable and do not use. Ensure remanufactured frogs meet the following wear requirements:

(1) Provide frog points that are in good condition and not worn, chipped, or broken.

(2) Maximum allowable wear on used or reconditioned frogs is:

Frog Point	3 mm
Top Surface	3 mm
Raised Guarding Face (Self-Guarded)	3 mm
All Wear Surfaces	3 mm

(3) Minimum flangeway depth for used frogs is 44 mm. Minimum flangeway width is 48 mm.

- b. Provide new frog bolts, nuts, lock washers, and headlocks.

2.12.3.3 New or Replacement Guard Rails

Ensure new or replacement guard rails are a minimum of 4.6 m in length and are new or used in good condition. Provide guard rails of any of the following designs: Tee rail, solid manganese steel, or an acceptable hook flange design, in accordance with JIS E 1307. Ensure the guard face for used guard rails is smooth and not worn more than 3 mm from its new condition. Equip guard rails bolted to the running rails with fillers. When fillers are installed or repaired, use new bolt assemblies. All bolts, nuts, and associated hardware must be new. Equip clamped guard rails with block wedges, filler wedges, and cotter keys. Provide new guard rail plates or use acceptable replacements. Install single-shoulder tie plates used with guard rails with the shoulder on the inside flush

against the base of the guard rail.

2.12.3.4 Hook Plates

Hook plates must be new or acceptable used material and of the designs and lengths indicated on AREMA Eng Man, Plan Nos. 112 and 241, or per JIS E 1305.

2.12.3.5 Switch Stands

2.12.3.5.1 New or Replacement Switch Stands

Provide new or replacement switch stands conforming to AREMA Eng Man, Plan 251-64, which are new or fully reconditioned, low-stand type with model number [Bethlehem Steel model 51A][_____]. Provide [automatic-action][semi-automatic action (spring)] [positive-action (rigid)] switch stand with [adjustment from the top with shims through a moveable cover][spring connecting rods][adjustable connecting rods][_____].

2.12.3.5.2 Existing Switch Stands

Recondition existing switch stands, staffs and targets, where not designated for replacement, by cleaning to bare metal and then paint with one coat of metal primer.[Clean and re-lubricate the interior portion of the stands, including mechanisms.] Paint switch stand staff with two coats of black enamel paint. Similarly prepare and paint switch targets with two coats of red or white enamel paint to indicate switch position in accordance with normal railroad practice.

2.12.3.5.3 Switch Lamps

Equip each stand with one of the following switch lamps as indicated on the project plans:

2.12.3.5.3.1 Reflecting Type

Approved reflecting switch lamps fitted with standard commercial-type double red and white reflecting lenses but without day signal targets.

2.12.3.5.3.2 Reflecting Type with Daylight Disk

Approved reflecting switch lamps fitted with standard commercial-type double red and white reflecting lenses, and with day signal targets.

2.12.3.5.3.3 Illuminated Type

Approved illuminated lamps with primary battery, battery housing, and cable.

2.12.4 Track Crossings

Provide new track crossings fabricated in accordance with AREMA Eng Man, Plan No. [_____]. Rail weight and section is [_____]. Provide tie layout in accordance with AREMA Eng Man, Plan No. [_____].

2.12.5 Rail Braces

Provide either the fixed or adjustable type rail braces of standard manufacture.

2.13 GRADE CROSSINGS

Use recyclable materials in grade crossings conforming to EPA requirements in accordance with Section 01 33 29 SUSTAINABILITY REQUIREMENTS AND REPORTING.

2.13.1 Crossing Material or Surface

Within 30 days of the Notice to Proceed, submit the brand name of the premanufactured crossing material or crossing surface material proposed for use along with manufacturer's literature concerning the product; and for built-in-place crossings, the type of materials to be used along with manufacturer's literature. Submit detailed installation procedure for the premanufactured crossing material or crossing surface material proposed for use within 30 days of the notice to proceed. Ensure roadway width is as indicated in the contract drawings. Provide crossing material or surface complying with the following:

- a. Construct a semi-permanent aggregate crossing of compacted crushed aggregate placed between the rails and as short approaches to the track. Provide aggregate consisting of a crushed gravel or crushed stone material conforming to the requirements of [ballast] [subballast] [ASTM D1241, Type I, Gradations A or B].
- b. Construct a permanent aggregate crossing of compacted crushed aggregate placed in the track between bond timbers header as indicated. Provide crushed aggregate consisting of [ballast] [subballast] [a crushed aggregate material conforming to the requirements of ASTM D1241, Type I, Gradations A or B].
- c. Provide [constructed-in-place] [prefabricated] full-depth timber crossings. Ensure timber road crossing materials are [oak] [acceptable hardwood]. Provide seasoning and treatment conforming to the requirements of AWP A U1.
- d. Use bituminous paving materials for full-depth asphaltic cement concrete (bituminous) crossing with bond timbers flangeway headers conforming to the applicable State of [_____] Highway Specification for a [_____] type mix design. Ensure bond timbers are [oak] [acceptable hardwood]. Provide seasoning and treatment conforming to AWP A U1.
- e. Provide concrete pavement materials for full-depth, cast-in-place concrete crossings conforming to the requirements of Section 03 30 00 CAST-IN-PLACE CONCRETE.
- f. Use premanufactured, precast concrete panels for grade crossings constructed of reinforced concrete having a minimum 28-day compressive strength of 34.5 MPa. Ensure each panel is manufactured to meet HS20-44 loading in accordance with AASHTO HB-17, with 30 percent impact increment. Base loading on single axle loads of 14,500 kg. Use precast crossing panels that are the product of a company regularly engaged in the manufacture of such panels, and whose products have been successfully used in the commercial railroad industry for at least 2 years.
- g. Provide full depth panels for premanufactured elastomeric crossing systems. Ensure elastomeric systems with or without steel composition

grade crossing panels are the product of a company regularly engaged in the manufacture of such products, and whose products have been successfully used in the commercial railroad industry for at least 2 years.

2.13.2 Rail

Provide rail within the road crossing and for at least 6 m on either side of the crossing that is [_____] [50N] as specified in paragraph Rail and Joint Bars.

2.13.3 Ties

Provide ties within the road crossing and for at least 6 m on either side of the crossing consisting of hardwood or polymer composite and as specified in paragraphs Crossties and Switch Ties.

2.13.4 Track Materials

For premanufactured crossing surfaces or systems, provide tie plates, spikes or other rail fasteners, rail anchors, and other track materials conforming to the manufacturer's recommendations. Unless specified by the crossing manufacturer, provide track materials as specified in paragraph MISCELLANEOUS TRACK MATERIALS.

2.13.5 Threaded Fasteners and Screw Spikes

Use threaded fasteners in grade crossings of the sizes and lengths specified by the grade crossing manufacturer or as indicated for built-in-place crossings. Use screw spikes with a minimum ultimate tensile strength of 400 MPa, conforming to JIS E 1109 and galvanized for corrosion protection.

2.13.6 Pipe for Subdrains

Pipe for subdrains must be [152] [203] [_____] mm diameter corrugated, perforated [polyethylene complying with ASTM F667/F667M] [bituminous coated galvanized corrugated steel].

2.13.7 Cable Conduit

Provide cable conduit under grade crossings consisting of 102 mm diameter PVC pipe conforming to UL 651, and a minimum of Schedule 80.

2.14 MISCELLANEOUS TRACK MATERIALS

Submit manufacturer's data for all track materials to be furnished. Provide miscellaneous track materials as follows:

2.14.1 Spikes

2.14.1.1 Track Spikes

Provide new track spikes conforming to JIS E 1108. Use track spikes size 145 mm by 16 mm with 37 kg/m or heavier rail or with 40N or 50N rail.

2.14.1.2 Bridge Spikes

[Use minimum 19 mm diameter washer head screw spikes that allow a minimum

of 127 mm penetration into the stringers to connect the bridge ties to the stringers on an open-deck bridge, in accordance with AREMA Eng Man, Chapter 7, Part 7.]

2.14.2 Bolts, Nuts, and Spring Washers

Use new track bolts, nuts, and spring washers throughout the project for both new and relay rail.[Use bolts in both steel and timber bridge connections.]

2.14.2.1 Bolts and Nuts

The various rail, joint bars, and rail drillings require various lengths and diameters of bolt assemblies. Determine the number of bolt assemblies of each size required. All bolt diameters must be the largest possible for a given rail drilling and joint bar punching. Provide track bolts and nuts conforming to JIS E 1107. Ensure track bolts are long enough to leave at least two threads exposed after the nut is tightened.[Use JIS B 1186 F10T or JSS II 09 S10T bolts for steel bridge connections. Minimum 19 mm diameter with lengths as required.]

2.14.2.2 Spring Washers

Size spring washers and nuts to ensure that the spring washer develops its full reactive force and does not jam into the joint bar hole. Provide spring washers of the size to fit the bolt and nut used and conforming to JIS E 1115.

2.14.3 Rail Anchors

Where special tools are required to install or remove anchors, furnish a minimum of one tool for each 5,000 anchors, or fraction thereof, not to exceed 5 tools per job.

2.14.3.1 New Installation

Provide new rail anchors for new installations. Use sizes conforming to the various sizes of rail on the project and conforming to JIS E 1111. Anchors may be either drive-on or spring type.

2.14.3.2 Rail Clips and Fasteners

Provide single tight fit clips with fillers as necessary to fit rail section furnished. Clip or fastener design must anchor rail against longitudinal movement.

2.14.4 Insulated Joints

Provide insulated joints conforming to JIS E 1125. Do not use conventional continuous insulated joints with fiber insulation. Unless otherwise directed by the Contracting Officer, use insulated joints for the following rail sections, rail drilling, and number of joints:

RAIL SECTION	DRILLING	NO. JOINTS
[_____]	[_____] - [_____]	[_____]

2.14.5 Bumping Posts, Cushion Heads and Wheelstops

Provide new bumping posts, cushion heads, and wheelstops of a standard design that has been in use by commercial railroad industry for at least 5 years. Use bumping posts, cushion heads, and wheelstops manufactured by a company regularly engaged in the manufacture of these products.

2.14.5.1 Bumping Posts

Provide bumping posts consisting of all-steel construction, that bolt firmly onto the rail, and of a type designed for general service. Provide bumping posts that have tension with 3800 mm^2 cross-sectional area and compression members with a moment of inertia no less than $15 \times 10^6 \text{ mm}^4$ of JIS G 3101 Grade SS400 steel. Bumping post must be capable of withstanding a yield load of 3525 kN.

2.14.5.2 Cushion Heads

Provide cushion heads consisting of all steel construction, that firmly bolt, attach, or clamp onto the bumper or end dock (platform or ramp). Cushion heads must resist 356 kN of compression.

2.14.5.3 Wheelstops

Provide wheelstops consisting of all-steel construction, that firmly bolt or clamp onto the rail, and of a type designed for general service.

2.14.6 Inner Guard Rail

Inner guard rail must be Class IV or better used rails as indicated in Part 2, Chapter 4, "Inspection Classification of Second Hand Rail for Welding", of AREMA Eng Man or JIS E 1307. Rail must be 40 kg/m or greater. Ensure all rails used at any one inner guard rail location are the same weight and section. Ensure joint bars match the rail provided and are in good condition.

2.14.7 Gage Rods

2.14.7.1 New Gage Rods

Provide new, double-clamp style gage rods manufactured in conformance with "Specifications for Special Trackwork" of AREMA Eng Man. Provide double clamp style gage rods that are threaded on both ends and equip with four malleable steel casting clamps to rigidly hold both sides of the base of both rails.

2.14.8 Derails

2.14.8.1 New Derails

Provide new derails of a standard design that has been in use by the commercial railroad industry for at least 5 years. Provide derails consisting of all-steel construction and designed to be permanently spiked to a crosstie. Provide either one-way or two-way derails as indicated. Provide either sliding type or hinged type derails as indicated. When the type of derail indicated requires a derail stand, connecting rod, and operating mechanism for proper operation, provide the derail and all necessary components as a unit. Provide locations, sizes, and directions of the derails as indicated on the contract drawings.

2.15 RAIL BONDING AND GROUNDING

2.15.1 Rail Bonds

Provide exothermic type ("Cadweld") bonds applied to the field side of the rail head[, or [1154] mm bonds welded to the rail web]. The bond cables must be flexible bare copper stranded 8 mm diameter cables conforming to JIS C 3102 with preformed ends. Bond cables must be flexible bare copper stranded cables with preformed ends and must conform to JIS E 3601.

2.15.2 Grounding Rods

Grounding rods must be [19 mm diameter copper clad steel rods] [25 mm diameter zinc-coated steel rods]. The minimum length of ground rods must be 2.5 m.

2.15.3 Ground Connection Cables

Make connections between the grounding system or ground rods and rails with a bare flexible copper stranded 9 mm cable conforming to JIS C 3102.

2.15.4 Electrical Connecting Hardware

Provide electrical connecting hardware consisting of bronze pressure bar type materials having no rotating parts coming in direct contact with conductors.

2.16 WELDING

2.16.1 Rail Welding Kits

Ensure kits for thermite type rail welds are approved by the Contracting Officer before use. Provide welding kits for all rail sections used and no differentiation will be made between Contractor-furnished and Government-furnished rail sections for measurement and payment purposes.

2.16.2 Electrodes

Provide AWS low-hydrogen, high tensile 140-16 (extrapolation) or 25-20 electrode, Grade 310-16 and 310-15 stainless steel rod welding electrodes. Provide electrodes of the smallest practical diameter worked at the lowest compatible current. Ensure coating on low-hydrogen type electrodes is thoroughly dry when the electrode is provided. Use electrodes taken from hermetically sealed packages within one hour of the time the package is opened. Dry electrodes not used within this one-hour period and electrodes taken from non-hermetically sealed packages for at least one hour between 371 and 427 degrees C. Electrodes so dried may be stored at temperatures between 107 and 205 degrees C until used, or, if not stored and not used within one hour after this drying is completed, re-dry before use. Do not use electrodes which have been wet.

PART 3 EXECUTION

3.1 REMOVAL, SALVAGE, AND DISPOSITION OF MATERIALS

Do not dismantle tracks and segments of track until approved to do so by the Contracting Officer. Salvage the following materials for later use by the Government. Some of these items will be used in the repair of tracks

as indicated.

3.1.1 Materials To Be Salvaged

Materials to be salvaged for later use by the Government are:

a. [____].

b. [____].

Other materials are the property of the Contractor and remove from the project.

3.1.2 Methods and Procedures

The Contractor may use any methods to dismantle the track, provided proper measures are taken to ensure the safety of the laborers and the general public, and no damage is caused to track components to be salvaged or other tracks and structures which are indicated to remain. Do not cause damage to adjacent sidewalks or paved roadways during removal of existing tracks. Restore damage to these facilities caused by the Contractor at Contractor's expense.

3.1.3 Inventory of Track Materials

Keep a detailed inventory of excess and salvaged track materials stockpiled for the Government. Record detailed inventory in appropriate format and furnish to the Contracting Officer.

3.1.4 Inspection and Reconditioning of Used Track Materials

Clean and inspect salvaged track materials for defects to determine their suitability for further use.

3.1.4.1 Cleaning By Hand or Mechanical Means

Clean rail, joint bars, gage rods, tie plates, rail anchors, and other materials by hand or mechanical means to remove all adhering dirt and heavy rusting so that the bare steel can be examined.

3.1.4.2 Visual Examination of Rails

Visually examine rails for evidence of defects such as those illustrated on Form 402-A found in Chapter 4 Part 3 of AREMA Eng Man. Bring such defects to the attention of the Contracting Officer who will be the final judge as to the serviceability of the rail. Mark rails having bolt hole cracks or end batter under paragraph TRACK REPAIR that can be reconditioned for use by cropping and redrilling at the location of the defect with yellow paint. Reject rails with other defects or which cannot be reconditioned scrap and mark with bright red paint and stack separately.

3.1.4.3 Visual Examination of Joint Bars

Existing joint bars and compromise joint bars which are removed and no longer required at that location due to rail replacement or other work may be cleaned and reused at other locations, subject to review and approval of the Contracting Officer. Salvage or scrap joint bars and compromise joints that are not reused. Visually examine joint bars for defects and wear. Scrap joint bars with bolt hole or spike slot cracks. Scrap barr

which do not fit tightly against the rail or bars in which the bolt holes are excessively corroded or worn. The Contracting Officer will be the final judge of the serviceability of joint bars. Mark scrapped bars with bright red paint and stack separately.

3.1.4.4 Visual Examination of Gage Rods

Visually examine gage rods for bends, cracks, or breaks. Bent, cracked, or broken gage rods are considered as scrap, marked with bright red paint and stacked separately.

3.1.4.5 Visual Examination of Tie Plates and Rail Anchors

Visually examine tie plates and rail anchors for cracks, breaks, excessive wear, and excessive corrosion. Track material with these defects are considered scrap, mark with bright red paint and stack separately.

3.1.4.6 Gage Rods

Remove and salvage gage rods which exist in tangent track and in curved track with a curvature of 10 degrees or less. Reuse salvaged gage rods that have been inspected and cleaned to the maximum extent possible.

3.1.4.7 Grade Crossing Materials

Salvage existing premanufactured grade crossing panels, rail and other track materials as indicated, or as designated by the Contracting Officer. All salvaged materials will remain the property of the Government, and reinstall as indicated or transport to the military installation storage yard. Remove grade crossing materials to be salvaged, clean as required for proper reinstallation, mark or label as necessary for proper reinstallation, and transport to the reinstallation location or to the storage yard.

3.1.5 Transport and Stack Excess and Salvaged Materials

3.1.5.1 Material Not Used In Track Repair

Stack excess and salvaged materials which are not used in track repair work at a site on the military installation designated by the Contracting Officer.

3.1.5.2 Stacking of Rails

Stack rails on approved sills a minimum of 152 mm above the ground. Stack rails with the heads up and with the ends even. Separate each layer by at least three 50 by 100 mm wood strips evenly spaced along the length of the rail. Group rails by weight, section, drilling, condition, length, and amount of wear. Mark the weight, section, drilling, and length on one of the rails near the mid-height of the stack. Paint these markings neatly near one end of the rail.

3.1.5.3 Stacking of Joint Bars, Gage Rods, and Tie Plates

Sort joint bars, gage rods, and tie plates by section, punching and condition and stack on pallets. Steel band each pallet stack for forklift handling. The maximum weight on any pallet is 680 kg. Wire compromise joint bars together in pairs and stack on pallets, separate from other bars.

3.1.5.4 Containers

Sort rail anchors by type and size and place in kegs, steel drums, or other approved containers. Label containers with the rail weight and section.

3.1.5.5 Stacking of Special Trackwork Materials

Palletize and stack special trackwork materials as directed by the Contracting Officer. Mark the rail weight, rail section, and length on each switch point. Mark the weight, section, and frog number on the side of each frog casting. Place other salvaged switch materials in steel drums and label as to rail weight, section, length of points, and turnout size.

3.1.6 Material to be Scrapped

[All material] [_____] must be scrapped and must become the property of the Contractor.

3.2 PLACEMENT OF BALLAST [AND SUBBALLAST]

Place ballast [and subballast] to the lines and grades indicated. The average thickness must be within 6 mm of the thickness indicated. Subgrade must conform to the requirements of Section 31 00 00 EARTHWORK. Do not place ballast [and subballast] on soft, muddy, or frozen areas. Where the prepared subgrade (roadbed) is soft, muddy, rutted, exhibits severe depressions, or is otherwise damaged, do not place the ballast [and subballast] until the damaged subgrade has been repaired and the area has been approved by the Contracting Officer.

3.2.1 Subballast

3.2.1.1 Subballast Placement

Place subballast in [two] uniform horizontal lifts of no more than 152 mm for the full width of the cross-section to the total depth indicated. Shape each subballast layer to a section conforming to the subballast section shown on the drawings and thoroughly compact.

3.2.1.2 Subballast Compaction

Compact each subballast lift using approved compaction equipment. Use sufficient roller weights, vibration frequencies (where applicable), tire pressures (where applicable), and number of passes to obtain in-place densities across the full width of the subballast and throughout the entire depth of the layer of no less than 95 percent of the ASTM D1557 or JIS A 1210 laboratory maximum dry density for the subballast material. Prior to placement of subsequent subballast layers, scarify the top of the previous layer to a depth of approximately 50 mm to insure proper bond of the layers. Field measure density in accordance with ASTM D1556/D1556M (use base plate as shown in the drawing) [or ASTM D6938. Check and adjust the calibration curves, if necessary, using only the sand cone method as described in paragraph Calibration, of the ASTM publication. Tests performed in accordance with ASTM D6938 result in a wet unit weight of soil and use ASTM D6938 to determine the moisture content of the soil. Also check the calibration curves furnished with the moisture gages along with density calibration checks as described in ASTM D6938. Make

calibration checks of both the density and moisture gages by the prepared containers of material method, as described in paragraph Calibration, in ASTM D6938, on each different type of material to be tested at the beginning of a job and at intervals as directed.] Take one field density test for each 1000 square meters of each layer of material placed in each area.

3.2.2 Ballast

3.2.2.1 Ballast Placement

Place Number 5 AREMA ballast in the tracks where indicated; use 50 mm of Number 5 ballast near turnouts and for 10 m each side of the switch stand to provide a smooth walking surface for railroad employees. All other areas require size AREMA Number [4] [4A] ballast.

3.2.2.2 Ballast Distribution

Do not disturb ballast until the [subgrade] [subballast] has been approved by the Contracting Officer. No payment will be made for ballast which is distributed without the Contracting Officer's approval.

- a. Distribute ballast distribution to the depth indicated, from either trucks or railroad cars. [If available, the Government will furnish a locomotive for unloading ballast along the track if a carload or more is used. Make arrangements for use of the locomotive by contacting [_____] at least [_____] hours in advance of the time the locomotive is needed.] [A government locomotive is not available for unloading ballast.]
- b. Prevent forming of ruts that would impair proper roadway drainage when distributing ballast from trucks and off track equipment. Level any ruts formed greater than 25 mm and grade to drain.
- c. Unload ballast as close as possible to the point of use so that unnecessary handling is prevented. Pick up and redistribute excess ballast at the Contractor's expense. If additional ballast is required for dressing, add it at no increase in unit price.
- d. Do not release ballast cars until they have been inspected. Ballast cars may be weighed by the Government before and after dumping the ballast at no cost to the Contractor.

3.2.2.3 Ballast Below Ties

For new construction, the last 100 mm ballast below the tie, place the shoulder ballast and the ballast in the tie cribs subsequent to the rail and tie installation. For surfacing existing track, place the ballast subsequent to rail and tie replacements.

3.3 TRACK CONSTRUCTION AND OUT-OF-FACE RELAY

Ensure track construction not covered specifically herein is in accordance with Ministry of Land, Infrastructure, Transport and Tourism (MLIT) Railroad Bureau, the Railway Technical Research Institute (RTRI), and JR Freight recommendations and recommended practices.

3.3.1 Roadbed Preparation

Perform clearing and grubbing, grading, excavation, embankment preparation, and subgrade preparation in accordance with Section [____]. Obtain approval of roadbed surface, grade, and drainage prior to any distribution of construction material. Where the subgrade or roadbed is damaged during distribution of materials, fill and compact ruts and depressions and ensure the roadbed surface is reapproved prior to track construction.

3.3.2 Geotextile for Track Construction

Install geotextile between the subgrade and the ballast as shown. Perform installation in accordance with subparagraph Geotextile Installation under paragraph Highway Crossings.

3.3.3 Unloading the Materials

The use of picks in the handling of ties will not be permitted. Unload rails from cars with an approved derrick or crane and place with the head up without dropping and with sufficient support under the base. Distribute rails of proper length as necessary for road crossings, switches, joint spacing, and other special conditions.

3.3.4 Ties

Standard center-to-center spacing of crossties is [50][53] mm. Space switch ties and bridge ties as indicated on the drawings. Ensure the ends of ties on one side of the track are parallel to the rail and the center of the tie is on the approximate center line of the track. Align the ends on the inside of curves and continue on that side until reaching a curve in the opposite direction. On double tracks, align the ties on the outside ends.

3.3.5 Tie Plates

Tracks must be fully tie-plated. Ensure tie plates are free of dirt and other foreign material when installed. Place tie plates so that the rails will have full bearing on the plate, and the plate will have full bearing on the tie. Set tie plates at right angles to the rail with the outside shoulder against the base of the rail, and centered on the tie. Install canted tie plates to cant the rail inward.

3.3.6 Rail

Ensure the base of the rail and the surface of the tie and tie plate are free of dirt and other foreign materials prior to laying rail.

3.3.6.1 Laying Rail

Lay rail without bumping or striking, to narrow gage (1.067 m between points 16 mm below the top of the rail) on tangents and on curves up to 12 degrees.

- a. Lay jointed rails, one at a time, with space allowance for expansion being provided between rail ends in accordance with TABLE VI.
- b. Gaps between rail ends in insulated joints must only be sufficient to permit insertion of standard end posts.

- c. Use a standard rail thermometer to determine the rail temperature. Lay the thermometer close to the web on the side of the rail base which is shaded from the sun's rays in advance of the laying operation and leave there long enough to accurately record the temperature. The Contractor quality control representative must see that rail temperature is checked frequently and that proper rail expansion shims are used. Calibrate all thermometers against the Contracting Officer's rail thermometer which will have been accurately calibrated and will be considered as the standard.
- d. Except through turnouts and at insulated joints, do not vary the staggering of the joints on one side no more than [460] [500] mm in either direction from the center of the opposite rail.
- e. Do not use rails less than 10 m in length in out-of-face rail relay. However, rails no less than 4 m long may be used for final connections to existing rails to prevent joints from occurring at prohibited locations or to provide the specified joint stagger in curves.
- f. Rail joints must not occur in or within 6 m of a road crossing, alongside of or within 1.5 m of the end of any switch or turnout guard rail, or the end of any open deck bridge.

3.3.6.2 Joints

Align [Stagger] joints in opposite rails [one-half the rail length but no less than 3.5 m apart, except closer joints may be required at turnouts and insulated joints]. Do not install rail less than 4 m in length in track. Ensure no joint is less than 2 m from the ends of open-deck bridges, or less than 1 m from switch points. Do not install joint within 6 m of a road crossing, outer perimeter of any structure, or any location which restricts access to the joint. Where joints are required in these areas, weld the joints.

3.3.6.3 Expansion Allowance

Provide allowance for expansion at rail joints by using rail-expansion metal shims. Remove shims to within 12 rails of the laying. Provide shims of the thickness shown in TABLE VI. Determine the temperature of the rail by use of a thermometer placed on the rail base on the side away from the sun. Typical rail gap gages are as shown.

TABLE VI. SHIM THICKNESS					
10.1 m Rail 99 Joints per km		12.5 m Rail 84 Joints per km		25 m Rail 42 Joints per km	
Rail Temperature (degrees C)	Shim Thickness (mm)	Rail Temperature (degrees C)	Shim Thickness (mm)	Rail Temperature (degrees C)	Shim Thickness (mm)
Below -23	8	Below -14	8	Below 2	8
-23 to -10	6	-14 to -4	6	2 to 8	6

TABLE VI. SHIM THICKNESS					
10.1 m Rail 99 Joints per km		12.5 m Rail 84 Joints per km		25 m Rail 42 Joints per km	
Rail Temperature (degrees C)	Shim Thickness (mm)	Rail Temperature (degrees C)	Shim Thickness (mm)	Rail Temperature (degrees C)	Shim Thickness (mm)
-9 to 1	5	-3 to 7	5	9 to 16	5
2 to 15	3	8 to 18	3	17 to 23	3
Over 16	2	Over 19	2	Over 24	2

3.3.6.4 Cutting Rail

Use only rail saws or track chisels to cut rail. Drill new holes using a standard template. Do not burn holes in rail. Holes cut with a torch will not be accepted. When drilling of rail is necessary, remove all chips and burrs before applying joints.

3.3.6.5 Rail Replacement

The following procedures apply to rail replacement work:

- a. Spot rail replacement is defined as replacement of 30 m or less of contiguous rails, usually with rails of the same section. Installation of relief rail in place of defective rail is considered spot rail replacement. Replacement of more than 30 m of contiguous rails is considered to be out-of-face rail relay.
- b. If spikes are withdrawn, plug the holes with treated tie plugs of proper size to fit the hole, prior to replacement of rail. If spikes are withdrawn and spikes are to be redriven in existing spike holes, plug the holes with treated tie plugs prior to redriving the spike. Do not install tie plugs in prebored holes unless spikes have been driven and withdrawn.
- c. Spike all ties with new spikes in accordance with paragraph Spot Tie Replacement.
- d. Ensure that rail ends at joints are not lipped or uneven. Ensure tread portion (vertical) or gage side (horizontal) rail end mismatch is no greater than 2 mm. Correct rail end mismatch greater than 2 mm by welding and grinding on the smaller rail. Grinding the larger rail is not permitted unless approved by the Contracting Officer. Make welded transitions at a rate of 1 to 80.
- e. Rails removed from track will be designated by the Contracting Officer as relay (for use on project), reclaimer (to be salvaged and stockpiled), or scrap. Joint bars removed from track will be designated as relay, reclaimer, or scrap. Mark scrap materials as scrap using bright red paint, transport them off the military installation or to the military installation temporary scrapyard.

Transport relay materials required to complete other repair work of this contract to the location of need. Classify and inventory materials and stack at the military installation storage site, all as indicated for salvage materials in paragraph Removal, Salvage, and Disposition of Materials.

- f. Use metal rail expansion shims when laying rail. Do not use wood sticks or other material as shims. Provide a sufficient supply of each shim available to permit rail laying to progress without delay.

3.3.6.6 Out-of-Face Rail Relay

Replace existing rail with the designated new or used rail between designated limits in a continuous operation. It is expected that replacement of one rail of a given track will be completed prior to replacement of the opposite rail. Lay used rail [with previous gage side wear facing out, unless required to match existing wear patterns] [as directed by the Contracting Officer].

3.3.6.7 Spot Rail Replacement

Make spot rail replacements where necessary to replace existing defective rails or to compensate for rail joint gap adjustments.

3.3.6.7.1 Replacement Rail

Use replacement rail of equal length or longer than the rail it replaces. The minimum length of rail used is 4 m.

3.3.6.7.2 Spot Rail Replacement Resulting in Joint Stagers

Unless otherwise approved by the Contracting Officer on a case by case basis, do not allow spot rail replacement to result in joint staggers less than 1.33 m.

3.3.7 Joint Bars

Provide clean joint bars. Install rail joints so that bars are not cocked between the base and head of the rail. Properly seat bars in the rail and install the full number of correct-size bolts, nuts, and spring washers. Place bolts with nuts alternately on inside and outside of rail. Apply a corrosion resistant lubricant to the bolt threads prior to application of nuts. Tighten bolts to torque of approximately [_____] N-m, beginning at the center of the joint and working both ways to the ends of the joint. After the track has been in service [, but before acceptance of the work,] check all bolts and retighten to a torque of approximately [_____] N-m. [Connect rail of different sections by properly fitting compromise joint bars. The mismatch for compromise joints for either tread surface or on the gage side must not exceed 3 mm]. Replace defective joint bars designated on the contract drawings, discovered by the Contractor during track repair operations, or as identified by the Contracting Officer with acceptable joint bars.

3.3.8 Spiking

3.3.8.1 Spiking Procedures

Spike rail promptly after being laid. Start and drive spikes vertically and square with the rail. Pre-drill synthetic ties accordance with

manufacturer's recommendations for size and depth. Drive spikes to allow approximately 3 to 5 mm space between the underside of the spike and the top of the rail base. Do not overdrive spikes, or straighten while being driven. Do not install spikes through the slots in skirted-type, slotted joint bars (angle bars). Do not drive spikes against the ends of joint bars.

3.3.8.2 Number of Spikes

Use four rail-holding spikes on each tie on tangents and curves less than 4 degrees. Place spikes on the gage side of the running rail directly across from each other and place the spikes on the field side of the running rail directly across from each other. Offset spikes on the gage side longitudinally from the field spike and ensure all four spikes are rail-holding spikes next to the base of the rail. Hold this pattern consistent. On curves 4 degrees or greater, but no more than 36 degrees, use six spikes on each tie with the spikes located as follows: One rail-holding spike on the field side and two rail-holding spikes on the gage side for both rails. [Spike curves 36 degrees and greater with eight spikes per tie, located as follows: One rail-holding spike and one plate-holding spike on the field side and two rail-holding spikes on the gage side for both rails.] Use eight rail-holding spikes on each tie through road crossings.

3.3.9 Rail Anchor Placement

Locate rail anchors as indicated on the project plans. Where the use of rail anchors is indicated, apply a minimum of [_____] anchors per 12.5 m of rail in the pattern indicated on the project drawings. Space the rail anchors approximately uniformly along the rail length. Install rail anchors to the gage side of the rail against the same tie face on opposite rails. Ensure rail anchors grip the base of the rail firmly and have full bearing against the face of the tie. Do not move rail anchors by driving them along the rail. Do not apply rail anchors to track on an open-deck bridge. Where anchors are used on track approaching an open deck bridge, box anchor every third tie for at least four rail lengths, off each end of the bridge. Anchor rail immediately after spiking and before rail has experienced a large temperature change.

3.3.10 Inner Guard Rails

Install guard rails on bridges and trestles as indicated. Ensure guard rails are approximately 280 mm from the gage side of track rails and extend a minimum of 15 m beyond the structure. Curve the ends inward and beveled. Fully bolt guard rails. Ensure guard rails are not higher than the running rail and no be more than 25 mm lower than the running rail. Spike each guard rail with two spikes to each tie but do not tie-plate. Unfit track rail in short lengths may be used for guardrails.

3.3.11 Derails

Install derails properly where indicated. Do not allow derailed equipment to foul other tracks. Install in accordance with the manufacturer's instructions. Where no specific installation instructions are available for salvaged derails, reinstall in accordance with good track construction practice to ensure proper performance of their intended function.

3.3.12 Superelevation

Superelevate curves as shown on the drawings unless otherwise directed by the Contracting Officer. Obtain superelevation by raising the outside rail of the curve. Maintain inside rail at grade. The maximum superelevation will be [_____] mm. Carry full superelevation throughout each curve, unless otherwise directed or shown on the drawings. Ensure superelevation runoff is at a uniform rate, and extends at least the full length of the spirals. The normal rate of superelevation runoff will be 13 mm per 9.4 m; however, this may be increased to 25 mm in 9.4 m with the prior approval of the Contracting Officer.

3.3.13 Preliminary Surfacing

The preliminary alignment and surfacing gangs must follow the unloading of the ballast. Complete rail renewal, tie renewal, bolt tightening, and ballast placement prior to commencement of surfacing and alignment work.

3.3.13.1 Lifts

- a. Bring the track, after being aligned, to grade and surface in lifts not exceeding 100 mm each. After each lift, tamp the ballast. When using jacks, place them close enough together to prevent undue bending of rail or stress of rail and joint. Raise both rails at one time and as uniformly as possible, except where superelevation is required. Lift the track so that after a period of no less than 5 train operations (70 metric ton ballast car) after the last lift, it will be necessary to give the track a final lift of between 25 and 50 mm to bring it to grade.
- b. In areas where major track resurfacing is not required, perform a "skin lift" tamping operation to ensure that the ties are adequately tamped, the ballast section is adequately compacted and dressed, and to correct minor deficiencies in surface and alignment. The rise in skin lift areas is 25 mm or less and usually does not require that additional ballast be placed.
- c. A 50 mm rise must provide an average 50 mm raise in the track being surfaced.
- d. A 100 mm rise must provide an average 100 mm raise in the track being surfaced, and make in at least two lifts not to exceed 50 mm per lift.
- e. A 150 mm raise must provide an average 150 mm raise in the track being surfaced, and make in at least 2 lifts. The initial lift must not exceed 100 mm with the final lift not to exceed 70 mm.

3.3.13.2 Tamping

Perform raising and tamping of track with an automatic, vibratory, squeeze type power tamper with 16 tamping heads, capable of raising both rails simultaneously and maintaining cross-level. The equipment to be used for surfacing operations is subject to approval by the Contracting Officer. Every tie in the track must receive two or more full insertions of the tamping heads. Power-tamp ballast under both sides of ties from each end to a point [300 mm inside each rail for 2.4 m ties,] [380 mm inside each rail for 2.6 m ties,] [and] [460 mm inside each rail for 2.7 m ties]. Fill the center with ballast, but tamping will not be permitted in the center of the tie between the above stated limits. Tamp both ends of the

ties simultaneously and tamp inside and outside of the rail at the same time. Do not use tamping tools with more than 35 percent wear and work opposite each other on the same tie. Tamp ballast under switch ties and road crossing ties the entire length of each tie. Tamp all ties to provide solid bearing against the base of the rail after the track or turnout is raised to grade at final surfacing. Bring all down ties up to the base of rail and machine tamp. Ensure the resultant track surface and alignment is uniform and smooth. Tamping of track in snow or frozen ballast conditions will not be permitted.

3.3.13.3 Replacement of Ties

After tamping has been completed and the jacks removed, replace all ties pulled loose to their proper position, respike and retamp to provide full bearing against the rail.

3.3.13.4 Track Off The Ends of Open Deck Bridges

Track off the ends of open deck bridges must maintain the same grade as the track on the bridge for a minimum of 8 m beyond the bridge abutment and then transition smoothly to meet established track grades.

3.3.13.5 Runoff of Track Raises

Do not allow the runoff at the end of a rise to exceed 13 mm in 9.4 m of track unless otherwise approved by the Contracting Officer.

3.3.13.6 Horizontal Realignment

Establish horizontal realignment of curved track using manual or mechanical means as described in the AREMA Eng Man Chapter 5, Part 3 Section 3.2, "String Lining of Curves by the Chord Method" or as approved by MLIT or the Railroad Company that operates on the railroad.

3.3.14 Final Surfacing

After preliminary surfacing has been completed, check grade and line stakes and bring the track to grade and alignment.

3.3.14.1 Final Tamping

Bring track to grade and retamp the ballast in the manner described for preliminary surfacing, except decrease the tamping distance inside the rail from 300 to 250 mm for 2.4 m ties, 380 to 330 mm for 2.6 ties, and 460 to 410 mm for 2.8 ties.

3.3.14.2 Final Alignment

Give the track a final aligning conforming to the established track centers.

3.3.14.3 Final Dressing

After the final alignment, dress the ballast to the section indicated. After final dressing, do not allow ballast to cover the tops of the ties. Leave the portion of the subgrade outside the ballast line with a full, even surface and properly dress the shoulder of the subgrade to the indicated section to provide proper drainage away from the track.

3.3.14.4 Surplus Ballast

Distribute surplus ballast remaining after final surfacing and dressing of the ballast section or otherwise dispose of as directed by the Contracting Officer.

3.3.15 Cleanup

Upon completion of the work, [remove all rubbish, waste, and discarded materials generated by the work from the project area] [dispose of rubbish, waste, and discarded materials in an approved manner as directed by the Contracting Officer]. Leave areas where the Contractor has worked, including but not limited to, project areas, material storage sites, and borrow or disposal areas in a clean, well-graded, and well-drained condition.

3.3.15.1 Shoulder Removal and Reconstruction

Where track construction or rehabilitation operations result in deposition of materials along the track shoulders that would impede the free drainage of the geotextile and track structure, remove the material. Where [undercutting] [ploughing] operations leave fouled shoulder materials that impede free drainage of the geotextile and the track structure, remove the shoulder material, and reconstruct the ballast shoulders using the materials and dimensions as indicated. Areas where shoulder removal and reconstruction are required [are] [are not] indicated on the drawings.

3.3.15.2 Spoil Materials

Dispose spoil materials removed from the track [as indicated] [off site at the Contractor's expense]. Do not place spoil materials on the shoulders, in ditches, in drains, or in other areas where they would impede the flow of water away from the track.

3.3.16 Final Adjustments

Sixty calendar days after the track has been accepted and put into operation, perform, at no cost to the Government, necessary resurfacing adjustments to leave the track in alignment and on grade.

3.3.17 Tolerances for Finished Track

Completed track must meet the following tolerances. Repair track not meeting the tolerances specified below to meet these requirements, at no additional cost to the Government.

3.3.17.1 Gage

Track gage must be within plus 6 mm or minus 3 mm of narrow gage (1.067 m).

3.3.17.2 Alignment

Measure alignment as the deviation of the mid-offset of a 18.9 m line, with the ends of the line at points on the gage side of the line rail, 16 mm below the top of the railhead. Either rail may be used as the line rail on tangent track; however, use the same rail for the entire length of the tangent. The outside rail in a curve is always the line rail. Alignment on tangents are not allowed to deviate from uniformity more than 13 mm. Alignment on curves are not allowed to deviate from uniformity

more than 10 mm.

3.3.17.3 Track Surface

Track surface must meet the following requirements:

- a. The runoff at the end of a raise must not exceed 13 mm in any 9.4 m of rail.
- b. The deviation from design profile on either rail at the mid-ordinate of a 18.9 m chord must not exceed 13 mm.
- c. Deviation from design elevations on spirals must not exceed 13 mm.
- d. Deviation from zero cross level at any point on tangent or from designated superelevation on curves or spirals must not exceed 13 mm.
- e. The difference in cross level between any two points less than 18.9 m apart on tangents, and on curves between spirals must not exceed 13 mm.

3.3.17.4 Guard Face Gage

Guard face gage is the distance between the guard lines measured across the track at right angles to the gage line, and is measured at the point of frog on both sides of the turnout. The design value for guard face gage is 1340 mm. Ensure guard face gage is within plus or minus 3 mm of the design value.

3.3.17.5 Guard Check Gage

Guard check gage is the distance between the gage line of a frog and the guard line of its guard rail, or guarding face, measured across the track at right angles to the gage line. The design value for guard check gage is 1388 mm. Ensure guard check gage is within plus or minus 3 mm of the design value.

3.4 TURNOUTS AND TRACK CROSSINGS

Locate turnouts and crossovers as indicated on the drawings. Provide complete switch, frog and guardrail assemblies. Accurately bend rail. Changes in rail weight or section will not be permitted within the limits of the switch ties. Place headblocks at right angles to the main track and securely spike in place. Except where directed otherwise, install switch stands so that when the switch is set for the normal position, the connecting rod keeps the points closed with a pulling force. Adjust switches properly. Lubricate switch components and slide plates.

3.4.1 Turnout Reconstruction

3.4.1.1 Install Salvaged Turnouts

Reconstruct turnouts using Government materials, except switch ties which are furnished and installed. This work includes transporting the turnout from the Government stockpile to the installation site and reconstruction of the turnout.

3.4.1.2 Salvage and Install Turnouts

Salvage (remove) and install turnouts. This work consists of removal of

the turnout, transporting to the installation site all turnout materials except the switch ties, and reconstructing the turnout using new switch ties.

3.4.1.3 Turnout Removal and Salvaged or Scrapped

Salvage or scrap materials from turnouts that are removed from the track and that are not to be reinstalled as indicated on the drawings.

3.4.1.4 Trackbed

Prepare the trackbed by excavating and wasting existing ballast or subgrade materials and establishing a firm top of subgrade as indicated on the contract drawings.[Place subballast as indicated and compact.][Place geotextile to the limits indicated.]

3.4.1.5 Replacement Turnout

Construct the replacement turnout at the location indicated on the contract drawings. Locate replacement turnouts so that the point of frog remains at the same location as the original turnout point of frog. Use dimensions, details, and configuration of each turnout as indicated on JIS E 1301, JIS E 1303, JIS E 1304, JIS E 1305, JIS E 1306 and JIS E 1307. Place switch ties as indicated on JIS E 1301, JIS E 1303, JIS E 1304, JIS E 1305, JIS E 1306 and JIS E 1307, except substitute even meter increments in length of switch ties, at Contractor's option, for 150 mm increments in length of switch ties. The end of a switch tie must not be within 355 mm of a spike. Shift connecting tracks to their new alignments as shown on the contract drawings and connect all tracks to the replacement turnout. Place tracks within 30 mm of design alignment prior to ballasting work.

3.4.1.6 Matching

Properly fit and match switch points/stock rails, rail joints, frog castings, and other parts of the turnout that must fit together. Match both rail ends at all rail joints throughout the turnout and at the joints at the frog matched on both the top (tread portion) and on the gage side of the rail. Rail end welding and grinding [are][are not] acceptable methods to achieve a good match.

3.4.1.7 Placing of Ballast

Place ballast as required and the bring turnout to proper grade in a minimum of three lifts. Do not exceed an initial lift of 100 mm. Do not exceed a final lift of 50 mm and bring all tracks into final alignment at that time. Ensure tamping, ballast dressing requirements, and alignment tolerances are as indicated in paragraph TRACK CONSTRUCTION AND OUT-OF-FACE RELAY. Ensure ballast level in cribs beneath the connecting rod, switch point rails, and switch rods are at least 100 mm below any steel.

3.4.1.8 Existing Switch Stand

Install the existing switch stand, or a replacement stand if specified, and adjust the switch operating mechanisms so that the switch operates smoothly and without excessive force being required. Lubricate all switch plates and connection points in the switch rod with a switch lubricant, which does not allow sand or debris to adhere to the lubricant.

3.4.1.9 Rail Anchors

Box-anchor all switch ties to the extent possible. Anchor ties only when box-anchors can be applied to every rail on the tie.

3.4.2 Turnout Repair

Indicate turnouts which will remain in their existing location but require repairs in the "Schedule of Turnout Repairs" on the contract drawings and repaired as specified below.

3.4.2.1 Switch Ties

Remove and replace defective switch ties. Maintain existing nondefective switch ties in place. Install replacement switch ties at a uniform spacing, but no greater than 530 mm center to center. The end of a switch tie must not be within 36 mm of a spike. Do not interlace switch ties, where one tie penetrates the crib area of another tie.

3.4.2.2 Bolt Tightening

Tighten all bolts in all turnouts within the project area. Replace any bolt that cannot be tightened with a bolt assembly of the proper diameter and length.

3.4.2.3 Rebuild Switch Points and Protectors, Frogs, and Guard Rails

Reuild switchpoints, frogs, guard rails, or switch point protectors as specified in paragraph ELECTRIC ARC WELDING.

3.4.2.4 Regage Closure Rails

Regage track from heel of switch to the toe of frog. Perform regaging as specified in paragraph TRACK CONSTRUCTION AND OUT-OF-FACE RELAY.

3.5 HIGHWAY CROSSINGS

Construct highway and other grade crossings within the project as indicated on the contract drawings.

3.5.1 Subgrade

[For new construction, blade the subgrade in the crossing area and for 6 m beyond each end of the crossing to a level surface and compact to at least 90 percent CE55 maximum dry density for cohesive materials or 95 percent CE55 maximum dry density for cohesionless materials.][For track rehabilitation, excavate old contaminated ballast and subballast a minimum 300 mm below the design elevation of the bottom of the tie, 300 mm beyond the ends of the ties, and for at least 6 m beyond each end of the crossing. Blade the subgrade to a level surface.] Clean drainage areas and slope away from the crossing in both directions along the track and the roadway. Install [surface ditches][subdrains] as indicated.

3.5.2 Geotextile Installation

Place geotextile between the subgrade and the ballast section in the crossing area and for 6 m beyond each end of the crossing.

3.5.2.1 Preparation

Prepare surfaces on which geotextiles will be placed in accordance with the applicable portions of this specification, and ensure surfaces are free of irregularities such as sags, cavings, erosion, or vegetation. Correct any irregularities to ensure continuous, intimate contact of the geotextile with the whole surface. Remove any loose material or debris prior to geotextile placement.

3.5.2.2 Placement

- a. When geotextile is to be installed in an existing track following removal of the ballast by undercutting or ploughing, take special care to remove as many of the large ballast particles that remain on the roadbed surface as possible.
- b. Place a protective sand layer 50 mm thick [or subballast] on top of the geotextile after it has been installed.
- c. Carefully place the geotextile on the prepared surface with the long dimension parallel to the prepared surface. Place the geotextile free of wrinkles, folds, creases, and tension. Hold the geotextile in place by pins, small aggregate piles or ballast bags, until it is completely covered. Cover the geotextile immediately after placement in track. The maximum exposure time for the geotextile, from removal of the protective shipping cover to placement of the ballast/subballast cover materials which prevent exposure to sunlight, is 2 consecutive days.
- d. The minimum overlap of geotextile splicing seams is 900 mm. If several geotextile units are placed with the required overlap prior to the placement of the [ballast][subballast], check the overlap distance of each overlap as placement of [ballast][subballast] approaches the overlap. Ensure that the required overlap exists when the geotextile is covered.
- e. The geotextile must remain free of any contamination such as mud, dust, sediment, debris, etc., that will impair its function. Remove contamination without damage to the geotextile or to the prepared surface at the Contractor's expense. If the geotextile is damaged, its function impaired by the cleaning efforts, or if it cannot be properly cleaned, repair the prepared surface, if necessary, and replace the damaged or impaired geotextile with geotextile meeting requirements of this specification. Do not operate equipment in direct contact with the geotextile. Direct surface drainage, as much as possible, away from the geotextile installation area to prevent accumulation of mud, debris, and sediment.

3.5.2.3 Placement of Cover Material

Place [ballast][subballast] cover material in contact with the geotextile ensuring intimate contact of the geotextile with the prepared surface and with the cover material. Perform placement without damage to the geotextile including tears, punctures, or abrasion.

3.5.2.4 Equipment Operations on the Cover Material

Place a minimum depth of 200 mm of cover material over the geotextile before equipment is allowed to operate on the covered geotextile. Limit

equipment operations on the covered geotextile to those necessary for track construction and equipment turning is not allowed on the covered geotextile.

3.5.2.5 Minimum Ballast Depth

The minimum depth of ballast between the bottom of the tie and the top of the geotextile is 300 mm.

3.5.2.6 Tamping Operations

Tamp ballast materials by setting the tamping force and insertion depth to the minimum necessary to adequately tamp the track. Monitor the depth of tamping and limit the depth to prevent detrimental effects of the tamper feet on the geotextile.

3.5.2.7 Double Layers

Double layers of geotextile is not allowed, except for splicing overlaps at seams.

3.5.3 Ballast Placement and Surfacing

Place and tamp ballast as specified in paragraph TRACK CONSTRUCTION AND OUT-OF-FACE RELAY except that in crossings, compact the ballast between the ties thoroughly with a vibratory compactor, or other approved means, after each raise. Tamp the ballast for the entire length of the crossties for highway crossings. Perform final alignment and surfacing of the track prior to placement of the crossing surface. Perform final surfacing to bring the track to the final grade and alignment as indicated on the contract drawings. Where the crossing involves two or more tracks, the top of the rail for all tracks must form a plane with the adjacent roadway surface. The top of rail elevation must be 50 to 100 mm above surrounding pavement elevation, with a smooth transition of pavement. Compact the ballast in the cribs and on the shoulders using a vibratory plate compactor or other approved means.

3.5.4 Ties

Use [hardwood][concrete][polymer composite] ties. Space a minimum of 500 mm center to center. For premanufactured grade crossings, provide ties conforming to the manufacturer's recommendations for the type of grade crossing surface materials being used.

3.5.5 Tie Plates, Spikes, and Anchors

Fully tie plate all ties within the crossing and for 6 m beyond each end of the crossing, and spike with 4 rail-holding spikes per tie plate. [Fully box anchor each tie within the crossing.] [Install rubber tie pads between the tie and tie plate on all ties within the crossing area and for 6 m beyond each end of the crossing.]

3.5.6 Rail

Rail within the crossing area and for 6 m beyond each end of the crossing must be, at a minimum, [57][_____] kg/m. [Protect] [Do not protect] rail from corrosion by application of an approved rust inhibitor. Bolted joints are not permitted in any Type 2, Type 3, Type 4, or Type 5 crossing or within 6 m of either edge of the crossing surface. Bolted joints will

be eliminated by either field welding the joints to form continuous rail throughout this area or by using 24.4 m rail lengths.

3.5.7 Lining and Surfacing

Spike rail to line and mechanically tamp and surface the track to the grade and alignment of the existing track and roadway. Where the crossing involves two or more tracks, bring the top of rails for all tracks to the same plane.

3.5.8 Crossing Surface

Ensure the surface of the highway is [in the same plane as][no greater than 6 mm higher than] the top of the rails for a distance of 600 mm outside of the rails for either single or multiple-track crossings. Make a smooth transition between the crossing surface and the adjoining pavement.

3.5.8.1 Type 1 Aggregate Crossings

Construct Type 1 crossings by placing the aggregate material between the rails and outside of the rails to form an approach ramp as indicated in the contract drawings.

3.5.8.2 Type 1A Aggregate with Timber Flangeway Guards Crossings

Install bond timber headers with the edge of the timber solid against the edges of the tie plates prior to placement of the aggregate. Fasten headers to the ties as indicated using the appropriate size and length fasteners. After installation of the bond timber, place the aggregate in the track and on the outside approaches and compact.

3.5.8.3 Type 2 Timber Plank Crossings

Install Type 2 crossings as shown or in accordance with the manufacturer's instructions for prefabricated timber crossing units. Allow the surface of the crossing timbers to form a smooth plane with the top of the rails and the adjacent roadway surface. Attach crossing timbers to the ties as indicated in the contract drawings using the appropriate size and length fasteners, unless otherwise specified by the manufacturer's instructions.

3.5.8.4 Type 3a Asphalt Crossings

Type 3a crossings are full-depth asphalt crossings as shown in the contract drawings. Place the asphalt in lifts not to exceed 50 mm thick and compact with approved compaction equipment. General requirements for asphalt placement are specified in [_____] State Highway Specifications.

3.5.8.5 Type 3b Asphalt With Timber Flangeway Header Crossings

Type 3b crossings are full-depth asphalt crossings as shown in the contract drawings. Place the asphalt in lifts not to exceed 50 mm thick and compact with approved compaction equipment. General requirements for asphalt placement are specified in [_____] State Highway Specifications. Install flangeway timbers prior to the placement of the asphalt pavement. Install timbers with the dapped edge of the timber solid against the ends of the tie plates. Fasten flangeway timbers to the ties as indicated in the contract drawings using the appropriate size and length fasteners.

3.5.8.6 Type 4a Cast-in-place Concrete Crossings

Construct Type 4 crossings as shown in the contract drawings using the materials specified herein. Provide concrete forming, reinforcement, and placement conforming to the requirements of Section 03 30 00 CAST-IN-PLACE CONCRETE.

3.5.8.7 Type 4b Prefabricated Concrete Panel Crossings

Install Type 4A crossings and crossing materials in accordance with the crossing manufacturer's instructions. Use tie spacings and track materials in the crossing in accordance with the installation instructions and manufacturer's recommendations.

3.5.8.8 Type 5 Full Depth Rubber Crossings

Install Type 5 crossings and crossing materials in accordance with the crossing manufacturer's printed instructions. Use tie spacings and track materials in the crossing in accordance with the installation instructions and manufacturer's recommendations.

3.5.9 Signs and Signals

The type and location of railroad-highway crossing warning signs and signals must conform to the requirements of MUTCD, Part VIII.

3.5.9.1 Location and Positioning of Signs

Locate and erect signs for both highway and railroad track installation as shown. Unless otherwise shown, erect signs so that sign face is vertical and at a deflection angle of 87 degrees from the center of the highway lane or track which the sign serves and facing the direction of travel. Where lanes or tracks are on curves, ensure sign faces are on a deflection angle of 87 degrees to the tangent to the curve. Erect signs so that specular reflection is minimized or eliminated. After installation is completed, the signs will be inspected during the day and at night by the Contracting Officer. If specular reflection is apparent on any sign, adjust its positioning to eliminate or minimize this condition. Make this adjustment and any subsequent adjustments at no additional cost to the Government.

3.5.9.2 Traffic Control

During installation of highway signs, provide for the safe and expeditious movement of traffic through the work area. Provide schedule of lane closures, work zone safety and traffic control, and related items.

3.5.10 Crossing Flangeways

Upon completion of the grade crossing installation, the flangeways through the crossing must be a minimum of 50 mm deep and between 65 and 75 mm wide. Ensure that adequate flangeways are provided prior to installation of the final crossing surface.

3.5.10.1 Flangeway Filler

Except for Type I crossings, fill all open crossing flangeways with [asphaltic concrete and compact as indicated on the drawings][prefomed rubber filler].

3.5.10.2 Clean Grade Crossing Flangeways

Where grade crossing flangeways are obstructed (filled in), remove foreign material to provide a minimum 50 mm depth and 65 mm width flangeways on the gage side of the rails.

3.5.11 As-Built Drawings

Submit one set of reproducible originals of the final as-built drawings for each automatic crossing protection installation prior to final acceptance by the Contracting Officer. Use materials and methods to produce these drawings meeting the requirements of this specification that result in drawings which are easy to revise without damage to the drawing.

3.6 BONDING AND GROUNDING TRACK

Bond and ground track as indicated. Where track is designated for bonding and grounding, ensure the rails are bonded electrically continuous and effectively grounded. Make connections by exothermic welds in accordance with the manufacturer's instructions.

3.6.1 Rail Joint Bond

Bond rail joints on both rails of designated track using an exothermic type bond. Apply bond to the field side of the rail [head] [web] unless otherwise approved by the Contracting Officer. Electrically insulate track to be bonded and grounded from the remaining track using one of the specified insulated joints.

3.6.2 Rail Cross-Bond and Ground

Install rail cross-bond and ground using an exothermic type bond. Apply the cross-bond to the [rail head][rail web]. [Install one cross-bond and ground at 30.5 m intervals along the designated tracks.][Provide one cross-bond and ground for each section of bonded and grounded track.] Make connections between grounding system or ground rods and rails with bare stranded copper cable, install at least 300 mm below the bottom of the ties. Drive ground rods vertically full-length. Locate the top of the ground rod at the toe of the ballast slope a minimum of 300 mm below the top of the subgrade. Do not exceed a maximum resistance to ground from any grounded rail or structure of 25 ohms. Make any corrections needed to reduce the resistance to below 25 ohms at no cost to the Government.

3.6.3 Inspection of Rail Bond and Ground

Visually inspect loose, damaged, or missing rail bond wires, cross bond wires, ground connections, and ground rods. If there is a signal failure, bonding can be tested for current loss in the joints using a volt meter. Mark defective items for repair.

3.6.4 Rail Bonds At Signalized Grade Crossings

Bolted rail joints within the approach circuits to signalized highway grade crossings must be double-bonded using both a rail head bond and a web bond. Install rail head and web bonds in the locations indicated where the existing rail bonds are missing, broken, or otherwise ineffective.

3.6.5 Existing Bonds

Protect existing rail bonds[, cross-bonds][, ground connections, and grounding rods] from damage. Except for bonds attached to rails which are designated to be replaced in this contract, replace bonds which are damaged or destroyed by the Contractor's operation at no cost to the Government.

3.6.6 Removal of Defective Bonds

Remove rail head pin-type and welded-type bonds by shear cutting old cables immediately adjacent to the weld or pin. Remove rail web type pin bonds by knocking the old pin out with a drift. Do not use flames or torches to remove defective bonds.

3.7 INSTALLATION OF MISCELLANEOUS TRACK MATERIALS

3.7.1 Tie Plates

Furnish tie plates to the work sites as required. Deliver excess tie plates, remaining at the conclusion of the contract, to the military installation storage site and stack where directed by the Contracting Officer.

3.7.2 Insulated Joints

Install insulated joints where indicated and in accordance with the manufacturer's installation instructions.

3.7.3 Bumping Posts, Cushion Head, and Wheelstops

Bumping posts, cushion head, and wheelstops must be [removed,][installed,][or][reinstalled][_____]. Perform installation in accordance with the manufacturer's instructions. Where no specific installation instructions are available for salvaged bumping posts and wheelstops, reinstallation must be in accordance with good track construction practice to ensure proper performance.

3.7.4 Inner Guard Rails

Install inner guard rails as detailed in the contract drawings. Spike each rail to alternate crossties throughout the full length using two spikes per rail per tie; tie plates are not required. Install guard rails using acceptable joint bars of the proper size to fit the rails being joined. Bolt each joint with at least two bolts and one fully tightened bolt per rail.

3.7.5 Gage Rods

Install one gage in the crib immediately ahead of the switch point of all turnouts. Install two gage rods on the curved closure rail, one ahead of the joint, and one ahead of the toe of the frog in all turnouts.

3.7.6 Installation of Joint Bars

Install joint bars with their full number of bolt assemblies unless otherwise noted. Seat bars properly on the rail and tighten the bolts beginning at the center of the joint and working toward the ends of the

bars, alternating between rails. Use bolts of the proper diameter and length for the rail and joint bars at the joint. The use of extra washers to shim out track bolt nuts is prohibited. Place bolts with nuts alternately on inside and outside of rail.

3.8 BRIDGE REPAIR

Submit shop drawings necessary for the construction and erection of the railroad bridge work. Provide shop drawings made from measurements taken at the site wherever possible or from established measurements, when actual measurements are not available. The Contractor is responsible for the accuracy of the established measurements, the information furnished to the subContractors for the preparation of their Shop Drawings, and the checking of all Shop Drawings. Drawings must bear the stamp of a Professional Engineer. Repair bridge as follows:

3.8.1 State and Local Government Permits

Obtain necessary permits from state and local governments for work over public roads. Prepare traffic maintenance and detour plans; submit them for approval to the appropriate authorities; erect and maintain signs, barricades, lighting, and other traffic control devices in accordance with MUTCD; pay for police details; and stage the work to provide for the continued safe public use of the roadways beneath the bridges.

3.8.2 Work Hours

The Contractor may be required by local or state authorities to work at night or on split shifts to avoid peak traffic hours at bridges [_____]. No additional compensation will be made for any costs associated with meeting such requirements.

3.8.3 Schedule of Bridge Repair Work

Schedule the work of this project to minimize the duration of interruptions to rail service. Schedule bridge repair work, so that to the maximum extent practical, bridges on the same line are taken out of service and repaired simultaneously.

3.8.4 Timber Pile Repair

A timber pile can be spliced or shimmed to repair areas of deterioration or to compensate for settlement of the pile. Any spliced pile must achieve a bearing adequate for its design loading. Do not splice more than 50 percent of the piles in a single bend. Do not splice or shim more than 25 percent of the piles in the entire substructure.

3.8.5 Timber Pile Replacement

Replace any pile when it does not achieve adequate bearing, the pile has greater than 50 percent deterioration, or replacement is more economical. [Drive replacement pile along side existing piles] [Construct a two pile support pier under the bridge cap to carry the load of the deteriorated pile].

3.8.6 Bridge Tie Replacement Open-Deck Bridges

Where spot replacement of bridge ties is required, remove the existing tie without permanently disturbing the track surface. Use new bridge ties of

the proper wood species, structural grade, and size for the intended application. Shimming of bridge ties will not be permitted.

3.8.7 Rivet Replacement

Where replacement is required, replace rivets with high-strength bolts as specified in Section 05 12 00 STRUCTURAL STEEL.

3.9 ELECTRIC ARC WELDING

Perform welding to repair or rebuild frogs, switch point, guard rails, switch point protectors and rails (engine burns, battered ends, etc.) in accordance with AREMA Eng Man, Chapter 5, Part 5, Section 5.10 and AWS D1.1/D1.1M. Submit a detailed specification covering the step-by-step procedures to be employed in making the electric arc welds. Include a complete description of each of the following items as applicable and any other essential characteristics in the procedure specifications.

- a. Type, size, and capacity of electric welding machine (250 amp minimum), grinder and other equipment. Also, type and size of material (welding rod or wire).
- b. The method to be used to remove defective and excess metal prior to welding (arcair or grinding).
- c. The method to be used to prevent warping.
- d. The method used for preheating, including time and temperature.
- e. The method of applying metal buildup and slag removal.
- f. The method of securing original contour of items welded.
- g. Quality control procedures to be followed.
- h. Welding materials (rod or wire), name and manufacturer of materials (low carbon steel) for welding rail, rail frogs, guard rails, switch point protectors, and switch points without manganese inserts and materials (manganese alloy) for welding manganese frogs, RBM frogs, manganese switch point inserts and manganese railroad crossing inserts or castings.

3.9.1 Welding Supervision

Perform electric arc welding under the direct supervision of an experienced welding supervisor or foreman and by a certified welder.

3.9.2 Weather Conditions

Do not perform welding in rain, snow, or other inclement weather without adequate protection of the welding from the elements.

3.9.3 Welding Manganese Frogs and Crossings

Tighten bolts, drive spikes down, and tamp ties under crossing and frogs for level surface, when welding manganese frogs and crossings. Grind out chips and cracks with grinding machine or gouge out with arcair gouging device even if crack goes through the entire casting. When gouging device is used, no finished grinding of cracks or chips is required. If cracks

are gouged out to bottom of casting, reinforcement strap must be [placed underneath the hole.][welded to the bottom of the hole in casting with the wire feed machine, allowing the frog or crossing to be welded back to level surface using the skip method.]

3.9.3.1 Manganese Overheating

Ensure that manganese is not overheated in this process. If manganese shows signs of overheating, allow casting to air cool and then continue welding process. Repeat the process as many times as necessary to prevent manganese from overheating. [Use] [Do not use] flnge carbons to keep welding metal out of flangeways. Build welded surface slightly higher than normal surface of casting so when ground, it will have sufficient weld metal to grind to a level surface. Use a 600 mm straightedge to check this work. Grind edges of flangeways and sides of points in a roll manner, using a frog and crossing flangeway gage as a guide.

3.9.3.2 Slotting

Slot manganese frogs and crossings with a 5 mm slotting wheel. Also weld, grind, and slot connecting rail joints to frog in like manner. Repeat the grinding and slotting process approximately 6 weeks from the time the frog is put back in service and thereafter when overflow appears on points and flangeways.

3.9.4 Welding Switch Points

Overflow of stock rail must be ground off of ball of rail on both sides and switch point ground to where cracks and chips are ground out. Grind off all grease and rust of point as far back as point is to be welded. Adjust switch point tight against stock rail and check gage. If gage just ahead of switch point is tight, open it to where gage reads 6 mm open. Do the following before starting to weld: 1) Open switch point and place rail flange carbon between switch point and stock rail. 2) Pull switch tight against carbon and hold with spike; another rail carbon can be placed just on top of reinforcement binding strap on point to use as guide for first welding pass; carbon can then be removed or left in place. 3) Grind switch point with surface grinder or utility grinder. 4) Apply graphite or oil to switch points and plates to prevent rusting and to make switch throw easier. 5) Check with proper authority to ensure ample time to complete welding, grinding and cooling before traffic is due. Switch point must be ground welded complete without chipping weld slag.

3.9.5 Welding Switch Point Protectors

3.9.5.1 In Track

Perform the following operations: 1) Check with proper authority to ensure ample time to complete welding, grinding and cooling before traffic is due. 2) Use a steel ruler to determine the amount of weld needed on manganese switch point protectors; measure the top of the protector any place where there is no wear. 3) Grind out the work hardened surface and any cracks or chips. 4) Weld the protector with the semi-automatic wire feed machine slightly wider than the width of a new switch point protector; run a string bead along the bottom of the wear surface on the protector guard; leaving flux on this bead continue with string bead until protector is built back to size without overheating the protector. If signs of overheating appear, use intermittent welding procedure. 5) Grind back the protector to the correct width. 6) Use roll method on top inside

corner of protector.

3.9.5.2 Out of Track

Perform the following operations: 1) Use a steel tape to determine the amount of weld needed on manganese switch point protectors; measure the top of the protector any place where there is no wear. 2) Ground out the work hardened surface and any cracks or chips. 3) Weld the protector with the semi-automatic wire feed machine to just a little wider than the width of a new switch point protector; the protector can be laid on its side and three flat beads run on wear surface of the protector guard; ground back to the size of a new protector. 4) Use intermittent method and skip welding to keep protector from overheating. 5) Use the roll method on inside corner of running wear surface of guard.

3.9.6 Welding Engine Burns

Remove the damaged steel of the rail by grinding or arc air to get below the burn area into sound metal. Remove sufficient amount of metal to eliminate all shatter cracks.

3.9.6.1 Depth and Length Limitations

Do not repair engine burns requiring welds greater than 10 mm in depth below the top of the rail head by welding and grinding. While grinding out the damaged metal, stop the operation when it is discovered that the necessary weld will go too deep into the rail head. Weld the ground out portion and apply joint bars at the weld location with the rail undrilled at the middle bolt holes, centering the joint bars under the engine burn. Notify the supervisor of maintenance immediately so that the rail can be removed from track. Dispose these failed rails in accordance with current instructions. Do not weld engine burns which would require a weld longer than 200 mm.

3.9.6.2 Ambient Limitations

Avoid welding and grinding engine burns when the air temperature is below 0 degrees C. When welding is necessary below 0 degrees C, protect the heated area by covering with insulating material to retard cooling. Do not weld engine burns during rain or heavy snow.

3.9.6.3 Number of Welds

Determine the maximum number of burns in a 12 mm rail, or equivalent, that can be economically welded. Unless otherwise directed, when a rail has more than 8 burns needing repair, replace the rail.

3.9.6.4 Welding Procedure

Weld the burn with semi-automatic wire feed machine. Use the skip method in this process because no preheating or post heating is needed. If engine burns are found in groups close together, grind out ten to fifteen burns at a time, welding one pass at a time on each of the burns. Repeat the process until all of the burns are completed to a surface just higher than the normal ball of the rail. Then cool the burn until hand can be placed on it. Grind welds to a level surface with cup wheel attachment grinder.

3.9.7 Welding Rail Joints

Tighten bolts in the joint bars and pull the joint to a level surface. Check joint bars for wear and replace if they are badly worn. Use six hole bars if available. Place a straightedge across the joint to determine the amount of batter. Use straightedge with a minimum of 450 mm in length. Do not weld a rail joint with less than 3 mm of batter. If batter is 3 mm or more, build up the rail joint. If rail cracks or chipped out places are present in rail ends, melt them out with acetylene torch, gouge out with arcair or grind out with grinder. If cracks or chips extend below ball, replace rail. Replace rail if horizontal crack in ball of rail extends more than 200 mm. Preheat rail ends to approximately 93 degrees C before welding. Starting 40 mm from the end, build the rail back as follows: Weld a 25 mm strip into bed; grind the rail ends to a level surface with surface grinder or cup wheel attachment; and cross slot rail joint with 5 mm grinding stone to keep rail ends from overlapping and chipping out.

3.10 THERMITE WELDING PROCEDURES

Submit a detailed statement covering the step-by-step procedures to be employed in making the welds, including a complete description of each of the following items, as applicable, and any other essential characteristics included in the welding procedures:

- a. The manufacturer's trade name for the welding process.
- b. The method used for cutting and cleaning the rail ends. Flame cutting of rail ends will not be allowed.
- c. The minimum and maximum spacing between rail ends.
- d. The method used for maintaining the rails in alignment during welding.
- e. The method used for preheating, including time and temperature.
- f. The tapping procedure, including the minimum time required to cool the weld under the mold insulation.
- g. The method used, including a description of special tools and equipment, for removing the upset metal and finishing the weld to the final contour.
- h. Quality control procedures to be followed.
- i. The contractual agreements with any subcontractor employed by the Contractor in doing the work.

Perform thermite welding procedures by a technician certified to meet ANSI/ASNT CP-189, level II or III qualifications and comply with the following paragraphs:

3.10.1 End Preparation

Rails to be welded must meet the requirements Section 2.2, "Specifications for Fabrication of Continuous Welded Rail" given in Chapter 4, Part 2 of AREMA Eng Man. Align the rail ends in accordance with paragraph GAP AND ALIGNMENT. Rail ends must show no steel defects, dents, or porosity before welding. Do not make bolt holes in, or permit to remain in, the

ends of the rail to be welded. One handling hole may be made in each end of welded string. Cut off rail ends containing such holes during track construction. Rail which must be cut for any reason must be cut square and clean by means of approved rail saws or abrasive cutting wheels in accordance with Chapter 5 of AREMA Eng Man, Section 10.3, "Recommended Practice For Use of Abrasive Wheels".

3.10.1.1 Cleaning

Clean rails to be welded of grease, oil, dirt, loose scale, and moisture to a minimum of 150 mm back from the rail ends, including the railhead surface. Clean using a wire brush, to completely remove dirt and loose oxide and by use of oxygen-acetylene torch to remove grease, oil and moisture. Use a power grinder with an abrasive wheel to remove scale rust, burrs, lipped metal and mill brands which would interfere with the fit of the mold, for 50 mm on each side of the ends.

3.10.1.2 Gap and Alignment

The minimum and maximum spacing between rail ends must be as specified by the rail welding kit manufacturer and the approved welding procedures.

- a. The ends of the rails to be welded must be properly gapped and aligned to produce a weld which conforms to the alignment tolerances below. Align rail on the head of the rail. Hold rail gap and alignment without change during the complete welding cycle.
- b. Vertical alignment must provide for a flat running surface. Any difference of height of the rails must be in the base.
- c. Align horizontally so that any difference in the width of heads of rails occurs on the field side. Horizontal offsets are not allowed to exceed 1 mm in the head and/or 3 mm in the base.

3.10.2 Surface Misalignment Tolerance

Combined vertical offset and crown camber is not allowed to exceed 3 mm at 315 degrees C or less. Combined vertical offset and dip camber is not allowed to exceed 1 mm at 315 degrees C or less.

3.10.3 Gage Misalignment Tolerance

Combined horizontal offset and horizontal kink camber is not allowed to exceed 3 mm at 315 degrees C or less.

3.10.4 Thermite Welding

Perform welding in accordance with Chapter 4, Part 2, Section 2.5 of AREMA Eng Man, articles "Thermite Welding - Rail Joints" and Section 2.2 "Specification for Fabrication of Continuous Welded Rail", except as modified by these specifications. Inspect all welds visually at the time of welding.

3.10.4.1 Thermite Weld Preheating

Preheat rail ends prior to welding to a sufficient temperature and for sufficient time as indicated in the approved welding procedures to ensure full fusion of the weld metal to the rail ends without cracking of the rail or weld.

3.10.4.2 Thermite Weld Cooling

Leave molds in place after tapping for sufficient time to permit complete solidification of the molten metal and proper slow cooling to prevent cracking and provide a complete weld with proper hardness and ductility.

3.10.5 Weld Finishing and Tolerances

Bring welded joints in the finished track to a true surface and alignment by means of a proper grinding or planing machine (shear). Perform finish grinding with an approved grinder operated by a skilled workman grinding evenly and leaving the joints in a smooth and satisfactory condition. Eliminate all cracks. Finish the completed weld by mechanically controlled grinding in conformance with the following requirements:

- a. A finishing deviation of not more than plus or minus 1 mm of the parent section of the rail head surface will be allowed. Finish the gage side of the rail head to plus or minus 1 mm of the parent section.
- b. Welds produced by welding kits which are specially designed to produce reinforced welds need not be ground in the finishing area except as necessary to remove fins, burrs, cracks, etc.

3.10.6 Weld Quality

Each completed weld must have full penetration and complete fusion and be entirely free of cracks or fissures. Welds must meet the acceptance criteria given in AWS D1.1/D1.1M.

3.10.7 Weld Numbering

Semi-permanently mark a sequential weld number on the rail immediately adjacent to the weld, using a quality lead paint marker at the time the weld is made. Number welds sequentially in the order in which they are made. The Contracting Officer will provide the initial weld number. Assign defective welds which are replaced a new sequential number by adding a letter to the defective weld number (e.g., defective weld 347 would be replaced by 347A).

3.11 TRACK REPAIR

3.11.1 Cutting and Drilling of Rail

Use only rail saws and abrasive cutting wheels for this operation. Other methods for cutting rail will not be acceptable. Cuts must be square and clean. When given the option of cutting existing rail or new rail being installed, cut the existing rail. When new holes are necessary, they must be drilled. Do not punch, slot, or burn holes with a torch. Ensure holes are sized and located as shown on the contract drawings. Peen or grind drilled bolt holes to remove sharp edges.

3.11.2 Rail Joints

In areas which do not require out-of-face rail replacement, tighten all track bolts. Defective track bolts, nuts and lock washers ("bolt assemblies"), and replace those that cannot be tightened. This work includes both spot replacement of assemblies at locations to be determined by the Contracting Officer ("Spot Bolt Assembly Replacement") and

out-of-face replacement of all bolt assemblies within a rail joint ("Joint Repair").

3.11.2.1 Used Bolt Assemblies

Used bolt assemblies removed from rail joints are the Contractor's property and do not be reincorporated in the work. Remove existing bolt assemblies designated to be replaced by methods which do not damage joint bars or rails.

3.11.2.2 Joint Repair

Replacement of defective joint bars and correction of rail-end mismatch, as designated or directed by the Contracting Officer, is defined as joint repair work. At designated joint repair locations, remove both joint bars from the rails and inspect the rail ends for damage or defects.

3.11.2.3 Cleaning of Finishing Area

Clean the finishing area of mill scale, rust, and dirt by wire brushing, compressed air, solvents, or a combination of these or other methods.

3.11.2.4 Rail Ends

The clean rail ends will be jointly examined by the Contractor and the Contracting Officer for the presence of any rail defects that would make the rail unsuitable for further use at the location. If a rail is determined to have an end defect, either crop or replace the rail.

3.11.2.5 Joint Gap

Where pull-aparts have occurred, whether currently gapped or not, or where the rail joint gap exceeds 19 mm, adjust the joint gap to the rail joint gap specified in TABLE VI. Perform rail joint gap adjustment work in conjunction with spot rail replacement work and bolt renewal work.

3.11.3 Spiking

Verify the proper gage, as indicated in this section, immediately prior to spiking.

3.11.4 Spot Tie Replacement

Replace defective ties as marked in the field and as directed by the Contracting Officer.

3.11.4.1 Paint Markings and Tie Inspection

Paint markings may exist on the existing rails and crossties. Such markings do not necessarily indicate work within the scope of the contract. Participate in a walk-through tie inspection with the Contracting Officer prior to commencement of tie replacement work. The scope of the tie replacement work will be determined at that time and relevant paint markings made or touched up as required.

3.11.4.2 Additional Tie Work

In areas where existing ballast inhibits tie inspection, additional ties may be required beyond those marked. The scope of such additional tie

work will be identified by the Contracting Officer as adjacent work progresses.

3.11.4.3 Old Spikes, Rail Anchors, tags and Tie Plates

Pull and scrap old spikes. Remove, sort, and salvage rail anchors. Remove and inspect tie plates and, classify as either relay or scrap. Mark scrap tie plates as scrap and do not reinstall in the track. Acceptable relay tie plates may be reused at that location or at other locations as required. Old stationing tags will be removed and replace on the new tie.

3.11.4.4 Humped Track

Where the track will not be surfaced, in order to prevent permanent distortion ("Humping") of the line and surface of the track when performing spot tie replacement, excavate the tie cribs and ends, remove the old ties, and install the new ties without jacking the rails. Resurface humped track at the Contractor's expense.

3.11.4.5 Minimal Humping

For spot or out-of-face tie replacement, where the track will be surfaced and aligned under this Contract, a minimal amount of humping will be allowed, provided the surfacing tolerances can be met.

3.11.4.6 Fouled or Muddy Ballast

Excavate and waste fouled or muddy ballast, as identified by the Contracting Officer, outside of the track area where it will not interfere with drainage of the track.

3.11.4.7 Insertion of New Ties

Insert new ties with the flat (tie plate) surface up, square to the line of the rails.

- a. Insert ties so that the average tie spacing in any one rail length does not exceed 530 mm and so that the maximum spacing between any two ties does not exceed 610 mm and the maximum spacing is not less than 460 mm.
- b. Crosstie position at joints must result in a "suspended joint" arrangement unless otherwise directed by the Contracting Officer.

3.11.4.8 Positioning of Tie Plates

Position tie plates on the tie so that the shoulder has full bearing against the base of the rail. Center the plate on the tie width, except position the plate up to 13 mm off-center if necessary to avoid spiking into an existing tie split. Ensure that all tie plates in a given stretch of track are either canted or flat. Do not mix canted and flat tie plates within a given stretch of track.

3.11.4.9 Re-spacing of existing ties

Re-spacing of ties is required to straighten slewed ties or to correct uneven tie spacing. Remove crib and shoulder ballast as required to facilitate sliding crossties to their final position or to insert new

ties. Do not use spike mauls or sledges to slide ties. Install rail anchors and ballast immediately after ties are re-spaced.

3.11.4.10 Track Gage

Set track gage at the time of spiking.

3.11.4.10.1 Tangent Track

For track rehabilitation or spot rail replacement on tangent, regage the track if the existing gage is less than 1420 mm or is equal to or greater than 1460 mm. Regage these sections of track to conform with the gage of the adjacent track; ensure the gage after regaging is between 1430 and 1450 mm.

3.11.4.10.2 Curved Track

Gage curved track as shown in TABLE V.

3.11.5 Joint Respiking

Many joints in track will be found with nonstandard spiking patterns and other deficiencies. These include joints with no tie plates, plates which are positioned so that it is not possible to spike through the plate on both sides of the joint, spikes driven against the ends of skirted joint bars, and similar deficiencies. Respike such joints in accordance with the following.

3.11.5.1 Substitution of Tie Plates

When tie plates are available which will permit spiking through the tie plate at the edge of the joint bar skirts on both sides of the rail, substitute them for existing plates.

3.11.5.2 Respiked Joints

Plug existing spike holes in all respiked joints.

3.11.6 Regaging

Where the existing track gage is less than 1420 mm or is equal to or greater than 1460 mm, or as designated by the Contracting Officer, regage the track. Regage these sections of track to conform with the gage of the adjacent track; ensure the track gage after regaging is between 1430 and 1450 mm.

3.12 SAMPLING AND TESTING

Sampling and testing is the responsibility of the Contractor. Submit one certified copy of Test Reports for each test performed on the ballast [and subballast] within 2 working days of the test completion. Perform sampling and testing by an approved commercial testing laboratory, or by the Contractor, subject to approval. If the Contractor elects to establish testing facilities, base approval of such facilities on compliance with ASTM D3740 or as approved by MLIT. Work requiring testing will not be permitted until the Contractor's facilities have been inspected and approved. The first inspection of the facilities will be at the expense of the Government and any subsequent inspections required because of failure of the first inspection is at the expense of the

Contractor. Such costs will be deducted from the total amount due the Contractor.

3.12.1 Ballast [and Subballast] Samples

Perform periodic sampling and testing of ballast [and subballast] material to ensure continued compliance with this specification. During construction, take one representative sample of the ballast [and subballast] material from each 1818 metric tons of ballast [and subballast] delivered to determine the material gradation. For each 9090 metric tons or a fraction thereof of ballast delivered, obtain an additional amount of material in order to perform the quality and soundness tests specified. Take samples for material gradation, quality, and soundness tests in conformance with ASTM D75/D75M or JIS A 1201. Reduce test samples from field samples in conformance with ASTM C702/C702M. Ensure sample sizes are sufficient to provide the minimum sample sizes required by the designated test procedures. If any individual sample fails to meet the gradation requirement, halt placement and take immediate corrective action to restore the specified gradation. If any individual sample fails to meet the specified quality and soundness requirements, halt placement and take immediate corrective action to restore the specified quality.

3.12.2 Ballast [and Subballast] Tests

3.12.2.1 Sieve Analyses

Make sieve analyses in conformance with ASTM C117 and ASTM C136/C136M or JIS A 1102. Sieves must conform to ASTM E11 or JIS Z 8801.

3.12.2.2 Bulk Specific Gravity and Absorption

Make bulk specific gravity and absorption tests in conformance with ASTM C127 or JIS A 1110.

3.12.2.3 Percentage of Clay Lumps and Friable Particles

Determine the percentage of clay lumps and friable particles in conformance with ASTM C142/C142M or JIS A 1137.

3.12.2.4 Degradation Resistance

Determine resistance to degradation of materials in conformance with ASTM C131/C131M or JIS A 1121 and ASTM C535. Test materials with gradations having 100 percent passing the 25 mm sieve in conformance with ASTM C131/C131M or JIS A 1121. Test materials having gradations with particles larger than 25 mm in conformance with ASTM C535.

3.12.2.5 Soundness Test

Make soundness tests in conformance with ASTM C88 or JIS A 1121.

3.12.2.6 Percentage of Flat or Elongated Particles

Determine the percentage of flat or elongated particles in conformance with ASTM D4791.

3.12.3 Examination of Geotextile

[Sample the geotextile upon delivery to the project site. Use sampling procedures detailed in ASTM D4759 and ASTM D4354 with the number of sample units selected from TABLE II of ASTM D4354. An independent testing laboratory must perform the index property tests specified in TABLE II on each of the sample units and determine conformance with the minimum requirements of TABLE II. Conformance must be determined in accordance with ASTM D4759.] [Test geotextile seams expected to perform a reinforcement function in accordance with ASTM D4595.] The Contracting Officer may examine any geotextiles for defects, damage, or nonconformance prior to installation. Any geotextile not meeting the minimum property requirements of paragraph GEOTEXTILE, or remove geotextile that is determined to be damaged or defective from the site and replace with additional geotextile meeting the requirements of this specification at no additional cost to the Government.

3.13 INSPECTION AND FIELD TESTING

Perform quality control inspection and field testing.

3.13.1 Track

Perform inspection to ensure that all the requirements of these specifications are met. Inspect bolted joints for loose bolts and for smooth transitions between rails of different sections. Check rail, tie plates, and ties to ensure that the rail is properly seated and has full bearing on the tie plate and tie. Upon completion of construction, take and record measurements of track gage, cross level, and alignment at least once every [30] [60] [_____] m of track centerline length. Provide a copy of these measurements to the Contracting Officer.

3.13.2 Welded Joints - Visual Inspection

Quality control inspection and field testing must be performed by a technician certified to meet ANSI/ASNT CP-189 level II or III qualifications with a minimum of one year experience in testing rail for defects. Inspect each welded joint in the presence of the Contracting Officer after removal of the mold and grinding of excess metal. Pay particular attention to surface cracking, slag inclusion, gas pockets, and lack of fusion. Correct or replace, at no extra cost to the Government, any weld found defective. The method of correction must be as approved by the Contracting Officer.

3.13.3 Electric Arc Welding Inspection

Inspect electric arc welds to determine that the item welded conforms to the desired contour and contains no visible cracks or voids.

3.13.4 Thermite Weld Joints Testing

Each thermite weld joint must be [ultrasonically tested] [dye tested] following the visual inspection. The method of inspection and acceptance must be in accordance with AWS D1.1/D1.1M. Correct or replace defective welds, at no additional cost to the Government. The method of correction must be as approved by the Contracting Officer. Ultrasonic testing [must] [will] be performed by the [Contractor] [Government] after the rail has been installed in track. The testing will determine whether or not each weld meets the criteria of paragraphs Gage and Alignment, Weld Finishing

and Tolerances, and Weld Quality. Cut welds, made in the track which the Contracting Officer determines to be unacceptable, out of the rail and replace by a section of new rail and two new welds. Make saw cuts at least 150 mm from the centerline of the faulty weld. Replacement welds and replacement rails are the sole expense of the Contractor. Renumber replacement welds as indicated. Ultrasonically test replacement welds made in track.

3.13.5 Electric Arc Weld Testing

Inspect the welds visually and check the contours after completion and later test by the ultrasonic method. The [Government will] [Contractor must] have the welds tested by the ultrasonic method. The testing will determine whether or not each weld meets the quality criteria. Defective welds will be removed and the item rewelded at the Contractors expense.

3.13.6 Inspection of Geotextile

At the direction of the Contracting Officer, remove the cover material from the geotextile at 3 locations per km so that the geotextile may be inspected for damage. At each location, remove the cover material to expose a 1.2 by 1.2 m section of the geotextile. If punctures, tears, improper installation, other impairment or damage are found within this section, excavate additional sections to determine the extent of the damage. Repair or replace damaged geotextile and recover with ballast/subballast at the Contractor's expense.

3.13.7 Testing Relay Rail

3.13.7.1 Testing for Wear

Check each relay rail for wear by the Contractor's quality control representative in the presence of the Contracting Officer after the material is delivered to the construction site. Monitor the installation of track for defects in rail and joint bars being installed. Do not install rail and joint bars that are found to be defective in track.

3.13.7.2 Testing for Defects

Upon completion of the track construction, have the rail tested by ultrasonic methods. Ultrasonic testing must be done by a Contractor normally engaged in this type of testing with a minimum of 5 years of experience. Submit results of the ultrasonic rail testing. Results must list defects and rail stationing. Schedule a rail testing machine and notify the Contracting Officer of the type of machine and schedule. Remove and replace Contractor furnished rails which are found to have any detectable defect at that time at no additional cost to the Government. Remove and replace Contractor furnished joint bars and compromise joint bars that are found to be cracked or broken at no additional cost to the Government. Submit Data package 1 in accordance with Section 01 78 23 OPERATION AND MAINTENANCE DATA.

TABLE VII RECORD OF ITEMS REPAIRED OR REBUILT BY THE ELECTRIC ARC WELDING METHOD AND GRINDING					
[enter date]	[enter Installation name]			Turnout Number:	
[enter time (24hr)]	Air Temp (C*) and Weather Conditions:				
ITEM REBUILT	DESCRIPTION	WEIGHT	LENGTH	LH RH	REINFORCED
Switch Point					
Frog					
Railroad Crossing					
Guard Rails					
Switch Point Protector					
Rail (Ends)					
Rail-Engine Burns					
[_____]					
*NOTE: Temperature to the nearest 1/2 degree.					

INSTALLATION _____ WELD NUMBER _____

FINAL INSTALLED

LOCATION _____ TRACK _____
STATION _____ RAIL Left Right (Circle)

DATE _____ TIME _____ AM
PM (Circle)

AIR TEMPERATURE _____ F*. WEATHER _____
RAIL TEMPERATURE _____ F*. _____

WELD KIT MANUFACTURER _____

RAIL GAP

NEAREST 1.6 MM _____

RAIL CUT REQUIRED? YES NO (Circle)

BACK RAIL

MANUFACTURER _____ USED RAIL? YES NO (Circle)

YEAR/MONTH ROLLED _____ HEAT NUMBER _____

AHEAD RAIL

MANUFACTURER _____ USED RAIL? YES NO (Circle)

YEAR/MONTH ROLLED _____ HEAT NUMBER _____

REMARKS _____

ULTRASONIC TEST DATE & RESULTS _____

KIT MFG. REPRESENTATIVE

PRESENT _____ WELDING FOREMAN _____
(Initial) (Signed)

CONTRACTING OFFICER'S

REPRESENTATIVE

PRESENT _____ RECORDER _____
(Initial) (Signed)

_____ RECORDER _____
(Initial) (Signed)

FOR GOVERNMENT USE ONLY

ULTRASONIC TEST DATE AND RESULTS _____

*NOTE: Determination will be made to the nearest 1/2 degree.

-- End of Section --