

SECTION 01 91 00.15 10

TOTAL BUILDING COMMISSIONING
05/16

PART 1 GENERAL

1.1 SUMMARY

Commission the building systems listed herein. Employ the services of an independent Commissioning Firm. The Commissioning Firm must be a 1st tier subcontractor of the General or Prime Contractor and must be financially and corporately independent of all other subcontractors. The Commissioning Firm must employ a Lead Commissioning Specialist for the Contractor (CxG) that coordinates all aspects of the commissioning process. Perform Commissioning in accordance with the requirements of the contract specifications and the standard under which the Commissioning Firm's qualifications are approved. In the case of a conflict, the most stringent requirement will prevail.

The Commissioning Specialist for the Government (CxG) is a Government employee. In general, the CxG coordinates the commissioning activities and reports to the Contracting Officer's Representative/CxG, copying the General or Prime Contractor on all results in accordance with Third Party Certification (TPC) requirements. The CxG's responsibilities, along with all other contractors' commissioning responsibilities are detailed in the specifications. All members work together to fulfill their contracted responsibilities and meet the objectives of the Contract Documents.

1.2 SYSTEMS TO BE COMMISSIONED

Commission the following systems:

- [Heating, Ventilating, Air Conditioning, and Refrigeration Systems (HVAC)
-][Building Automation System
-][Utility Monitoring and Control System
-][Lighting Systems
-][Power Distribution Systems
-][Power Generation Systems
-][Renewable Energy Systems
-][Service Water Heating Systems
-][Plumbing Systems
-][Natural Gas and Propane Systems
-][Water Pumping and Mixing Systems
-][Irrigation Systems
-][Water Harvesting/Reclaim Systems
-][Compressed Air and Vacuum Systems
-][Energy and Water Utility Metering Systems and Sub-Meters
-] Building Envelope: moisture and thermal integrity and air tightness
- [Fenestration Control Systems
-]

1.3 REFERENCES

The publications listed below form a part of this specification to the extent referenced. The publications are referred to within the text by

the basic designation only.

AMERICAN SOCIETY OF HEATING, REFRIGERATING AND AIR-CONDITIONING
ENGINEERS (ASHRAE)

ASHRAE 180 (2012) Standard Practice for Inspection
and Maintenance of Commercial Building
HVAC Systems

ASHRAE 202 (2013) Commissioning Process for Buildings
and Systems

ASSOCIATED AIR BALANCE COUNCIL (AABC)

ACG Commissioning Guideline (2005) Commissioning Guideline

NATIONAL ENVIRONMENTAL BALANCING BUREAU (NEBB)

NEBB Commissioning Standard (2009) Procedural Standards for Whole
Building Systems Commissioning of New
Construction; 3rd Edition

SHEET METAL AND AIR CONDITIONING CONTRACTORS' NATIONAL ASSOCIATION
(SMACNA)

SMACNA 1429 (1994) HVAC Systems Commissioning Manual,
1st Edition

1.4 COMMUNICATION WITH THE GOVERNMENT

The Lead Commissioning Specialist (CxC) must submit all plans, schedules, reports, and documentation directly to the Contracting Officer's Representative concurrent with submission to the CQC System Manager. The Lead Commissioning Specialist must have direct communication with the Contracting Officer's Representative regarding all elements of the commissioning process; however, the Government has no direct contract authority with the Lead Commissioning Specialist.

1.5 SEQUENCING AND SCHEDULING

1.5.1 Sequencing

Complete the following prior to starting Functional Performance Tests of mechanical systems:

- a. All equipment and systems have been completed, cleaned, flushed, disinfected, calibrated, tested, and operate in accordance with contract documents and construction plans and specifications.
- b. Performance Verification Tests of the controls systems have been completed and the Performance Verification Test Report has been submitted and approved in accordance with Specifications.
- c. Testing, Adjusting, and Balancing has been completed and the Testing, Adjusting, and Balancing Report, has been submitted and approved in accordance with Specification Section 23 05 93 TESTING, ADJUSTING, AND BALANCING FOR HVAC.
- d. The building envelope is enclosed according to contract documents with

final construction completed, the Air Barrier Pressure Tests have been completed and the Air Leakage Test Reports and Diagnostic Test Reports have been submitted and approved in accordance with Specification Section 07 05 23 PRESSURE TESTING AN AIR BARRIER SYSTEM FOR AIR TIGHTNESS.

- e. The Pre-Functional Checklists have been submitted and approved.
- f. The Certificate of Readiness for mechanical systems has been submitted and approved.

Complete the following prior to starting Functional Performance Tests of the electrical systems:

- a. All electrical, power generation, and lighting equipment and systems have been completed, calibrated, tested, and operate in accordance with contract documents and construction plans and specifications.
- b. The building envelope is enclosed according to contract documents with final construction completed.
- c. Ceiling tiles, floor coverings, and window coverings are in place.
- d. The Certificate of Readiness for electrical systems has been submitted and approved.
- e. Lamps have completed a minimum 100 hour burn-in period.

1.5.2 Project Schedule

Include the following tasks in the project schedule required by Section [01 32 01.00 10 PROJECT SCHEDULE][01 32 16.00 20 SMALL PROJECT CONSTRUCTION PROGRESS SCHEDULES]. Ensure sufficient time is scheduled to accommodate the requirements of this specification section. The order of items listed below is not intended to imply a specified sequence:

- a. Submission and approval of the Commissioning Firm and Commissioning Specialist
- b. Submission and approval of the Testing, Adjusting, and Balancing (TAB) Firm and TAB Specialist specified in Section 23 05 93 TESTING, ADJUSTING, AND BALANCING FOR HVAC
- c. Submission of the Design Review Report specified herein.
- d. Submission of the Design Review Report specified in Section 23 05 93 TESTING, ADJUSTING, AND BALANCING FOR HVAC.
- e. Submission and approval of the Construction Phase Commissioning Plan
- f. Installation of permanent utilities (gas, water, electric)
- g. Building Envelope Construction
- h. Submission and approval of the Building Envelope Inspection Checklists
- i. Air Barrier Pressure Tests specified in Section 07 05 23 PRESSURE TESTING AN AIR BARRIER SYSTEM FOR AIR TIGHTNESS

- j. Drainage and Vent, Building Sewers, Water Supply Systems and Backflow Prevention Assembly Tests specified in Section 22 00 00 PLUMBING, GENERAL PURPOSE
- k. Factory Acceptance Testing for each of the systems to be commissioned as required by technical specifications
- l. Manufacturer's Equipment Start-Up for each of the systems to be commissioned.
- m. Potable Water System Flushing specified in Section 22 00 00 PLUMBING, GENERAL PURPOSE
- n. Operational Tests of the plumbing system specified in Section 22 00 00 PLUMBING, GENERAL PURPOSE.
- o. Potable Water System Disinfection specified in Section 22 00 00 PLUMBING, GENERAL PURPOSE
- p. Submission and approval of the TAB Schematic Drawings, Report Forms, and Procedures specified in Section 23 05 93 TESTING, ADJUSTING, AND BALANCING FOR HVAC.
- q. Submission and approval of Duct Air Leakage Test Procedures specified in Section 23 05 93 TESTING, ADJUSTING, AND BALANCING FOR HVAC
- r. Duct Air Leakage Test Execution specified in Section 23 05 93 TESTING, ADJUSTING, AND BALANCING FOR HVAC
- s. Submission and approval of the Final Duct Air Leakage Test Report specified in Section 23 05 93 TESTING, ADJUSTING, AND BALANCING FOR HVAC
- t. Testing, Adjusting, and Balancing (TAB) Field Work required by Section 23 05 93 TESTING, ADJUSTING, AND BALANCING FOR HVAC
- u. Submission and approval of the TAB Report specified in Section 23 05 93 TESTING, ADJUSTING, AND BALANCING FOR HVAC
- v. TAB Field Acceptance Testing required by Section 23 05 93 TESTING, ADJUSTING, AND BALANCING FOR HVAC
- w. Submission and approval of the Start-Up Testing Report.
- x. Submission and approval of the Performance Verification Test Procedures.
- y. Performance Verification Tests.
- z. Performance Verification Test Report.
- aa. Pre-Functional Checklist Submittal
- bb. Functional Performance Testing for each system to be commissioned
- cc. Integrated Systems Tests
- dd. Post-Test Deficiency Correction for each system to be commissioned

- ee. Re-Testing
- ff. Endurance Tests
- gg. Training for each of the systems to be commissioned
- hh. Systems Manual/Computerized Maintenance Management System Manual, Maintenance Plan, and Service Life Plan submission and approval
- ii. Submission and approval of the Commissioning Report
- jj. Seasonal Testing

1.6 SUBMITTALS

Government approval is required for submittals with a "G" designation; submittals not having a "G" designation are for information only. When used, a designation following the "G" designation identifies the office that will review the submittal for the Government. Submit the following in accordance with Section 01 33 00 SUBMITTAL PROCEDURES:

SD-01 Preconstruction Submittals

- Commissioning Firm; G
- Lead Commissioning Specialist
- Technical Commissioning Specialists
- Commissioning Firm's Contract

SD-06 Test Reports

- Design Review Report; G
- Interim Construction Phase Commissioning Plan; G
- Final Construction Phase Commissioning Plan; G
- Building Envelope Inspection Checklists; G
- Pre-Functional Checklists; G
- Issues Log
- Commissioning Report; G
- Post-Construction Trend Log Report; G

SD-07 Certificates

- Certificate of Readiness; G

SD-10 Operation and Maintenance Data

- Training Plan; G
- Training Attendance Rosters

Systems Manual; G

Maintenance and Service Life Plans

SD-11 Closeout Submittals

Construction Phase Commissioning Plan; G

Final Commissioning Report; G

1.7 COMMISSIONING FIRM

Provide a Commissioning Firm that is certified in commissioning by one of the following: the AABC Commissioning Group (ACG); the National Environmental Balancing Bureau (NEBB); the International Certification Board/Testing, Adjusting, and Balancing Bureau (ICB/TABB), the Building Commissioning Association (BCA); the Association of Energy Engineers (AEE). The Commissioning Firm must be certified in all systems to be commissioned to the extent such certifications are available from the certifying body. Describe any lapses in certification or disciplinary action taken by the certifying body against the proposed Commissioning Firm or Lead Commissioning Specialist in detail. Any firm or commissioning professional that has been the subject of disciplinary action by the certifying body within the five years preceding contract award is not eligible to perform any duties related to commissioning.

- a. Submit the Commissioning Firm's certification of qualifications including the name of the firm and certifications no later than 60 calendar days after Notice to Proceed. Submit four hard copies and an electronic copy.
- b. The Commissioning Firm's and Commissioning Specialists' certifications must be maintained for the entire duration of the duties specified herein. If, for any reason, the firm or a specialist loses a certification during this period, immediately notify the Contracting Officer's Representative and submit another Commissioning Firm or Commissioning Specialist for approval. All work specified in this specification section performed by the Commissioning Firm or associated Commissioning Specialists is invalid if the Commissioning Firm or Commissioning Specialist loses its certification prior to contract completion and must be performed by an approved successor.
- c. The Commissioning Firm must oversee and assist the General or Prime Contractor with the work specified herein. Submit the Commissioning Firm's Contract including the Scope of Work associated with the paragraph POST-CONSTRUCTION SUPPORT no later than 30 calendar days after approval of the Commissioning Firm. Submit four hard copies and an electronic copy.
- d. The Commissioning Firm may act as the Pressure Test Agency required by Section 07 05 23 PRESSURE TESTING AN AIR BARRIER SYSTEM FOR AIR TIGHTNESS provided that all qualification requirements of that specification section are met.

1.7.1 Lead Commissioning Specialist

The Commissioning Firm must provide a Lead Commissioning Specialist (Cx/C) that has a minimum of five years of commissioning experience, including two projects of similar size and complexity, and that is one of the

following: a NEBB qualified Systems Commissioning Administrator (SCA); ACG Certified Commissioning Authority (CxA); ICB/TABB Certified Commissioning Supervisor; BCA Certified Commissioning Professional (CCP); AEE Certified Building Commissioning Professional (CBCP); University of Wisconsin-Madison Qualified Commissioning Process Provider (QCxP); ASHRAE Building Commissioning Professional (BCxP).

- a. Submit the Lead Commissioning Specialist's certification of qualifications including the name of the specialist and firm; certifications; years of experience; and a listing of representative projects of similar size and complexity no later than 60 calendar days after Notice to Proceed. Submit four hard copies and an electronic copy.
- b. The Lead Commissioning Specialists certifications must be maintained for the entire duration of the duties specified herein. If, for any reason, the specialist loses a certification during this period, immediately notify the Contracting Officer's Representative and submit another Lead Commissioning Specialist for approval. All work specified in this specification section to be performed by the Lead Commissioning Specialist is invalid if the Lead Commissioning Specialist loses its certification prior to contract completion and must be performed by an approved successor.
- c. The Lead Commissioning Specialist must lead and oversee the commissioning work specified herein and be the primary point of contact for the Government regarding the commissioning work.

1.7.2 Technical Commissioning Specialists

Technical Commissioning Specialists, employed by the Commissioning Firm or financially and corporately independent subcontractor hired by the Commissioning Firm, and that have the following qualifications, must perform the technical work specified herein associated with each system to be commissioned:

- a. The technical work associated with mechanical systems including Heating, Ventilating, Air Conditioning, and Refrigeration Systems; Building Automation System; Utility Monitoring and Control System; Service Water Heating Systems; Plumbing Systems; Water Pumping and Mixing Systems; [Irrigation Systems]; [Compressed Air and Vacuum Systems]; Energy and Water Utility Metering Systems must be performed by a Commissioning Specialist certified by NEBB, ACG, ICB/TABB, or BCA in the commissioning of HVAC systems with five years of experience in the commissioning of HVAC systems.
- b. The technical work associated with electrical systems including Lighting Systems; Power Distribution Systems; Power Generation Systems; Renewable Energy Systems must be performed by an engineering technician certified by the InterNational Electrical Testing Association (NETA) or the National Institute for Certification in Engineering Technologies (NICET) with five years of experience inspecting, testing, and calibrating electrical distribution and generation equipment, systems, and devices.
- c. The technical work associated with the Building Envelope system must be performed by a registered architect with five years of building envelope design or construction experience. The Commissioning Firm team member with the required experience related to the building

envelope may act as the Air Barrier Inspector required by specification section 07 27 10.00 10 BUILDING AIR BARRIER SYSTEM provided that all qualification requirements of that specification section are met. The Commissioning Firm team member with the required experience related to the building envelope may act as the thermographer required by specification section 07 05 23 PRESSURE TESTING AN AIR BARRIER SYSTEM FOR AIR TIGHTNESS provided that all of the qualification requirements of that specification section are met.

- d. Submit the Technical Commissioning Specialist's certification of qualifications including the name of the specialist and firm; certifications; years of experience; and a listing of representative projects of similar size and complexity no later than 60 calendar days after Notice to Proceed. Submit four hard copies and an electronic copy.

1.7.3 Commissioning Standard

Comply with the requirements of the commissioning standard under which the Commissioning Firm and Specialists qualifications are approved. When the firm and specialists are certified by BCA, AEE, ASHRAE, or the University of Wisconsin-Madison, comply with the requirements of one of the acceptable standards unless otherwise stated herein. The acceptable standards are ACG Commissioning Guideline, NEBB Commissioning Standard, SMACNA 1429, or ASHRAE 202. Comply with applicable NETA and NICET testing standards for electrical systems.

- a. Implement all recommendations and suggested practices contained in the Commissioning Standard and electrical test standards.
- b. Use the Commissioning Standard for all aspects of Commissioning, including calibration of instruments.
- c. Where the instrument manufacturer calibration recommendations are more stringent than those listed in the Commissioning Standard, adhere to the manufacturer calibration recommendations.
- d. All quality assurance provisions of the Commissioning Standard such as performance guarantees are part of this contract.
- e. The Commissioning Specialists must develop commissioning procedures for any systems or system components not covered in the Commissioning Standard.
- f. Use any new requirements, recommendations, and procedures published or adopted prior to contract solicitation by the body responsible for the Commissioning Standard.

[1.8 SUSTAINABILITY THIRD PARTY CERTIFICATION (TPC)

The Commissioning Specialists must execute and document the commissioning activities required of the Commissioning Authority for the purposes of complying with the Third Party Certification (TPC) requirements for the project in accordance with Section 01 33 29 SUSTAINABILITY REPORTING. Provide all commissioning documentation required to meet the TPC requirements.

11.9 ISSUES LOG

The Lead Commissioning Specialist must develop and maintain an Issues Log for tracking and resolution of all deficiencies discovered through commissioning review, inspection, and testing. Include the date of final resolution of issues as confirmed by the Commissioning Specialist. Submit the Issues Log on a monthly basis at a minimum. At any point during construction, any commissioning team member finding deficiencies may communicate those deficiencies in writing to the Commissioning Specialist for inclusion into the Issues Log.

Track construction deficiencies identified in the Issues Log using QCS as specified in Specification Section 01 45 00.15 10 RESIDENT MANAGEMENT SYSTEM CONTRACTOR MODE(RMS CM).

1.10 CERTIFICATE OF READINESS

Prior to scheduling Functional Performance Tests for each system, issue a Certificate of Readiness for the system certifying that the system is ready for Functional Performance Testing. The Certificate of Readiness must include, for each system to be commissioned, all equipment and system start-up reports; Performance Verification Test Reports; completed Building Envelope Inspection Checklists; completed Pre-Functional Checklists; Testing, Adjusting, and Balancing (TAB) Report; HVAC Controls Start-Up Reports; and the Air Leakage Test Reports and Diagnostic Test Reports to the extent applicable to the system. The Contractor; the Lead Commissioning Specialist; the Contractor's Quality Control Representative; the Mechanical, Electrical, Controls, and TAB subcontractor representatives must sign and date the Certificate of Readiness. Submit the Certificate of Readiness for each system no later than 14 calendar days prior to Functional Performance Tests of that system. Submit four hard copies and an electronic copy. Do not schedule Functional Performance Tests for a system until the Certificate of Readiness for that system receives approval by the Government.

PART 2 PRODUCTS

Not used

PART 3 EXECUTION

3.1 CONSTRUCTION PHASE

3.1.1 Construction Commissioning Coordination Meeting

The Lead Commissioning Specialist must lead a Construction Commissioning Coordination Meeting no later than 14 days after approval of the Commissioning Firm and Commissioning Specialists to discuss the commissioning process including contract requirements, lines of communication, roles and responsibilities, schedules, documentation requirements, inspection and test procedures, and logistics as specified in this specification section. The Contractor's Superintendent or Project Manager, the Contractor's Quality Control Representative, and the Government must attend this meeting. Invite the User and a Directorate of Public Works Representative, Reserve Support Command Representative, or a Base Civil Engineer Office Representative to attend this meeting.

3.1.2 Construction Phase Commissioning Plan

3.1.2.1 Interim Construction Phase Commissioning Plan

The Lead Commissioning Specialist (CxC) must prepare the Interim Construction Phase Commissioning Plan. Submit the Interim Construction Phase Commissioning Plan no later than 30 calendar days after the Construction Commissioning Coordination Meeting and no later than 14 days prior to the start of construction of the building envelope. Submit four hard copies and an electronic copy.

Identify the commissioning and testing standards and outline the overall commissioning process, the commissioning schedule, the commissioning team members and responsibilities, lines of communication, documentation requirements for the construction phase of the project, and Template Building Envelope Inspection Checklists in the Interim Construction Phase Commissioning Plan. A Template Construction Phase Commissioning Plan is attached to this specification and is available in word format upon request. Please note that the Template Construction Phase Commissioning Plan is provided as a supplement and contains additional detailed requirements not specifically addressed within this specification section. The CxC is required to develop a commissioning plan that is comprehensive in scope and conforms to the requirements of the contract documents.

3.1.2.1.1 Checklists

Download example Building Envelope Inspection Checklists, Pre-Functional Checklists, Functional Performance Test Checklists, and Integrated Systems Test Checklists for specification section 01 91 00.15 TOTAL BUILDING COMMISSIONING at the following location:

<http://www.wbdg.org/ffc/dod/unified-facilities-guide-specifications-ufgs/forms-graphic>

The checklists submitted in the Interim and Final Construction Phase Commissioning Plans must contain the same level of detail shown in the examples. The submitted checklists are not required to match the format of the examples.

3.1.2.1.2 Contents

In addition to the requirements listed above and those included in the Template Commissioning Plan, include the following in the Interim Construction Phase Commissioning Plan:

- a. Plan purpose
- b. Commissioning scope
- c. Systems to be commissioned
- d. Examples and description of development of pre-functional, integrated systems test, and functional performance test checklists
- e. Building information
- f. Contact information for the Commissioning Specialists, the Contracting Officer's Technical Representative, and the Commissioning Team listed in paragraph Commissioning Team
- g. Roles and responsibilities

- h. Management plan
- i. Owner's Project Requirements
- j. Description of design reviews by the Commissioning Specialists
- k. Description and templates for site observation reports and the issues log
- l. Listing and description of required meetings
- m. Identification and sequence of commissioning and acceptance tasks for incorporation into the Project Schedule
- n. Listing of required submittals to Government and Commissioning Specialists
- o. Description of execution of building envelope inspection, pre-functional checks, integrated systems tests, and functional performance tests
- p. Description of Endurance Tests
- q. Acceptance testing of critical systems as identified in contract documents
- r. Operation and maintenance manual requirements
- s. Description of training requirements
- t. Description of required Systems Manual
- u. Description of the Commissioning Report

3.1.2.1.3 Template Building Envelope Inspection Checklists

The Building Envelope Technical Commissioning Specialist must develop the Template Building Envelope Inspection Checklists. Include items that verify the building materials and construction maintain the required thermal and moisture integrity and air tightness of the building envelope system in the Building Envelope Inspection Checklists.

3.1.2.2 Final Construction Phase Commissioning Plan

The Lead Commissioning Specialist (CxC) must prepare the Final Construction Phase Commissioning Plan. Submit the Final Construction Phase Commissioning Plan no later than 30 calendar days prior to the start of Pre-Functional Checks. Submit four hard copies and an electronic copy.

Include the information provided in the Interim Construction Phase Commissioning Plan. In addition, the Technical Commissioning Specialist must develop the Pre-Functional Checklists, Integrated Systems Test Checklists, and Functional Performance Test Checklists for each building, for each system required to be commissioned, and for each component for inclusion in the Final Construction Phase Commissioning Plan.

3.1.2.2.1 Pre-Functional Checklists

The Pre-Functional Checklists must include items for physical inspection or testing that demonstrate that installation and start-up of equipment and systems is complete. See paragraph Pre-Functional Checks for more information.

3.1.2.2.2 Functional Performance Test Checklists

Functional Performance Test Checklists must include procedures that explain, step-by-step, the actions and expected results that will demonstrate that the system performs in accordance with the contract. See paragraph Functional Performance and Integrated Systems Tests for more information. Include the following sections and details appropriate to the systems being tested in the Functional Performance Test Checklists:

- a. Notable system features including information about controls to facilitate understanding of system operation
- b. Conclusions and recommendations. Conclusions must clearly indicate if system does or does not perform in accordance with contract requirements. Recommendation must clearly indicate that the system should or should not be accepted by the Government.
- c. Test conditions including date, beginning and ending time, and beginning and ending outdoor air conditions
- d. Attendees
- e. Identification of the equipment involved in the test
- f. Control system feature identification
- g. Point-to-point observations including demonstrating system flow meters and sensors have been calibrated and are correctly displayed on the Operator work station
- h. Actuator operation observations demonstrating actuator responses to commands from the control system
- i. As-found condition of the system operation
- j. List of test items with step numbers along with the corresponding feature or control operation, intended test procedure, expected system response, and pass/fail indication.
- k. Space for comments for each test item.

3.1.2.2.3 Integrated Systems Test Checklists

Integrated Systems Test Checklists must include test procedures that explain, step-by-step, the actions and expected results that will demonstrate that the system performs in accordance with the contract. See paragraph Functional Performance and Integrated Systems Tests for more information. Include the following sections in the Integrated Systems Test Checklists:

- a. Notable features of the interconnected systems organized by discipline including information to facilitate understanding of system operation

- b. Conclusions and recommendations. Conclusions must clearly indicate if the systems do or do not perform in accordance with contract requirements. Recommendation must clearly indicate that the systems should or should not be accepted by the Government
- c. Test conditions including date and beginning and ending time
- d. Attendees
- e. Identification of the equipment and systems involved in the test
- f. List of test items with step numbers along with the corresponding feature or control operation, intended test procedure, expected system response, and pass/fail indication.
- g. Space for comments for each test item.

3.1.3 Design Review

The Lead Commissioning Specialist and Technical Commissioning Specialists must review the construction contract plans and specifications.

- a. Advise the Contracting Officer's Representative of any deficiencies that would prevent the building systems and features from operating or performing effectively and from being adequately maintainable.
- b. The Commissioning Specialists must provide a Design Review Report individually listing each deficiency and the corresponding proposed corrective action necessary for proper system operation or performance. Submit four hard copies and an electronic copy of the report to the Contracting Officer's Representative no later than 30 days after approval of the Commissioning Specialists.
- c. The Lead Commissioning Specialist must participate in a meeting to discuss any items contained in the report no later than 14 calendar days after submission of the report.

3.1.4 Construction Submittals

Provide all submittals associated with the systems to be commissioned, including shop drawings; equipment submittals; test plans, procedures, and reports; and resubmittal's to the Commissioning Specialists. The Technical Commissioning Specialist must review the submittals to the extent necessary to verify that the equipment and system installation will comply with the contract requirements.

3.1.5 Inspection and Testing

Demonstrate that all system components have been installed, that each control device and item of equipment operates, and that the systems operate and perform, including interactive operation between systems, in accordance with contract documents and the Owner's Project Requirements. Requirements in related specification sections are independent from the requirements of this section and do not satisfy any of the requirements specified in this specification section. Provide all materials, services, and labor required to perform the Pre-Functional Checks, Building Envelope Inspection, Integrated Systems Tests, and Functional Performance Tests.

3.1.5.1 Commissioning Team

Provide a commissioning representative for each sub-contractor associated with the systems to be commissioned. Each commissioning representative is responsible for coordination of their respective sub-contractor's execution of the commissioning activities and participation in the inspection and testing required by this specification section. The designers listed below are the designers of record for their respective systems. Substitutes must be approved by the Contracting Officer's Representative. The General or Prime Contractor shall provide a detailed schedule of all Functional Performance and Integrated System Testing activities to be accomplished at least 14 calendar days prior to the start date of testing.

3.1.5.1.1 Building Envelope Inspections Team

The following team members must participate in building envelope inspections:

Designation	Function
CxB	Building Envelope Technical Commissioning Specialist
QAR	Contracting Officer's Quality Assurance Representative
CQC	Contractor's Quality Control Personnel
BEC	Contractor's Building Envelope Commissioning Representative
[AD]	[Architectural Designer]

3.1.5.1.2 Mechanical System Pre-Functional Checks Team

The following team members must participate in Pre-Functional checks of mechanical systems:

Designation	Function
CxM	Mechanical System Technical Commissioning Specialist
QAR	Contracting Officer's Quality Assurance Representative
CQC	Contractor's Quality Control Personnel
MC	Contractor's Mechanical Commissioning Representative
EC	Contractor's Electrical Commissioning Representative
CC	Contractor's Controls Commissioning Representative
TABC	Contractor's TAB Commissioning Representative
PC	Contractor's Plumbing Commissioning Representative

Designation	Function
IC	Contractor's Irrigation Commissioning Representative

3.1.5.1.3 Electrical System Pre-Functional Checks Team

The following team members must participate in Pre-Functional checks of electrical systems:

Designation	Function
CxE	Electrical System Technical Commissioning Specialist
QAR	Contracting Officer's Quality Assurance Representative
CQC	Contractor's Quality Control Personnel
EC	Contractor's Electrical Commissioning Representative

3.1.5.1.4 Mechanical Systems Test Team

The following team members must participate in Functional Performance, Seasonal, and Integrated Systems Testing of mechanical systems:

Designation	Function
CxM	Mechanical System Technical Commissioning Specialist
QAR	Contracting Officer's Quality Assurance Representative
CQC	Contractor's Quality Control Personnel
MC	Contractor's Mechanical Commissioning Representative
EC	Contractor's Electrical Commissioning Representative
CC	Contractor's Controls Commissioning Representative
TABC	Contractor's TAB Commissioning Representative
PC	Contractor's Plumbing Commissioning Representative
IC	Contractor's Irrigation Commissioning Representative
[MD]	[Mechanical Designer]
[PD]	[Plumbing Designer]

3.1.5.1.5 Electrical Systems Test Team

The following team members must participate in Functional Performance and Integrated Systems Testing of electrical systems:

Designation	Function
CxE	Electrical System Technical Commissioning Specialist
QAR	Contracting Officer's Quality Assurance Representative
CQC	Contractor's Quality Control Personnel
EC	Contractor's Electrical Commissioning Representative
[ED]	[Electrical Designer]

3.1.5.1.6 Other Pre-Functional and Functional Performance Participants

The following may participate as team members during Pre-Functional Checks and Functional Performance Testing:

Designation	Function
[DPW]	[Directorate of Public Works Representative]
[BCE]	[Base Civil Engineer Office Representative]
[RSC]	[Reserve Support Command Representative]
[PWD]	[Public Works Division Representative]
User	Using Agent's Representative

3.1.5.2 Building Envelope Inspection

Document building envelope inspection by the commissioning team using the approved Template Building Envelope Inspection Checklists. Indicate commissioning team member inspection and acceptance of each Building Envelope Inspection Checklist item by initials at the time they are inspected and found to be in conformance with contract requirements. Inspect checklist items before they become hidden as construction progresses.

- a. Submit the completed and initialed Building Envelope Inspection Checklists no later than 7 calendar days after completion of inspection of all checklists items. Submit four hard copies and an electronic copy.
- b. The Building Envelope Technical Commissioning Specialist must make at least two site visits to the site to observe construction of the building envelope in-progress. On each visit, the Building Envelope Commissioning Specialist must review the Contractor's in-progress checklists to ensure that the commissioning team is inspecting the

building envelope as required.

- c. The Building Envelope Technical Commissioning Specialist must witness the building envelope pressure tests and diagnostic tests specified in Specification Section 07 05 23 PRESSURE TESTING AN AIR BARRIER SYSTEM FOR AIR TIGHTNESS. The Building Envelope Technical Commissioning Specialist must review the resulting reports and provide recommendations for correction of any deficiencies or further testing.

3.1.5.3 Pre-Functional Checks

Pre-Functional Checklists from the approved Final Construction Phase Commissioning Plan must be completed by the commissioning team. Complete one Pre-Functional Checklist for each individual item of equipment or for each system required to be commissioned including, but not limited to, ductwork, piping, equipment, fixtures (lighting and plumbing), and controls. Indicate commissioning team member inspection and acceptance of each Pre-Functional Checklist item by initials. Acceptance of each Pre-Functional Checklist item by each team member indicates that item conforms to the construction contract requirements in their area of responsibility. Technical Commissioning Specialist acceptance of each Pre-Functional Checklist item indicates that each item has been installed correctly and in accordance with contract documents and the Owner's Project Requirements. Submit the completed and initialed Pre-Functional Checklists no later than 7 calendar days after completion of inspection of all checklists items for each system. Submit four hard copies and an electronic copy. Include manufacturer start-up checklists associated with equipment with the submission of the Pre-Functional Checklists.

3.1.5.4 Testing, Adjusting, and Balancing (TAB) Report and Field Acceptance Testing

The Mechanical System Technical Commissioning Specialist must review the pre-final TAB Report required by Specification Section 23 05 93 TESTING, ADJUSTING, AND BALANCING FOR HVAC. Identify any deficiencies to the Contracting Officer's Representative and the Contractor's Quality Control Personnel. Resolve all deficiencies prior to TAB Field Acceptance Testing.

The Mechanical System Technical Commissioning Specialist must witness the TAB Field Acceptance Testing specified by Section 23 05 93 TESTING, ADJUSTING, AND BALANCING FOR HVAC. Include a certification by the Mechanical Technical Specialist that no outstanding deficiencies exist in the systems relative to Testing, Adjusting, and Balancing with the final TAB Report submittal.

3.1.5.5 HVAC Controls Test Reports

The Mechanical System Technical Commissioning Specialist must review the Performance Verification Testing Plan, Checklists, and Report. Include a certification by the Mechanical System Technical Commissioning Specialist that the submittals contain no deficiencies or that the submittals do not indicate any deficiencies in the HVAC systems or HVAC control systems with each of these submittals.

3.1.5.6 Tests

3.1.5.6.1 Functional Performance and Integrated Systems Tests

Schedule Functional Performance Tests for each system only after the Certificate of Readiness has been approved by the Government for the system. Correct all deficiencies identified through any prior review, inspection, or test activity before the start of Functional Performance Tests. Perform Integrated Systems Tests only after the Functional Performance Tests for each associated system are completed with all deficiencies resolved and after the related Functional Performance Test Checklists have been signed by each commissioning team member.

- a. Functional Performance Tests and Integrated Systems Tests must be performed with the Contracting Officer's Quality Assurance Representative present.
- b. Abort Functional Performance Tests or Integrated Systems Tests when any system deficiency prevents the successful completion of the test.
- c. Technical Commissioning Specialists must lead and document all Functional Performance Tests and Integrated Systems Tests for the systems to be commissioned with the Contractor and appropriate sub-contractors performing the Functional Performance Tests and Integrated Systems Tests. The representatives listed in the paragraph Commissioning Team must attend the tests. Abort Functional Performance Tests or Integrated Systems Tests when any required commissioning team member is not present for the test.

3.1.5.6.1.1 Checklist

Use the Functional Performance Test and Integrated Systems Test Checklists from the approved Final Construction Phase Commissioning Plan to guide the Functional Performance Tests and Integrated Systems Tests. Functional Performance Tests must be performed for each item of equipment and each system required to be commissioned and verify all sensor calibrations, control responses, safeties, interlocks, operating modes, sequences of operation, capacities, lighting levels, and all other performance requirements comply with construction contract regardless of the specific items listed within the Functional Performance Test and Integrated Systems Test Checklists provided. Testing must progress from equipment or components to subsystems to systems to interlocks and connections between systems. Integrated Systems Tests must be performed for the interactive operation between systems such as HVAC systems, fire protection systems, back-up electrical supply, energy generation systems, and other systems, and verify correct interactive operation, acceptable speed of response, and other contract requirements for both normal and failure modes. Examples of Integrated Systems Tests include the correct operation of HVAC systems during emergency system activation, correct operation of uninterruptible power supplies or energy generators and connected systems, or lighting system operation during power outage or emergency system activation. The order of components and systems to be tested must be determined by the Technical Commissioning Specialists.

3.1.5.6.1.2 Acceptance

Indicate acceptance of each item of equipment and systems tested by signature of each commissioning team member for each Functional Performance Test or Integrated Systems Test Checklist. The Contractor's

Quality Control Representative and the Technical Commissioning Specialists must indicate acceptance after the equipment and systems are free of deficiencies.

3.1.5.6.2 HVAC Test Methods

Perform Functional Performance Tests in accordance with the following:

3.1.5.6.2.1 Prior to Testing

Prior to testing operating modes, sequences of operation, interlocks, and safeties, complete control point-to-point observations, test sensor calibrations, and test actuator commands.

3.1.5.6.2.2 Simulating Conditions

Over-writing control input values through the controls system is not acceptable, unless approved by the Contracting Officer's Representative . Identify proposed exceptions in a protocol submitted to the Contracting Officer's Representative for approval. Before simulating conditions, overwriting values (if approved), or changing set-points, calibrate all sensors, transducers and devices. Below are several examples of exceptions that would be considered acceptable:

- a. When varying static pressures inside ductwork can not be simulated within the duct, and where a sensor signals the controls system to initiate sequences at various duct static pressures, it is acceptable to simulate the various pressures with a Pneumatic Squeeze-Bulb Type Signaling Device with gauge temporarily attached to the sensing tube leading to the transmitter. It is not acceptable to reset the various set-points, nor to simulate an electric analog signal (unless approved as noted above).
- b. Dirty filter pressure drops can be simulated using sheets of cardboard at filter face.
- c. Freeze-stat safeties can be simulated by packing portion of sensor with ice.
- d. High outside air temperatures can be simulated with a hair blower.
- e. High entering cooling coil temperatures can be used to simulate entering cooling coil conditions.
- f. Do not use signal generators to simulate sensor signals unless approved by the Contracting Officer's Representative , as noted above, for special cases.
- g. Control set points can be altered. For example, to see the air conditioning compressor lockout work at an outside air temperature below 13 degrees C, when the outside air temperature is above 13 degrees C, temporarily change the lockout set point to be minus 18 degrees C above the current outside air temperature. Caution: Set points are not to be raised or lowered to a point such that damage to the components, systems, or the building structure and/or contents will occur.
- h. Test duct mounted smoke detectors in accordance with the manufacturer's recommendations. Perform the tests with air system at

minimum airflow condition in ductwork.

- i. Test current sensing relays used for fan and pump status signals to control system to indicate unit failure and run status by resetting the set point on the relay to simulate a lost belt or unit failure while the unit is running. Confirm that the failure alarm was generated and received at the control system. After the test is conducted, return the set point to its original set-point or a set-point as indicated by the Contracting Officer's Representative .

3.1.5.6.2.3 Setup

Perform each test under conditions that simulate actual conditions as close as is practically possible. Provide all necessary materials and system modifications to produce the necessary flows, pressures, temperatures, and other conditions necessary to execute the test according to the specified conditions. At completion of the test, return the affected building equipment and systems to their pre-test condition.

3.1.5.6.3 Sample Strategy

Perform Functional Performance Tests and Integrated System Tests for all equipment and systems. Prepare and complete a Functional Performance Test checklist for each piece of equipment or system. Prepare and complete an Integrated Systems Test Checklist for all systems and equipment having interactive operation. Test 100 percent of all HVAC Central Plant equipment and primary air handling units. [Test [100] percent of renewable energy systems/equipment]. Sample testing of 10 units or [twenty] percent, whichever is greater, is allowed for HVAC equipment with identical controllers such as air terminal units and fan coil units. [Sample testing of [twenty] percent is allowed for other equipment and systems.]

3.1.5.6.4 Seasonal Tests

3.1.5.6.4.1 Initial Functional Performance Tests

Perform Initial Functional Performance Tests as soon as all contract work is completed, regardless of the season. Develop and implement means of artificial loading to demonstrate, to a reasonable level of confidence, the ability of the HVAC systems to handle peak seasonal loads.

3.1.5.6.4.2 Full-Load Conditions

In addition to the Initial Functional Performance Tests, perform Functional Performance Tests of HVAC systems under full-load conditions during peak heating and cooling seasons during outdoor air condition design extremes. Test cooling equipment and systems with the building fully occupied when performing the Functional Performance Tests during peak cooling season.

Schedule Seasonal Functional Performance Tests in coordination with the Government.

3.1.5.6.4.3 System Acceptance

Systems may be partially accepted prior to seasonal testing if they comply with all construction contract that can be tested during initial Functional Performance Tests. All Functional Performance Test procedures must be completed prior to full systems acceptance.

3.1.5.6.5 Aborted Tests and Re-Testing

Abort Functional Performance Tests, Integrated Systems Tests, or Seasonal Tests if any deficiency prevents successful completion of the test or if any required commissioning team member is not present for the test. reimburse the Government for all costs associated with effort lost due to re-testing due to test failures and aborted tests. These costs must include salary, travel costs, and per diem for Government commissioning team members. Re-test only after all deficiencies identified during the original tests have been corrected.

3.1.5.6.5.1 100 Percent Sample

Systems or equipment for which 100 percent sample size are tested fail if one or more of the test procedures results in discovery of a deficiency and the deficiency cannot be resolved within 5 minutes during the test.

Re-test to the extent necessary to confirm that the deficiencies have been corrected without negatively impacting the performance of the rest of the system.

3.1.5.6.5.2 Less than 100 Percent Sample

For systems tests with a sample size less than 100 percent, if one or more of the test procedures for an item of equipment or a system results in discovery of a deficiency, regardless of whether the deficiency is corrected during the sample tests, the item of equipment or system fails the test.

- a. If the system failure rate is 5 percent or less, meaning that 5 percent or less of the equipment or systems tested had at least one deficiency, re-test only on the items which experienced the initial failures.
- b. If the system failure rate is greater than 5 percent, meaning that more than 5 percent of equipment or systems tested had at least one deficiency, re-test the items which experienced the initial failures to the extent necessary to confirm that the deficiencies have been corrected . In addition, test another random sample of the same size as the initial sample for the first time. If the second random sample set has any failures, re-test those failed items and all remaining equipment and systems to complete 100 percent testing of that system type.

3.1.6 Training Plan

Develop a training plan which identifies all training required by specification sections associated with commissioned systems. Include a matrix listing each training requirement, content of the training, the trainer name, trainer contact information, and schedule and location of training. Submit four hard copies and an electronic copy of the Training Plan to the Commissioning Specialists and the Government no later than 30 calendar days prior to the associated training.

Document training attendance using training attendance rosters and provide completed attendance rosters to the Commissioning Specialists and the Government no later than 7 calendar days following the completion of training for each system to be commissioned. Submit four hard copies and

an electronic copy..

3.1.7 Systems Manual

Prepare and submit a Systems Manual including, for all commissioned systems, the Owner's Project Requirements, system single line diagrams, as-built sequences of operation and controls drawings, as-built control setpoints, recommended schedule for sensor and actuator calibration, recommended schedule of maintenance when not in the O&M manuals, recommended re-testing schedule with proposed testing forms, and full equipment warranty information. Update and resubmit the Systems Manual based on any corrective action taken during the warranty period. Include a signed certification or letter from the Lead Commissioning Specialist with the submittal stating that the Systems Manual is complete, clear, and accurate.

Submit Systems Manual no later than 30 calendar days following completion of Functional Performance Tests. Submit four hard copies and an electronic copy.

3.1.8 Maintenance and Service Life Plans

3.1.8.1 Maintenance Plan

Prepare and submit a Maintenance Plan for the project mechanical, electrical, plumbing, and fire protection systems. Prepare the HVAC and refrigeration sections of the Maintenance Plan in accordance with ASHRAE 180. Develop required inspection and maintenance tasks similar to Section 5 of ASHRAE 180 for the other commissioned systems and fire protection systems.

Submit the Maintenance Plan no later than 30 calendar days following the completion of Functional Performance tests. Submit four hard copies and an electronic copy.

3.1.8.2 Service Life Plan

Prepare and submit a Service Life Plan for the building envelope, structural systems, and site hardscape that includes the following for each assembly or component:

- a. A description of each including the materials or products.
- b. The estimated service life, in years.
- c. The estimated maintenance frequency and description of maintenance tasks.
- d. The point of maintenance access for the components with estimated service life less than service life of the building.

Submit the Service Life Plan no later than 30 calendar days following the completion of Functional Performance tests. Submit four hard copies and an electronic copy.

3.2 COMMISSIONING REPORT

Following the completion of Functional Performance Tests and Integrated Systems Tests, with the exception of Seasonal Tests, the Lead

Commissioning Specialist must prepare a Commissioning Report.

- a. Include an executive summary describing the overall commissioning process, the results of the commissioning process, any outstanding deficiencies and recommended resolutions, and any seasonal testing that must be scheduled for a later date. Indicate, in the executive summary, whether the systems meet the requirements of the construction contract and the Owner's Project Requirements.
- b. Detail any deficiencies discovered during the commissioning process and the corrective actions taken in the report. Include the completed Building Envelope Inspection Checklists, Pre-Functional Checklists, Functional Performance Test Checklists, Integrated Systems Test Checklists, the Commissioning Plans, the Issues Log, control sequences, meeting minutes, progress and site visit reports, Performance Verification Test Reports, Training Attendance Rosters, the Design Review Report, the final TAB Report.
- c. Submit the Commissioning Report no later than 14 calendar days following commissioning team acceptance of all Functional Performance Tests and Integrated Systems Tests with the exception of Seasonal Tests. Submit four hard copies and an electronic copy.
- d. Following any Seasonal Tests or Post-Construction Activities, update the Final Commissioning Report to reflect any changes and resubmit.

3.3 POST-CONSTRUCTION SUPPORT

3.3.1 Post-Construction Endurance Test

Perform a one-week Endurance Test once during the peak heating season and once during the peak cooling season during outdoor air condition extremes using the building control system to trend all points necessary to evaluate the installed equipment and system performance or as shown as requiring a trend on the project schedules. If insufficient buffer capacity exists to trend the entire endurance test, upload trend logs during the course of the endurance test to ensure that no trend data is lost. Poll all points shown in the project schedules with an alarm condition at 5 minute intervals. Poll all points shown in the project schedules required for trending, overrides, or graphical displays at 15 minute intervals.

The Mechanical System Commissioning Specialists must review the trend logs from the Endurance Tests to ensure that the systems have stable operation and operate as required by the construction contract and the Owner's Project Requirements. The Commissioning Specialists must provide a Post-Construction Trend Log Report that identifies any deficiencies noted in operation and includes a graphical representation of the trends. Provide one Trend Log Report for the peak cooling season and one Trend Log Report for the peak heating season. Submit four hard copies and one electronic copy of the Post-Construction Trend Log Reports no later than 14 calendar days following receipt of the trend log data by the Commissioning Specialist.

3.3.2 Post-Construction Site Visit

The Commissioning Specialists must visit the building site concurrent with the 9 month warranty inspection to inspect building system equipment and review building operation with the building operating/maintenance staff.

The Commissioning Specialists must identify any deficiency of the building systems to operate in accordance with the contract requirements and the Owner's Project Requirements. The Commissioning Specialists must advise the Contracting Officer's Representative of any identified deficiencies and the proposed corrective action. Submit an updated commissioning report and systems manual documenting the results of the post-construction inspection.

-- End of Section --