




Doc name	Comment	Visual, if any
GE01-CAS-0003-FL6-L1-C01	<p>Do we design concrete walls for security office? If yes, I would suggest considering glass walls to enable security team to have native visual access to the DC. I would also suggest to move security office next to the DC entrance.</p>	
GE01-CAS-0003-FL6-L1-C01	<p>We assume that there will be visitors/guest to our DC. I recommend to consider locker for personal belongings. That is one of the security requirements. I have highlighted area as potential space for locker</p>	
GE01-CAS-0003-FL6-L1-C01	<p>I recommend to have our space in DC. We can keep mission critical tools. E.g. We understand that we have redundant cooling system, but I would recommend to have also mobile fan for the disaster case and decreasing temperature in room (-s) with mission customer IT hardware</p>	
GE01-CAS-0003-FL6-L1-C01	<p>If we consider fire suppression system, e.g. FM-200, I recommend having separated cabinet for to keep balloons</p>	
GE01-CAS-0003-FL6-L1-C01	<p>I don't see CCTV points on the map. Is there any risk if we submit doc for UI Tier III design and then decide on CCTV design?</p>	
GE01-CAS-0003-FL7-L2-C01	<p>I would suggest putting Lego wall if space needs to be increase for more guests, e.g. company townhalls.</p>	

GE01-CAS-0003-
FL7-L2-C01

I would suggest to design internal walls made of glass with active film for blurring purposes.

