

EECC 2015

Indoor Air Pollution Data

Part 1:HVAC Parameters

Outdoor Parameter

| Parameter | Summer | Winter |
|---------------------------|--------|--------|
| Air Pressure (mbar) | 998.5 | 1020.2 |
| Dry-bulb Temperature (°C) | 34.8 | -10 |
| Wet-bulb Temperature (°C) | 26.7 | --- |
| Relative Humidity (%) | 73 | 54 |
| Air Temperature (°C) | 31 | -2 |
| Wind Velocity (m/s) | 2.8 | 3.2 |
| Wind Direction | C SSW | C SSW |

Indoor Parameter

| Location | Dry-bulb Temperature (°C) | | Relative Humidity (%) | |
|------------------------|---------------------------|--------|-----------------------|--------|
| | Summer | Winter | Summer | Winter |
| Manufacturing Facility | 27 | 18 | <65 | >30 |
| Lobby | 27 | 16 | 50~65 | >30 |

Air Conditioner Capacity

| | |
|------------------|--------|
| Cooling Capacity | 1614kW |
| Cooling Target | 81W/m |
| Heating Capacity | 1405kW |
| Heating Target | 71W/m |


Heating and Cooling Source

| | | |
|----------------------------|-------------|-------------|
| Ground source heating pump | SGHP800 | SGHP1000 |
| Heating/cooling capacity | 754kW/817kW | 937W/1040kW |

Heat Transfer Parameter

Outer wall heat transfer coefficient: 0.39 W/ (m°C)
 Outer window heat transfer coefficient: 2.6 W/ (m°C)
 Inner wall heat transfer coefficient: 0.56 W/(m°C)

Sketch map of HVAC



Part 2: Heat Pump Data

Overview of heat dump conditions 2013-2014

| | 11/1/13 | 12/1/13 | 1/1/14 | 2/1/14 | 6/2/14 | 7/2/14 | 8/2/14 | 9/2/14 |
|-----------------|---------|---------|--------|--------|--------|--------|--------|--------|
| Main Motor load | 20200 | 38420 | 34820 | 34940 | 21420 | 35140 | 30040 | 7400 |
| Water pump load | 9948 | 15624 | 16848 | 16632 | 11112 | 20094 | 17712 | 5532 |
| Heat pump load | 87500 | 173720 | 163900 | 165510 | 112570 | 119855 | 116780 | 10600 |
| Total load | 30148 | 54044 | 51668 | 51572 | 32532 | 55234 | 47752 | 12932 |

Heat pump and power usage condtions

| | 11/1/13 | 12/1/13 | 1/1/14 | 2/1/14 | 6/2/14 | 7/2/14 | 8/2/14 | 9/2/14 |
|---|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|-----------------|
| Main motor load | 20200 | 38420 | 34820 | 34940 | 21420 | 35140 | 30040 | 7400 |
| Water pump load | 9948 | 15624 | 16848 | 16632 | 11112 | 20094 | 17712 | 5532 |
| Heat pump load | 87500 | 173720 | 163900 | 165510 | 112570 | 119855 | 116780 | 24900 |
| System total load | 30148 | 54044 | 51668 | 51572 | 32532 | 55234 | 47752 | 12932 |
| Ground source heating/cooling load | 55010 | 98400 | 87910 | 90180 | 170560 | 151270 | 182660 | 43190 |
| System coefficient of performance (COP) | 2.9023 48414 | 3.2144 17882 | 3.1721 76202 | 3.2092 9962 | 3.4602 85258 | 2.1699 49669 | 2.4455 52019 | 1.9254 56233 |
| Device COP | 4.3316 83168 | 4.5216 03332 | 4.7070 64905 | 4.7369 77676 | 5.2553 68814 | 3.4107 8543 | 3.8874 83356 | 3.3648 64865 |

Part 3: Cost Benefit Analysis Data

Price of electricity has three phases:

- Top Power
 - Time Range: 10:30-11:30; 19:00-21:00
 - Price Calculation formula: ¥ 0.8024*1.7/kW.h
- Peak Power
 - Time Range: 8:30-10:30; 18:00-19:00
 - Price Calculation formula: ¥ 0.8024*1.6/kW.h
- Valley Power
 - Time Range: 23:00-7:00
 - Price Calculation formula: ¥ 0.8024*0.4/kW.h

Average price for all the other time: ¥ 0.8024/kW.h