

Test Switch SOFT Fault Flash Codes:

#	Problem
1	Zone Input 1 SHORTED
2	Zone Input 1 SHORTED
3	Zone Input 1 SHORTED
4	PSI Gauge Input OPEN
5	Valve 1 OPEN/SHORTED
6	Valve 2 OPEN/SHORTED
7	Valve 3 OPEN/SHORTED
8	UNDEFINED

Power Switch HARD Fault Flash Codes:

#	Problem
1	i2c Hard Fault (0x70)
2	i2c Hard Fault (0x71)
3	i2c Hard Fault (0x72)
4	12v Power Supply Fault
5	24v Power Supply Fault
6	24v High Current Condition
7	UNDEFINED
8	UNDEFINED

Power Switch ALARM Flash Codes:

#	Problem
1	Zone 1 ALARM
2	Zone 2 ALARM
3	Zone 3 ALARM
4	PSI Gauge ALARM
5	MANUAL ALARM
6	UNDEFINED
7	UNDEFINED
8	UNDEFINED

NON DISCLOSURE AGREEMENT

THIS DRAWING AND THE DESIGN IT DISCLOSES ARE THE PRIVATE PROPERTY OF ALERT WARNING SYSTEMS AND IS ISSUED IN CONFIDENCE FOR ENGINEERING INFORMATION ONLY. THE DRAWING AND / OR DESIGN MAY NOT BE USED, COPIED, REPRODUCED, OR OTHERWISE DISCLOSED IN PART OR AS A WHOLE TO OUTSIDERS OR USED FOR ANY OTHER PURPOSE WITHOUT THE PRIOR WRITTEN CONSENT OF ALERT WARNING SYSTEMS. THE DRAWING IS SUBJECT TO RECALL AT ANY TIME. YOUR POSSESSION OF THIS DOCUMENT CONSTITUTES ACCEPTANCE OF THESE TERMS.

© 2022 ALERT WARNING SYSTEMS

HARDWARE VERSION
3.2d PRE-PRODUCTION

SOFTWARE VERSION
2.10 BETA

DRAWN BY
BAF

DESCRIPTION
FAULT CODES

AVWS ACU BASELINE CODE FLOWCHART

Alert Warning Systems, Inc
10758 Trenton Ave, St. Louis, Missouri 63132 (314) 635-6500

DATE
05/22/2022

PAGE
1 of 1