

CONCRETE PLACEMENT REPORT

GENERAL INFORMATION

ENGLOBE PROJECT NO.: 02102531.172.0100.0101 CLIENT CONTRACT NO.: _____

PROJECT NAME: NSPW - 2022-133 Hwy 103 Ingramport to Hubbards Twinning - CIP

CLIENT: NSPW CLIENT P.O.: _____

ADDRESS: _____ CONTRACTOR: BD Clifton(Dexter)

1672 Granville St, 3rd Floor ARRIVAL TIME: 02:00 PM (-4 GMT)

PO Box 186 Halifax, NS B3J 3Z8 DEPARTURE TIME: 03:30 PM (-4 GMT)

ATTENTION: Isaac Bou-Karam

PHONE: (902) 229-1109 CELL: _____ EMAIL: isaac.bou-karam@novasctoia.ca

MIX NO: 35DOT FORMWORK: Trench walls DATE PLACED: 2023-12-19

SUPPLIER: South Shore Ready Mix (Chester) FORMWORK CLEAN: Yes METHOD OF PLACING: Chute

WEATHER: Rain / Overcast VIBRATORS: Pencil METHOD OF CURING: Insulated Tarps

EQUIPMENT NO.: 2

CALIBRATION DATE: 2023/12/12

SPECIFIED PROPERTIES

STRENGTH @ 28 DAYS: 35 MPa SLUMP: 80 +/- 20 mm AIR: 6 +/- 1 %

Load No.	Ticket No.	Truck No.	Time Record				Air (%)	Slump	Temp (°C)		Volume		No. Cylinders Cast	Cure Type
			Batch	Tested	Unload	Elapsed			Conc	Air	Load	Cum		
1	14699	27	13:28	14:35	14:55	1:27	5.8/5.9	65/70	23.5	9.0	4.56	4.56	7	Standard

SECTION: Guard cable tensioner footing

LOCATION: In centre line of road East of the old Mill Lake rd OP.

COMMENTS: There was no quality control on site.

RECORD NO.: m-5968 STANDBY: _____ ENGLOBE TECH: Tristan Pye PER: Peter Salah

For testing conducted by this company, procedures are carried out in accordance with CSA-A23.2. Reporting of these test results constitutes a testing service only. Engineering interpretation or evaluation of test results is provided only on request.

PROJECT MANAGER: Peter Salah

SITE PHOTOS

Dec 19, 2023 3:10:15 p.m.



Dec 19, 2023 3:10:15 p.m.



Dec 19, 2023 3:10:16 p.m.



SAMPLE PHOTOS

Dec 19, 2023 3:11:24 p.m.



10/90 sample of load 1 with a slump of 70mm.


Dec 19, 2023 3:11:25 p.m.



10/90 sample of load 1 with a temperature of 23.5.

TICKET PHOTOS

Dec 19, 2023 3:18:18 p.m.



SOUTH SHORE REALTY INC.
PO BOX 2407, BRIDGEWATER NJ 07005
PHONE: (908) 544-6338
www.southshore-nj.com

Chapter: NS **Licenses: NS**
PI: 902-75-3533
HT: 01/04/04-12/01

WARNING: KEEP PROTECTED

BOOK BURNS MAY RESULT FROM PROLONGED CONTACT WITH WET CONCRETE

PLANT	DATE	TIME	TRUCK NO	DRIVER	NOTES	JOB NUMBER
CHUCKER	THRU	TO	BY	REUSE	BEAR TRUCK ID	
BRUSH CUTTER	CUSTOMER NAME	EXT:55555555			DELIVERY ADDRESS	PIZ NUMBER
<div style="display: flex; justify-content: space-between;"> <div> <p>CLASSIC MTRE</p> <p>4.50</p> <p>QUANTITY</p> <p>4.50 m3</p> </div> <div> <p>DESCRIPTION</p> <p>30 MPB PORT FLTY BRCK AIR</p> <p>DESCRIPTION</p> <p>30 MPB PORT FLTY BRCK AIR</p> <p>WATER HANDLING</p> </div> <div> <p>ASS</p> <p>78.00</p> <p>AC MFT</p> <p>12.00</p> </div> <div> <p>WPH 000</p> <p>AC MFT</p> <p>12.00</p> </div> <div> <p>WPH 000</p> <p>AC MFT</p> <p>12.00</p> </div> <div> <p>WPH 000</p> <p>AC MFT</p> <p>12.00</p> </div> </div>						<p>JOB NUMBER</p> <p>10257</p> <p>AC CODE</p> <p>0001</p> <p>EXTENSION</p> <p>0050.00</p>
<div style="display: flex; justify-content: space-between;"> <div> <p>START DATE</p> <p>01/01/2018</p> </div> <div> <p>END DATE</p> <p>01/01/2018</p> </div> </div>						<p>START TIME</p> <p>08:00</p>

14699

PROJECT LOCATION

