



CSA CERTIFIED
LABORATORY FOR TESTING
CONCRETE

CONCRETE PLACEMENT REPORT

97 TROOP AVE., DARTMOUTH, N.S. B3B 2A7 - TEL (902) 468-6486 FAX 468-4919

Client

Nova Scotia Transportation And Infrastructure Renewal
PO Box 186, 1672 Granville Street
Halifax, Nova Scotia
B3J 2N2

Our Project No.

02000061.000.001

Client Contract No.:

4600019710

Client P.O.:**Contractor:****CC:**

Fax

ATTENTION: Krista Ranahan, P.Eng.

PHONE: (902) 722-1207

FAX:

Email:

krista.ranahan@no

Project: FO1-55-02-01 - JL Ilsley High School Concrete Testing

Supplier: Casey Metro
Weather: Overcast
Specified Properties: Strength, @28 Days : 28 MPa,
Mix No: C27101E
Formwork: Wood
Vibrators: Whip
Date Placed: 07-Jan-20
Method Of Placing: excavator & buc
Method Of Curing: Tarps
Slump: 125 +/- 25 mm
Air: 6 +/- 1 %

Load No.	Ticket No.	Truck No.	Time Record				Air (%)	Slump (mm)	Temp (C)		Volume		#Cyls Cast
			Batch	Tested	Unload	Elapsed			Conc	Air	Load	Cum.	
1	103442	37	15:37	16:10			1.6/3.5/5.7	110/150	N/A	1	4.78	4.78	3
2	103446	39	16:07	17:00			7.0	130	N/A	1	4.72	9.50	2

Section: Partial Electrical Duct Bank

Location: Starting section from Drysdale

Comments

Field Test results reported on site.

Record No: 29439 **Standby:** 0 **Englobe Tech:** BG

PER

For testing conducted by this company, procedures are carried out in accordance with CSA-A23.2. Reporting of these test results constitutes a testing service only. Engineering interpretation or evaluation of test results is provided only on request.

Project manager : Peter Salah