

ENGLOBE



CSA CERTIFIED
LABORATORY FOR TESTING
CONCRETE

CONCRETE PLACEMENT REPORT

97 TROOP AVE., DARTMOUTH, N.S. B3B 2A7 - TEL (902) 468-6486 FAX 468-4919

Client
NOVA SCOTIA DEPARTMENT OF PUBLIC WORKS
1672 Granville St, 3rd Floor
PO Box 186
Halifax, NS B3J 3Z8

Our Project No. 02102531.095.0100.0101
Client Contract No.: F01-113-01-09
Client P.O.: 4600021503
Contractor: Dexter Construction Company Ltd.
CC: Fax

ATTENTION: Jessica McNeil

PHONE: (902) 237-2267 **FAX:** **Email:** jessica.mcneil@no

Project: NSPW - F01-113-01-09 HI Summer Street Entrance

Supplier: Quality Concrete **Mix No:** E352A2B **Date Placed:** 31-Oct-22
Formwork Clean: Yes **Formwork:** Gravel **Method Of Placing:** Chute
Weather: Sunny **Vibrators:** Screed **Method Of Curing:** Exposed
Specified Properties: Strength @ 28 Days : 35 MPa, **Slump:** 100 Max mm **Air:** 5 - 8 %

#	Ticket No.	Truck No.	Time Record				Air (%)	Slump (mm)	Temp (C)		Volume		#Cyls Cast
			Batch	Tested	Unload	Elapsed			Conc	Air	Load	Cum.	
1	1156496	1136	14:26	15:20	15:45	1:19	7.0	85	21	15	4.97	4.97	5

Section: Sidewalk.

Location: Sidewalk in front on the infirmary on the bicycle rack side.

Comments Field Test Results Reported On Site.

Record No: 37648 **Standby:** 0 **Englobe Tech:** Jean-Paul Ghosn

PER

For testing conducted by this company, procedures are carried out in accordance with CSA-A23.2. Reporting of these test results constitutes a testing service only. Engineering interpretation or evaluation of test results is provided only on request.

Project manager : Peter Salah