

CONCRETE PLACEMENT REPORT

GENERAL INFORMATION

ENGLOBE PROJECT NO.: 02102531.099.0100.0101 CLIENT CONTRACT NO.: Chester, NS

PROJECT NAME: NSPW - IWK Emergency Department Redevelopment

CLIENT: NSPW CLIENT P.O.: B0J 1J0

ADDRESS: 1672 Granville St, 3rd Floor CONTRACTOR: Omega

PO Box 186 Halifax, NS B3J 3Z8 ARRIVAL TIME: 10:35 AM (-4 GMT)

DEPARTURE TIME: 12:35 PM (-4 GMT)

ATTENTION: Melanie Scholten

PHONE: (902) 497-1758 CELL: EMAIL: melanie.scholten@novascotia.ca

MIX NO: 35201N20 FORMWORK: Wood DATE PLACED: 2023-12-20

SUPPLIER: OSCO (Sackville) FORMWORK CLEAN: N/A METHOD OF PLACING: Crane/Bucket

METHOD OF CURING: Exposed

WEATHER: Light rain VIBRATORS: Whip EQUIPMENT NO.: 90

CALIBRATION DATE: 2023/12/12

SPECIFIED PROPERTIES

STRENGTH @ 28 DAYS: 35 MPa SLUMP: 80 +/- 30 mm AIR: No AEA %

Load No.	Ticket No.	Truck No.	Time Record				Air (%)	Slump	Temp (°C)		Volume		No. Cylinders Cast	Cure Type
			Batch	Tested	Unload	Elapsed			Conc	Air	Load	Cum		
1	23120231	51810	10:14	11:05	11:05	0:51	1.7	125	18.0	6.0	7.00	7.00	5	Standard
2	24129039	51602	11:16	11:55	11:55	0:39	1.6	150	17.5	6.0	7.00	14.00	0	Standard

SECTION: Walls and Columns.

LOCATION: Gridlines:
Columns: J-K/14
Walls: GL L-P/8+-9

COMMENTS: There was light rain during the pour.

RECORD NO.: m-5971 STANDBY: ENGLOBE TECH: Kambale Tumbura PER: Peter Salah


For testing conducted by this company, procedures are carried out in accordance with CSA-A23.2. Reporting of these test results constitutes a testing service only. Engineering interpretation or evaluation of test results is provided only on request.

PROJECT MANAGER: Peter Salah


SITE PHOTOS

SAMPLE PHOTOS

Dec 20, 2023 11:49:49 a.m.



Dec 20, 2023 11:49:49 a.m.



TICKET PHOTOS



