

# ENGLOBE



CSA CERTIFIED  
LABORATORY FOR TESTING  
CONCRETE

## CONCRETE PLACEMENT REPORT

97 TROOP AVE., DARTMOUTH, N.S. B3B 2A7 - TEL (902) 468-6486 FAX 468-4919

**Client**

NOVA SCOTIA DEPARTMENT OF PUBLIC WORKS  
1672 Granville St, 3rd Floor  
PO Box 186  
Halifax, NS B3J 3Z8

**Our Project No.**

02102531.095.0100.0101

**Client Contract No.:**

F01-113-01-09

**Client P.O.:**

4600021503

**Contractor:**

Dexter Construction Company Ltd.

**CC:**

Fax

**ATTENTION:** Jessica McNeil

**PHONE:** (902) 237-2267

**FAX:**

**Email:**

jessica.mcneil@no

**Project:** NSPW - F01-113-01-09 HI Summer Street Entrance

**Supplier:** Quality Concrete

**Mix No:** E352A2B

**Date Placed:** 01-Nov-22

**Formwork Clean:** Yes

**Formwork:** Gravel

**Method Of Placing:** Chute

**Weather:** Overcast

**Vibrators:** Screed

**Method Of Curing:** Plastic

**Specified Properties: Strength @ 28 Days :** 32 MPa, **Slump:** 100 Max mm **Air:** 5 - 8 %

#	Ticket No.	Truck No.	Time Record				Air (%)	Slump (mm)	Temp (C)		Volume		#Cyls Cast
			Batch	Tested	Unload	Elapsed			Conc	Air	Load	Cum.	
1	1156574	1161	14:53	15:40	16:20	1:27	6.6	100	21	15	5.73	5.73	5
2	1156583	1183	15:45	16:10	17:40	1:55	5.5	90	21	15	5.36	11.09	0

**Section:** Sidewalk and curb.

**Location:** Sidewalk in front of the Infirmary before the door building side, curb under canape in front of the entrance street side.

**Comments** Field Test Results Reported On Site, sidewalk and curb used exposed aggregate mix.

**Record No:** 37654

**Standby:**

1.5

**Englobe Tech:** Jean-Paul Ghosn

**PER**

For testing conducted by this company, procedures are carried out in accordance with CSA-A23.2. Reporting of these test results constitutes a testing service only. Engineering interpretation or evaluation of test results is provided only on request.

Project manager : Peter Salah