

A058 - G Customer Fire Alarm Battery Calculation

Fire alarms battery calculations for

Address

Postcode

Battery calculation

Job number

Standby current 1 X Standby time hrs

+ alarm current 2 =

X 1.25 = (Minimum battery capacity)

Round up to the nearest size battery in Ah (i.e. 5.6 = 7Ah)

Design Battery Size

Installed Battery Size

USE NEW SHEET FOR ANY ADDITIONAL PANELS

IF CALCULATION REQUIRED LARGER THAN PROVIDED BATTERIES PLEASE CONTACT PM OR LINE MANAGER

Fire alarms loop calculations for

Panel located

No of loops

For systems with multiple control panels, please complete additional A58/2 forms

Test carried out by

Name Test meter used

Signature Serial number

Date

SUBMIT