Trapping and imaging of single atom in the present of light shift



Yichao Yu
May 26, 2016
Ni Group/Harvard

Procedure

- MOT Loading
- Trapping
- Imaging
- Works for Cs
- Doesn't work for Na

Procedure

- MOT Loading
- Trapping
- Imaging
- Works for Cs
- Doesn't work for Na

Tweezer



Procedure

- MOT Loading
- Trapping
- Imaging
- Works for Cs
- Doesn't work for Na



Procedure

- MOT Loading
- Trapping
- Imaging
- Works for Cs
- Doesn't work for Na



Procedure

- MOT Loading
- Trapping
- Imaging
- Works for Cs
- Doesn't work for Na

Light shift

- Inefficient cooling; Heating
- Shift imaging light out of resonance



Light shift

- Inefficient cooling; Heating
- Shift imaging light out of resonance





Light shift

- Inefficient cooling; Heating
- Shift imaging light out of resonance







Light shift

- Inefficient cooling; Heating
- Shift imaging light out of resonance





Light shift

- Inefficient cooling; Heating
- Shift imaging light out of resonance







Light shift

- Inefficient cooling; Heating
- Shift imaging light out of resonance



Cs single atom loading

λ_{trap}	922	935	970
Loading %	0	≈ 50	≈ 50

Cs single atom imaging



Trap switching

- Alternate between resonant and trap light
- Switching at $1 - 3$MHz
  $f_{trap} = 10 \sim 400$kHz
  $\Gamma = 2\pi \times 5 \sim 10$MHz
- Being able to load single Na atom

Trap switching

- Alternate between resonant and trap light
- Switching at $1 - 3$MHz
  $f_{trap} = 10 \sim 400$kHz
  $\Gamma = 2\pi \times 5 \sim 10$MHz
- Being able to load single Na atom



Trap switching

- Alternate between resonant and trap light
- Switching at $1 - 3\text{MHz}$
  $f_{trap} = 10 \sim 400\text{kHz}$
  $\Gamma = 2\pi \times 5 \sim 10\text{MHz}$
- Being able to load single Na atom



Trap switching

- Alternate between resonant and trap light
- Switching at $1 - 3$MHz
  $f_{trap} = 10 \sim 400$kHz
  $\Gamma = 2\pi \times 5 \sim 10$MHz
- Being able to load single Na atom

Cs single atom loading

λ_{trap}	922	935	970
Loading %	≈ 50	≈ 50	≈ 50



Trap switching

- Alternate between resonant and trap light
- Switching at $1 - 3$MHz
  $f_{trap} = 10 \sim 400$kHz
  $\Gamma = 2\pi \times 5 \sim 10$MHz
- Being able to load single Na atom

Cs single atom loading

λ_{trap}	922	935	970
Loading %	≈ 50	≈ 50	≈ 50

Cs single atom imaging





Trap switching

- Alternate between resonant and trap light
- Switching at $1 - 3$MHz
  $f_{trap} = 10 \sim 400$kHz
  $\Gamma = 2\pi \times 5 \sim 10$MHz
- Being able to load single Na atom

Cs single atom loading

λ_{trap}	922	935	970
Loading %	≈ 50	≈ 50	≈ 50

Cs single atom imaging





Trap switching

- Alternate between resonant and trap light
- Switching at $1 - 3$MHz
  $f_{trap} = 10 \sim 400$kHz
  $\Gamma = 2\pi \times 5 \sim 10$MHz
- Being able to load single Na atom

Cs single atom loading

λ_{trap}	922	935	970
Loading %	≈ 50	≈ 50	≈ 50

Cs single atom imaging





Trap switching

- Alternate between resonant and trap light
- Switching at $1 - 3$MHz
  $f_{trap} = 10 \sim 400$kHz
  $\Gamma = 2\pi \times 5 \sim 10$MHz
- Being able to load single Na atom

Cs single atom loading

λ_{trap}	922	935	970
Loading %	≈ 50	≈ 50	≈ 50

Cs single atom imaging





Conclusion

- Measured the effect of light shift on loading and imaging of single atom
- Overcome the light shift by alternating trapping and resonant light to achieve loading of single Na atom.
- Generalizable to other species