

Exclusion Categories and Definitions and deviation thresholds

The following exclusions are applied while evaluating the performance with respect to the defined SLA metrics. This is to ensure that only meters with reliable and consistent operational conditions are considered in SLA calculations.

1. No Supply

This exclusion category includes meters that did not have electrical supply during the SLA monitoring window. The identification of such cases is based on **Power Events** recorded in the meter.

Example (SLA-1) | For Scheduled Interval Data Readings within 8 hours, if any meter has recorded a supply failure event occurring between **00:05 and 07:30**, it is classified under the “No Supply” exclusion. Such meters are excluded from SLA calculations since meter didn’t have the fair duration of power supply for transmitting the data which is required for meeting the SLA.

2. Inconsistent Supply

This exclusion applies to meters that had **intermittent or inadequate supply** during the SLA monitoring window, preventing consistent data communication. The cases are derived from the **Load Profile data** recorded in the meter.

Example (SLA-1) | For Scheduled Interval Data Readings within 8 hours, if a meter records **supply failure or voltage below 150 volts in more than 14 out of 16 blocks** (recorded till 08:00), it is categorized under this exclusion. These meters are excluded because unstable supply conditions prevent reliable data communication.

3. Last Gasp and Stopped Communication

This exclusion includes meters that have sent a “**Last Gasp**” flag indicating the power loss) and subsequently **stopped communication** for the remainder of the monitoring period. Meters that report a Last Gasp event and do not re-establish communication until the **end of the month** fall under this category. These meters are excluded as they seemed to be non-operational for the rest of the monitoring cycle.

4. TD/PD and Field Visit

This exclusion covers meters identified as Temporarily Disconnected , Permanently Disconnected, or those having connection-related issues discovered during field inspections. Such cases are captured during **Operations & Maintenance activities** performed by the field teams. Since these meters are physically disconnected or faulty, they are excluded from SLA evaluation.

5. Meter Days

“Meter Days” is a derived metric representing the total monitoring exposure of meters for a given SLA. It is calculated as:

Meter Days = Number of Meters × Number of Monitoring Days

- **Examples:**

- For **Load Profile** and **Daily Profile** SLAs – the monitoring is daily, so the number of days equals the total days in the month.
- For **Billing SLAs** – billing occurs once a month, so the monitoring period is considered as **1 day**.

- **Note:**

All exclusions mentioned above are measured in terms of **Meter Days** corresponding to the specific SLA metric.

Deviation Thresholds

SLA Metric	No Supply	Inconsistent Supply
SLA-1 Scheduled Interval data readings within 8 hours	00:05 to 07:30	More than 14 blocks out of 16
SLA-2 Scheduled Interval data readings within 12 hours	00:05 to 11:30	More than 22 blocks out of 24
SLA-3 Scheduled Interval data readings with in 24 hours	00:05 to 23:30	More than 45 blocks out of 48
SLA-41 Scheduled billing profile data for the bill period with in 72 hours	01-MM-YY 00:05 to 03-MM-YY 23:30	More than 135 blocks out of 144
SLA-42 Scheduled billing profile data for the bill period within 168 hours	01-MM-YY 00:05 to 07-MM-YY 23:30	More than 315 blocks out of 336