

Location (WHB unless otherwise stated)	TMV Type (Inta Tap or TMV2)	Hot Water Temperature (degrees C after 60 seconds)	Cold Water Temperature (degrees C after 2 mins)	Issues? (YES or NO)	Issue Notes
Winterfold	TAP	39.8	8.2	NO	
Winterfold Shower	N/A		N/A		
Lime Tree	TMV2	40.2	9.4	NO	
Lime Tree Shower	N/A		N/A		
Fontwell	TAP	39.2	16.7	NO	
Room 7	TAP	40.0	14.5	NO	
Room 8	TAP	40.0	20.0	NO	
Wisteria	TMV2	39.7	10.8	NO	
Wisteria Shower	N/A		N/A		
Rose Garden	TAP	39.4	10.1	NO	
Rose Garden Shower	N/A		N/A		
Room 10	TMV2	39.7	16.9	NO	
Room 11	TAP	40.5	8.3	NO	
Magnolia	—	—	—	—	ROOM REPAIRS.
Magnolia Shower	N/A		N/A		
Hurst Hill	TAP	38.1	8.5	NO	
Hurst Hill Shower	N/A		N/A		
Room 15	TAP	41.5	7.5	NO	
Room 45	TAP	42.0	6.6	NO	
Room 46	TAP	40.1	6.7	NO	
Room 16	TAP	40.6	7.8	NO	
Room 17	TAP	40.1	13.8	NO	
Room 17 Shower	N/A		N/A		
Room 18	TMV2	42.0	12.9	NO	
Room 18 Shower	N/A		N/A		
Room 19	TMV2	39.0	11.6	NO	
Room 19 Shower	N/A		N/A		
Room 20	TAP	41.9	9.8	NO	
Room 21	TMV2	40.2	12.8	NO	
Room 22	—	—	—	—	ROOM REPAIRS.
Room 23	TMV2	39.3	12.5	NO	
Room 23 Shower	N/A		N/A		
Room 25	TMV2	40.0	8.4	NO	
Room 26	TAP	39.3	9.4	NO	
Room 27	TAP	38.0	12.5	NO	
Room 28	TAP	40.8	9.0	NO	
Room 29	TAP	39.7	10.9	NO	
Room 30	TMV2	41.7	13.5	NO	
Room 32	TMV2	41.3	10.7	NO	
Room 33	TMV2	39.8	13.9	NO	
Room 34	TAP	38.7	10.2	NO	
Room 35	—	—	—	—	ROOM REPAIRS
Room 36	TAP	40.8	12.9	NO	

Room 37	TAP	38.1	9.6	NO	
Room 38	TAP	39.2	8.6	NO	
Room 39	TAP	38.4	8.7	YES	HOT WATER COME AND GOES
Room 40	TMV 2	41.0	12.8	NO	
Room 42	TAP	39.3	14.3	NO	
Room 43	TMV 2	41.2	12.0	NO	
Driver's	TAP	40.3	9.7	NO	
Driver's Shower	N/A		N/A		
Terrace	TAP	42.0	10.5	NO	
Terrace Shower	N/A		N/A		
June's	TMV 2	39.2	8.8	NO	
June's Shower	N/A		N/A		
Willow Tree	TAP	40.9	11.4	NO	
Willow Tree Shower	N/A		N/A		
Oakview	TMV 2	38.7	18.5	NO	
Oakview Shower	N/A		N/A		
Hawthorn	TAP	38.0	10.8	NO	HARD TO GET TO
Hawthorn Shower	N/A		N/A		TEMP.
Lakeview	TMV 2	38.0	9.6	NO	HAWTHORN + LAKEVIEW
Lakeview Shower	N/A		N/A		
Wey Bathroom	TMV 2	41.8	11.5	NO	
Wey Bath Spray	N/A		N/A		
Arun Bathroom	TAP	40.5	10.9	NO	
Arun Bath Spray	N/A		N/A		
Derwent Bathroom	TMV 2	39.7	8.6	NO	
Derwent Shower	N/A		N/A		
Coniston Bathroom	TAP	41.6	9.5	NO	
Coniston Shower	N/A		N/A		
Coniston Bath Spray	N/A		N/A		

DONE

4/2/19

S. M. Richetts.