

Location (WHB unless otherwise stated)	TMV Type (Inta Tap or TMV2)	Hot Water Temperature (degrees C after 60 seconds)	Cold Water Temperature (degrees C after 2 mins)	Issues? (YES or NO)	Issue Notes
Winterfold	TAP	40.3	14.0	NO	
Winterfold Shower	N/A		N/A		
Lime Tree	TMV2	41.0	14.3	NO	
Lime Tree Shower	N/A		N/A		
Fontwell	TAP	38.0	19.0	NO	
Room 7	TAP	41.0	17.4	NO	
Room 8	TAP	39.8	17.6	NO	
Wisteria	TMV2	39.6	14.1	NO	
Wisteria Shower	N/A		N/A		
Rose Garden	TAP	39.6	13.9	NO	
Rose Garden Shower	N/A		N/A		
Room 10	TMV2	41.3	19.0	NO	
Room 11	TAP	40.6	13.5	NO	
Magnolia	TMV2	38.3	13.5	NO	
Magnolia Shower	N/A		N/A		
Hurst Hill	11	11	11	11	REFURBISHMENT.
Hurst Hill Shower	N/A		N/A		
Room 15	TAP	39.7	12.6	NO	
Room 45	TAP	41.8	13.2	NO	
Room 46	TAP	40.7	12.6	NO	
Room 16	TAP	40.3	13.3	NO	
Room 17	TAP	38.2	15.3	NO	
Room 17 Shower	N/A		N/A		
Room 18	TMV2	42.0	17.5	NO	
Room 18 Shower	N/A		N/A		
Room 19	TMV2	40.2	14.4	NO	
Room 19 Shower	N/A		N/A		
Room 20	TAP	41.2	14.9	NO	
Room 21	TMV2	41.6	14.2	NO	
Room 22	TMV2	38.3	16.0	NO	
Room 23	TMV2	39.4	13.8	NO	
Room 23 Shower	N/A		N/A		
Room 25	TMV2	40.3	14.9	NO	
Room 26	TAP	41.0	16.0	NO	
Room 27	TAP	38.0	15.9	NO	
Room 28	TAP	39.5	15.9	NO	
Room 29	TAP	39.6	15.4	NO	
Room 30	TMV2	40.4	17.4	NO	
Room 32	TMV2	41.9	16.7	NO	
Room 33	TMV2	39.0	16.6	NO	
Room 34	TAP	38.0	15.7	NO	
Room 35	TMV2	40.4	16.4	NO	
Room 36	TAP	39.1	17.5	NO	

Room 37	TAP	39.9	14.9	NO	
Room 38	TAP	41.1	15.1	NO	
Room 39	TAP	39.1	14.5	NO	
Room 40	TMV2	41.8	17.4	NO	
Room 42	TAP	38.0	17.0	NO	
Room 43	TMV2	41.4	17.5	NO	
Driver's	TAP	39.7	15.2	NO	
Driver's Shower	N/A		N/A		
Terrace	TAP	41.1	15.7	NO	
Terrace Shower	N/A		N/A		
June's	TMV2	40.4	13.6	NO	
June's Shower	N/A		N/A		
Willow Tree	TAP	40.9	13.7	NO	
Willow Tree Shower	N/A		N/A		
Oakview	TMV2	38.6	17.2	NO	
Oakview Shower	N/A		N/A		
Hawthorn	TAPS	38.2	15.7	NO	
Hawthorn Shower	N/A		N/A		
Lakeview	TMV2	39.7	15.6	NO	
Lakeview Shower	N/A		N/A		
Wey Bathroom	TMV2	42.0	15.6	NO	
Wey Bath Spray	N/A		N/A		
Arun Bathroom	TAP	42.0	15.03	NO	
Arun Bath Spray	N/A		N/A		
Derwent Bathroom	TMV2	40.3	13.9	NO	
Derwent Shower	N/A		N/A		
Coniston Bathroom	TAP	42.0	14.4	NO	
Coniston Shower	N/A		N/A		
Coniston Bath Spray	N/A		N/A		

DONE

8/5/19

S.M. Riches