



Company: Eyhurst Court Ltd - GU5 0LB
Location: Kitchen
Risk Assessment: Electrical machinery
Reference No.: Kitchens
Date of Assessment: 29/10/2014
Completed By: Tim Whalley



Electrical machinery

Identified hazard:

Using electrical powered machinery in the kitchen area.



Who is at risk?

Kitchen/pantry staff and contractors

How is the risk controlled?

All electrically powered machinery is regularly inspected and tested by a competent person and suitable records maintained.
Fuses, miniature circuit boards (MCBs) and isolation switches are labelled with the circuits that they isolate and control.
Residual current devices are incorporated into the fixed electrical system or individual units are provided as required.
Fixed machines are fitted with suitable, lockable isolation switches.
There is a formal, documented machine isolation procedure.



The calculated risk factor for this task/operation is **21** (Probability: 3 x Severity: 7)

This is classed as a **MEDIUM** risk

Additional Measures:

None Required

Review Date

29/10/2015

Name: *T.M.W.*

Signature/s

Date

DL 18/3/15
DL 19/8/16
DL 29/12/17
DL 07/01/19