

Location (unless otherwise stated)	(WHB)	TMV Type (Inta Tap or TMV2)	Hot Water Temperature (degrees C after 60 seconds)	Cold Water Temperature (degrees C after 2 mins)	Issues? (YES or NO)	Issue Notes
Winterfold		TAP	40.9	12.3	NO	
Winterfold Shower		N/A		N/A		
Lime Tree		TMV2	40.6	12.7	NO	
Lime Tree Shower		N/A		N/A		
Fontwell		TAP	38.0	19.0	NO	
Room 7		TAP	40.3	17.1	NO	
Room 8		TAP	39.7	19.5	NO	
Wisteria		TMV2	39.1	11.8	NO	
Wisteria Shower		N/A		N/A		
Rose Garden		TAP	40.1	12.6	NO	
Rose Garden Shower		N/A		N/A		
Room 10		TMV2	40.3	19.6	NO	
Room 11		TAP	40.5	11.0	NO	
Magnolia		11 11	11 11	11 11	YES	WORKING ON ROOM
Magnolia Shower		N/A		N/A		
Hurst Hill		TAP	38.3	11.4	NO	
Hurst Hill Shower		N/A		N/A		
Room 15		TAP	39.8	10.7	NO	
Room 45		TAP	42.0	10.4	NO	
Room 46		TAP	38.0	10.3	NO	
Room 16		TAP	39.8	10.9	NO	
Room 17		TAP	40.3	14.5	NO	
Room 17 Shower		N/A		N/A		
Room 18		TMV2	42.0	19.0	NO	
Room 18 Shower		N/A		N/A		
Room 19		TMV2	39.7	15.0	NO	
Room 19 Shower		N/A		N/A		
Room 20		TAP	41.9	12.7	NO	
Room 21		TMV2	41.2	12.6	NO	
Room 22		TMV2	38.05	15.4	NO	
Room 23		TMV2	39.5	13.0		
Room 23 Shower		N/A		N/A		
Room 25		TMV2	40.7	14.5	NO	
Room 26		TAP	38.4	14.1	NO	
Room 27		TAP	38.1	14.8	NO	
Room 28		TAP	39.2	14.1	NO	
Room 29		TAP	40.5	14.5	NO	
Room 30		TMV2	38.1	14.9	NO	
Room 32		TMV2	41.7	14.6	NO	
Room 33		TMV2	40.1	18.3	NO	
Room 34		TAP	38.3	13.6	NO	
Room 35		TMV2	39.2	15.7	NO	
Room 36		TAP	42.0	13.2	NO	

Room 37	TAP	40.6	13.5	NO	
Room 38	TAP	39.9	13.8	NO	
Room 39	TAP	40.4	12.7	NO	
Room 40	TMV2	41.8	14.7	NO	
Room 42	TAP	39.3	15.8	NO	
Room 43	TMV2	40.1	14.5	NO	
Driver's	TAP	40.6	13.4	NO	
Driver's Shower	N/A		N/A		
Terrace	TAP	40.6	13.3	NO	
Terrace Shower	N/A		N/A		
June's	TMV2	40.2	14.4	NO	
June's Shower	N/A		N/A		
Willow Tree	TAP	41.3	12.2	NO	
Willow Tree Shower	N/A		N/A		
Oakview	TMV2	38.0	15.8	NO	
Oakview Shower	N/A		N/A		
Hawthorn	TAP	38.2	14.2	NO	
Hawthorn Shower	N/A		N/A		
Lakeview	TMV2	38.1	12.9	NO	
Lakeview Shower	N/A		N/A		
Wey Bathroom	TMV2	42.0	15.7	NO	
Wey Bath Spray	N/A		N/A		
Arun Bathroom	TAP	41.2	13.0	NO	
Arun Bath Spray	N/A		N/A		
Derwent Bathroom	TMV2	40.6	12.6	NO	
Derwent Shower	N/A		N/A		
Coniston Bathroom	TAP	41.9	11.7	NO	
Coniston Shower	N/A		N/A		
Coniston Bath Spray	N/A		N/A		

DONE

3/4/19

S. M. Richards.