

## Fire Alarm System Modification Certificate







Unit 17 Northbrook Business Park, Northbrook Road, Worthing, West Sussex. BN14 8PO.

Tel: 01903 830664

Fax: 01903 244008

Certificate of Modification for the Fire Alarm System at:

**Eyhurst Court Ltd** 

**Certificate Number:** 

IG/Birtley/220216/MOD

Address: Birtley House, Bramley, Guildford, Surrey. GU5 OLB

I/we being the competent person(s) responsible (as indicated by my/our signatures below) for the Modification of the fire detection and fire alarm system, particulars of which are set out below, CERTIFY that the said modification work for which I/we have been responsible has to the best of my/our knowledge and belief been carried out in accordance with the recommendations of 46.4 of BS 5839-1:2013, except for the variations, if any, stated in this certificate.

| Name:      | Iain Gibbs | Position: | Systems Manager          |
|------------|------------|-----------|--------------------------|
| Signature: | Janfiles   | Date:     | 6 <sup>th</sup> May 2016 |

For and on behalf of: Elite Fire Limited

Address: Unit 17 Northbrook Business Park, Worthing, West Sussex. BN14 8PQ.

The extent of liability of the signatory is limited to the system as described below. Extent of Installation work covered by this certificate:

Modifications to the existing fire alarm system throughout the building to bring the existing automatic coverage of the Fire Alarm System up to **BS 5839 Pt1 2013** to **Grade L1** standard

Variations from the recommendations of 46.4 of BS 5839-1:2013

Ground Floor Orangery - No detection within Skylight, 1 x Automatic detectors fitted either side.

Basement Stairs to ground Floor – No detector installed at the top of Staircase due to asbestos.

- Following the modifications, the system has been tested in accordance with the recommendations of 46.4.2 of BS 5839-1:2013
- Following the modifications, as fitted drawings and other system records have been updated as appropriate

I/we the undersigned confirm that the modifications have introduced no additional variations from the recommendations of BS 5839-1:2013, other than those recorded on this certificate.

Signed:

Capacity: Elite Fire Limited – Maintenance Organisation

( eg maintenance organisation, system designer, consultant or representative )