

'friendly, local service...nationwide'



L i f t G r o u p

LIFTS • ESCALATORS • CRADLES

3/19, Ropery Business Park,
Anchor and Hope Lane, London, SE7 7RX

Web www.jacksonlifts.com

Telephone 020 8293 4176

Service Attendance Form

Site Details

MNumber:	M54078	Site Contact:	Mark Teverson
Site Name:	Birtley House		
Site Address:	Bramley	Engineer:	0728
Site Postcode:	GU3 0LB	Route No:	225
Customer Lift Ref:	HPL Passenger Lift No 1	Supervisor:	Tony Moore
Property Code:		Contract Type:	A+

Service Work Details

Visit Month:	October	Date:	30/10/18
Main Ropes/Chains:	Worn but Serviceable	Tank Unit/Pipes:	Worn but Serviceable
Wiring/Flexes:	Worn but Serviceable	Rupture Valve/Safety Rope	Worn but Serviceable
Doors/Operator:	Worn but Serviceable	Controller:	Worn but Serviceable
Ram/Ram Seal:	Worn but Serviceable		
Service Type:	The service inspection type undertaken during this visit was type Y - Items visually checked during this visit may include (but are not limited to), controller, brake unit, motors/generators, winding gear, car entrances, door/gate operators, safety gear/guides, lift alarm, landing entrances, fire controls, overspeed governor, and shaft equipment. For a full break down of this service plan, please check your Jackson Lift Service Plan & Method Statement.		

Other Work Completed this Visit

	Due	Completed	Last Test Result
Insurance Items:			
Safety Test:	30/08/19	30/08/18	Satisfactory

Autodialler

	Installed	Audible Alarm Functional	Line Functional	Calls JLG helpdesk
Test Results:	Yes	Yes	Yes	No

Comments

General Remarks

Sign Off

Engineer Name:	Steve Cooper	Client Name:	n/a
Signature:		Signature:	