



Company: Eyhurst Court Ltd - GU5 0LB  
Location: General  
Risk Assessment: Hand Washing  
Reference No. All Depts  
Date of 16/03/2015  
Assessment:  
Completed By: Tim Whalley



## Hand Washing

### Identified hazard:

There is a risk to all staff from scalding due to high temperatures of hot water from some outlets.



### Who is at risk?

All Staff and Contractors

### How is the risk controlled?

Whilst some outlets have been fitted with Thermostatic Mixing Valves to reduce this risk, the programme of upgrading all outlets is not yet complete.



The calculated risk factor for this task/operation is **9** (Probability: 3 x Severity: 3)

This is classed as a **LOW** risk

### Additional Measures:

Further Measures	Person Responsible	Date For Completion
TMVs fitted where necessary	Tim Whalley	01/08/2015

### Review Date

16/03/2016

Name: *Tim W.*

Signature/s: *[Signature]*

Date: *18/3/15*

*Sh 07/01/19*

*Shally 27/12/17*

*19/8/16*