

'friendly, local service...nationwide'



L i f t G r o u p

LIFTS • ESCALATORS • CRADLES

3/19, Ropery Business Park,  
Anchor and Hope Lane, London, SE7 7RX

Web [www.jacksonlifts.com](http://www.jacksonlifts.com)

Telephone 020 8293 4176

## Service Attendance Form

### Site Details

MNumber:	M54079	Site Contact:	Mark Teverson
Site Name:	Birtley House		
Site Address:	Bramley	Engineer:	0728
Site Postcode:	GU3 0LB	Route No:	225
Customer Lift Ref:	HPL Passenger Lift No 2	Supervisor:	Tony Moore
Property Code:		Contract Type:	A+

### Service Work Details

Visit Month:	December	Date:	11/12/18
Main Ropes/Chains:	Worn but Serviceable	Tank Unit/Pipes:	Worn but Serviceable
Wiring/Flexes:	Worn but Serviceable	Rupture Valve/Safety Rope	Worn but Serviceable
Doors/Operator:	Worn but Serviceable	Controller:	Worn but Serviceable
Ram/Ram Seal:	Worn but Serviceable		
Service Type:	The service inspection type undertaken during this visit was type Z - Items visually checked during this visit may include (but are not limited to), controller, motors/generators, main sheave, winding gear, brake unit, car entrances, door/gate operators, safety gear/guides, lift alarm, landing entrances, landing protection, and shaft equipment. For a full break down of this service plan, please check your Jackson Lift Service Plan & Method Statement.		

### Other Work Completed this Visit

	Due	Completed	Last Test Result
Insurance Items:			
Safety Test:	30/08/19	30/08/18	Satisfactory

### Autodialler

	Installed	Audible Alarm Functional	Line Functional	Calls JLG helpdesk
Test Results:	No			

### Comments

pressure gauge faulty requires renewal

### General Remarks

CAR COMMUNICATIONS REQUIRED

### Sign Off

Engineer Name:	Steve Cooper	Client Name:	
Signature:		Signature:	