


# Lambeth Scientific Services Limited

Arlington Lodge, 26 Wanless Road, London SE24 0HW  
Tel: 020 7737 1111 Fax: 020 7926 8882



## 4-Stage Certificate of Reoccupation

Report No:	AGL2104	Date:	25.06.08	Analyst:	AP	Arrival Time:	1150
Name & Address of The Testing Laboratory:				Site Address for Clearance:			
Lambeth Scientific Services Arlington Lodge 26 Wanless Road London				BIRLET NURSING HOME BRAMLEY SURREY			
Postcode: SE24 0HW		Tel: 020 7737 1111		Postcode: GU5 0LB		Tel:	
Name & Address of Licensed Asbestos Contractor:				Name of Site Supervisor: A FISHER			
SOUTHERN INSULATION UNIT 23 CAKERSTRAEM RD ALTON HANTS				Person who Witnessed Smoke Test: u u			
Postcode: GU34 2GA		Tel:					
Location Of Enclosure:		BUNKER ROOM		Description of Asbestos Removal:		AIB TO CEILING + ENVIRONMENTAL CLEAN	
Stage 1 of 4: Preliminary check of site condition and job completeness							
1.1 Plan of work checked to confirm areas to be assessed. (Record any problems, differences, fixed installations or ACMs to remain.)				Comments: ALL SATISFACTORY			
State Yes if the following are Intact & Operating / record the problem if not.							
1.2 Work areas		YES					
1.3 Enclosures / NPU		YES					
1.4 Hygiene facilities		YES					
State Yes if the following areas & their immediate surrounds appear to be free of obvious Asbestos debris and Asbestos waste sacks / record problem if not.							
1.5 Skip area / Waste route		YES					
1.6 Transit route		YES					
1.7 Hygiene facilities		YES					
1.8 Enclosure / work area		YES					
(Note 1:8 should also be free of unnecessary equipment. If No or insufficient viewing panels are fitted note this down and continue with the assessment, as the area inside the enclosure will be covered in section 2.)							
Stage 1: <u>Passed</u> / Failed		Time: 1159		Date: 25.06.08		Assessed By: A PORTER	
Comments:							
Signature of Assessor:		Note: if failed carry on remaining stages and get the representative to sign the acknowledgement later					
Stage 2 of 4: Thorough Visual Inspection							
Requirement				Yes / No		Comments	
2.1 Hygiene units are free from waste, debris, dust, contaminated clothing etc.				YES			
2.2 Airlock / Enclosure are free of waste bags, materials and unnecessary equipment.				YES			
2.3 All ACM's have been completely removed from the underlying surfaces				YES			
2.4 Interior surfaces of the enclosure are free from debris and settled dust.				YES			
Stage 2: <u>Passed</u> / Failed		Time: 1223		Date: 26.06.08		Assessed By: A PORTER	
The Hygiene Unit, Airlock and Enclosure were <u>FREE</u> / NOT FREE of visible Asbestos waste, debris and surface dust.							
Comments:							
Signature of Assessor:		If failed strike through remaining stages and get the representative to sign the acknowledgement box at the end					



# Lambeth Scientific Services Limited

Arlington Lodge, 26 Wanless Road, London SE24 0HW  
Tel: 020 7737 1111 Fax: 020 7926 8882





Report No:	AOL2104	Date:	25.06.08	Analyst:	AP
<b>Stage 3 of 4: Clearance Air Monitoring inside the Enclosure</b>					
Sampling information		Yes / No		Comments:	
3.1 All areas are dry:		YES			
3.2 Air movers off & sealed:		YES			
3.3 No evidence of lock down sprays:		NO			
3.4 Original floor surface uncovered:		YES			
3.5 Disturbance type used:		BRUSH			
3.6 Total time of disturbance:		3 Minutes			
3.7 Area or volume of enclosure:		30 m <sup>2</sup> or m <sup>3</sup>			
3.8 No. of air samples collected: (a drawing showing the sampling positions is included below)		2			

<b>Sampling details &amp; Type of Test: (Clearance = C / Reassurance = R / Personal = P / Background = B / Leak = L)</b>									
Field Code:	C	Microscope No:	ME01	Flowmeter No:	AF12	Graticule Diameter:	100	NPL Test:	5
Test Type:	C	Site Temp °C	23.0	Site Pressure (Mb):	1018	Exposed filter Diameter (mm)	22.52		


**Disclaimer:** The following results were obtained from exposed membrane filters cleared by the acetone/triacetin method and examined under phase contrast microscopy as detailed in the current issue of the HSE document HSG248 Asbestos: The analysts' guide for sampling, analysis and clearance procedures. Opinions, interpretations and stages 1 to 4 of clearance testing are within the scope of accreditation.

Field Code	Pump Position	Group	Pump No	Cowl No	Flow Rate (L/min)			Sampling Time			Samp Vol	No of fibres	No of fields	Fibre conc. f/ml
					Start	End	Mean	Start	End	Duration				
A01	WITHIN AREA	1	AP5	AH7	12.0	12.0	12.0	1228	1308	40	480	2	200	<0.01
A02	WITHIN AREA	1	AP6	AH8	12.0	12.0	12.0	1228	1308	40	480	1 1/2	200	<0.01

The measured respirable airborne fibre concentration is less than the clearance indicator of 0.01 f/ml as recommended by the Health & Safety Executive and is considered to be sufficiently low for normal occupation of the area tested

<b>Enclosure Layout &amp; Sampling Position:</b> 	Stage 3: <u>Passed</u> / Failed	Time:	1315	Date:	25.06.08
	Assessed By:	A PORTER			
	Comments:  <b>THE AREA IS NOW / NOT CLEARED FOR THE ENCLOSURE TO BE DISMANTLED.</b>  Signature of assessor:   (If failed strike through remaining stage & get the representative to sign the acknowledgement box at the end)				





# Lambeth Scientific Services Limited

Arlington Lodge, 26 Wanless Road, London SE24 0HW  
Tel: 020 7737 1111 Fax: 020 7926 8882



Report No:	A02104	Date:	26.06.08	Analyst:	AP
Stage 4 of 4: Assessment of site for reoccupation (after the enclosure is removed)					
Requirements	Yes / No	Comments			
4.1 Former enclosure/work area and its immediate surrounds are free from any visible debris, asbestos sacks and waste.	YES				
4.2 Transit route and waste area is free from any asbestos debris, asbestos sacks and waste.	YES				
4.3 All ACMs in the scope of work have been removed and any known ACMs remaining are intact.	YES				
Stage 4: <u>Passed</u> / Failed	Time: 1330	Date: 26.06.08	Assessed by: A PORTER		
The area <u>CAN BE</u> / CANNOT BE reoccupied. Comments:					
Assessor's Signature:					

Contractor's Representative Acknowledgement:

I have been advised by ..... that the certificate of reoccupation has not been issued because the area has failed stage ...

I have been advised by A PORTER ..... that the certificate of reoccupation can be issued as the area has passed all FOUR stages.  
(If failed, strike through remaining stages and get the supervisor to sign the acknowledgement)

Name of the Supervisor: A FISHER Signature: Date: 26.06.08 Time: 1332

Issue of Certificate of Reoccupation by the Assessor:

Copies of this certificate no. 12104 ..... issue no. 1 ..... were issued to the following person: A FISHER

Name of Assessor: A PORTER Signature: Date: 26.06.08 Time: 1332