

FDL Generators Limited
1 Jupiter House, Calleva Park
Aldermaston, Berkshire Rg7 8NN
Tel: 01189817451
Fax: 01189817054
Email: generators@fdlpower.co.uk
Web: www.fdlpower.co.uk



Generator Test Sheet

Customer: Birtley House **Date:** 03 07 2018

Address: Birtley Road, Guildford

Postcode:

Make: FG Wilson **Engine Type:** Perkins **Alternator type:** Stamford **KVA:** 135

Set Serial Number: E4617A/001 **Hours run:** **Max Amps:** 187 **Voltage:** 415 **Hz:** 50

FDL Engineer: Dan Gibbs	Heater: working
Meters/instrumentation: working	Protection switches: tested
Emergency/ warning lights: tested	Fuel pumps/Injector operation: good
General wiring: sound	Fuel pipes/filters/tanks: good
Acid level: level	Lubrication dip stick/state of oil: level
State of cells: passed/80%	Fire valve: n/a
Charge rates: 13.2v float	General security all parts: secure
Coolant system: level	Exhaust system: no leaks
Antifreeze %: 50% mix/topped up	Fuel transfer: manual fill
Resilient Mountings: sound	Regulation: stable

Time	Engine speed	Load per phase Amps	Volts	Lube oil Pressure	Cooling water Temp	D.C Charge Amps	Remarks
0950	52hz	0	415	80psi	40*c	+ve	off load startup

Comments

Battery is becoming weak. Recommend to replace (1x 067) also recommend to test condition of engine oil (1x sample)
Recommend to replace fuel filter due to age (2x FS19838)
Cleaned and greased battery terminals
Topped up coolant level
Run set up off load
Tested engine protections-working/reset
No issues found
Set remains in auto

Items Supplied

Battery terminal grease
5lts x 5ry coolant

Fuel Level

60% full

Print Name: Tim Whaley

Signature:

A handwritten signature in black ink, appearing to be 'Tim Whaley'.