

LIFTS • ESCALATORS • CRADLES

3/19, Ropery Business Park, Anchor and Hope Lane, London, SE7 7RX

> Web www.jacksonlifts.com **Telephone** 020 8293 4176

Service Attendance Form

Site Details

MNumber: M54080 Site Name: Birtley House

Site Address: Bramley Site Postcode: GU3 0LB

Customer Lift Ref: HPL Passenger Lift No 3

Property Code:

Site Contact: Mark Teverson

0728

225

09/01/19

Worn but Serviceable

Worn but Serviceable

Engineer: Route No:

Tank Unit/Pipes:

Controller:

Supervisor: Tony Moore

Rupture Valve/Safety Rope Worn but Serviceable

Contract Type: A+

Service Work Details

Visit Month: January Date:

Main Ropes/Chains: Worn but Serviceable Wiring/Flexes: Worn but Serviceable Doors/Operator: Worn but Serviceable

Ram/Ram Seal: Worn but Serviceable

Service Type: The service inspection type undertaken during this visit was type X - Items visually checked during this visit may include (but are not limited to), controller, brake unit, car entrances, door/gate operators, lift alarm, landing entrances and shaft equipment.

For a full break down of this service plan, please check your Jackson Lift Service Plan & Method Statement.

Other Work Completed this Visit

Due **Last Test Result** Completed

Insurance Items:

30/08/19 30/08/18 Safety Test: Satisfactory

Autodialler

Installed **Audible Alarm Functional** Line Functional Calls JLG helpdesk Test Results: Yes No Yes No

Comments

General Remarks

Car Communications Telephone Line Down

Sign Off

Engineer Name: Client Name: Steve Cooper

Signature:

Signature:





