

Location (WHB unless otherwise stated)	TMV Type (Inta Tap or TMV2)	Hot Water Temperature (degrees C after 60 seconds)	Cold Water Temperature (degrees C after 2 mins)	Issues? (YES or NO)	Issue Notes
Winterfold	TAP	39.8	14.1	NO	
Winterfold Shower	N/A		N/A		
Lime Tree	TMV 2	41.2	18.3	NO	
Lime Tree Shower	N/A		N/A		
Fontwell	TAP	37.6	20.0	NO	
Room 7	TAP	41.1	20.0	NO	
Room 8	TAP	41.2	18.4	NO	
Wisteria	TMV 2	39.4	15.8	NO	
Wisteria Shower	N/A		N/A		
Rose Garden	TAPS	40.5	15.8	NO	
Rose Garden Shower	N/A		N/A		
Room 10	TMV 2	41.7	20.0	NO	
Room 11	TAP	41.0	13.1	NO	
Magnolia	TAP	41.1	13.3	NO	
Magnolia Shower	N/A		N/A		
Hurst Hill					
Hurst Hill Shower	N/A		N/A		LOCKED
Room 15	TAP	40.0	12.0	NO	
Room 45	TAP	43.2	11.9	NO	
Room 46	TAP	42.0	12.1	NO	
Room 16	TAP	40.7	13.0	NO	
Room 17	TAP	40.8	15.0	NO	
Room 17 Shower	N/A		N/A		
Room 18	TMV 2	41.5	14.8	NO	
Room 18 Shower	N/A		N/A		
Room 19	TMV 2	39.8	15.1	NO	
Room 19 Shower	N/A		N/A		
Room 20	TAP	42.3	15.1	NO	
Room 21	TMV 2	40.1	14.3	NO	
Room 22	TAP	40.5	13.7	NO	
Room 23	TMV 2	39.5	13.8	NO	
Room 23 Shower	N/A		N/A		
Room 25	TMV 2	40.5	13.0	NO	
Room 26	TAP	41.3	13.7	NO	
Room 27	TAP	39.3	14.0	NO	
Room 28	TAP	41.4	14.7	NO	
Room 29	TAP	41.0	14.5	NO	
Room 30	TMV 2	42.0	16.1	NO	
Room 32					WORKING ON ROOM.
Room 33	TMV 2	40.8	15.8	NO	
Room 34	TAP	39.3	13.9	NO	

Room 35	TAP	40.9	16.0	NO	
Room 36	TAP	39.9	15.1	NO	
Room 37	TAP	38.8	15.2	NO	
Room 38	TAP	39.8	13.2	NO	
Room 39	TAP	39.5	13.7	NO	
Room 40	TMV 2	41.8	17.2	NO	
Room 42	TAP	38.9	15.4	NO	
Room 43	TMV 2	39.4	17.3	NO	
Driver's	TAP	41.0	15.0	NO	
Driver's Shower	N/A		N/A		
Terrace	TAP	41.0	15.2	NO	
Terrace Shower	N/A		N/A		
June's	TMV 2	39.2	14.0	NO	
June's Shower	N/A		N/A		
Willow Tree	TAP	41.6	14.2	NO	
Willow Tree Shower	N/A		N/A		
Oakview	TMV 2	38.2	17.5	NO	
Oakview Shower	N/A		N/A		
Hawthorn	TAP	38.1	16.2	NO	
Hawthorn Shower	N/A		N/A		
Lakeview	TMV 2	38.3	16.5	NO	
Lakeview Shower	N/A		N/A		
Wey Bathroom	TMV 2	40.5	18.0	NO	
Wey Bath Spray	N/A		N/A		
Arun Bathroom	TAP	40.7	15.4	NO	
Arun Bath Spray	N/A		N/A		
Derwent Bathroom	TMV 2	40.6	15.4	NO	
Derwent Shower	N/A		N/A		
Coniston Bathroom	TAP	42.0	14.2	NO	
Coniston Shower	N/A		N/A		
Coniston Bath Spray	N/A		N/A		

6/11/18

John Whalley

TSD WHALLEY