

Emergency Lighting Test

Location description	Device Number	PASS	FAIL
House Ground Floor			
Front Entrance Hall	9501	✓	
Front Entrance Hall	9502	✓	
Reception Hall	9503	✓	
Main Hall	9504	✓	
Central Admin Office	9505		✓
Terrace Apartment	9506	✓	
Orangery	9507	✓	
O/S Willow Tree	9508	✓	
Training Room Stairs	9509	✓	
Training Room	9510	✓	
Orangery	9511	✓	
Orangery	9512	✓	
O/S Basement	9513	✓	
Orangery Corridor	9514	✓	
Visitor's WC 1	9596	✓	
O/S Staff Room	9515	✓	
O/S Staff Room	9516	✓	
Housekeeping Corridor	9517	✓	
Kitchen Corridor	9518	✓	
Housekeeping Corridor	9519	✓	
Main Plant Room	9599	✓	
Activities Corridor	9520	✓	
Activities Room	9521	✓	
Activities WC	9522	✓	
Activities Corridor	9523	✓	
Annexe Lift Motor Room	9524	✓	
Annexe Lift Lobby	9525	✓	
Activities Corridor	9526	✓	
Annexe Ground Floor			
Annexe Corridor (West)	9527	✓	
Annexe Corridor (West)	9528	✓	
Annexe Corridor (Stairwell)	9529	✓	
Annexe Corridor (Stairwell)	9530	✓	
Annexe Corridor (Sun Lounge)	9531	✓	
Sun Lounge	9532	✓	
Annexe Corridor (East)	9533	✓	
Annexe Corridor (East)	9534	✓	
Annexe Corridor (North)	9535a	✓	
Annexe Corridor (North)	9535b	✓	
Annexe First Floor			
Annexe Far Stairs	9583a	✓	
Annexe First Floor Corridor (North)	9583b	✓	
Annexe First Floor Corridor (East)	9582	✓	
Annexe First Floor Corridor (East)	9581	✓	
Annexe First Floor Corridor (East)	9580	✓	
Annexe First Floor Corridor (East)	9579	✓	
Annexe Central Stairs	9578	✓	
Annexe First Floor Corridor (West)	9577	✓	
Annexe First Floor Corridor (West)	9576	✓	
House First Floor			
House Link Corridor (East)	9575	✓	
House Link Corridor (O/S Linen Room)	9574	✓	

Emergency Lighting Test

House Link Corridor (O/S Consiton Bathroom)	9573	✓	
House Link Corridor (West)	9572	✓	
North Wing Corridor (East)	9571	✓	
North Wing Corridor	9570	✓	
North Wing Corridor (O/S Magnolia)	9569	✓	
North Wing Corridor (Staff Room Stairs)	9568	✓	
North Wing Corridor (O/S Manager's Office)	9567	✓	
Main Hall Mezzanine	9566	✓	
West Wing Corridor (Lift Lobby)	9565	✓	
West Wing Corridor (O/S Wisteria)	9564	✓	
West Wing Corridor (O/S Room 8)	9563	✓	
Winterfold	9562	✓	
House Second Floor			
Second Floor Central Stairs	9584	✓	
Second Floor Corridor (O/S Hawthorn)	9585	✓	
Second Floor Corridor (O/S Hawthorn)	9586	✓	
Second Floor Corridor (O/S Hawthorn)	9587	✓	
Second Floor Corridor(O/S Oakview)	9588	✓	
Second Floor Lift Lobby	9589	✓	
Second Floor Corridor (Central Stairs)	9590	✓	
Lakeview Corridor	9591	✓	
Lakeview Corridor	9592	✓	
Lakeview Corridor	9593	✓	
Lakeview Corridor	9594	✓	
Second Floor East Stairs	9595	✓	

EMERGENCY
LIGHT TESTS
18/7/19
S.M. Picketts