

Location (W/HB unless otherwise stated)	TMV Type (Inta Tap or TMV2)	Hot Water Temperature (degrees C after 60 seconds)	Cold Water Temperature (degrees C after 2 mins)	Issues? (YES or NO)	Issue Notes
Winterfold	TAP	41.6	11.9	NO	
Winterfold Shower	N/A		N/A		
Lime Tree	TMV2	40.5	12.7	NO	
Lime Tree Shower	N/A		N/A		
Fontwell	TAP	38.2	18.3	NO	
Room 7	TAP	41.5	15.4	NO	
Room 8	TAP	40.8	20.0	NO	
Wisteria	TMV2	39.6	11.2	NO	
Wisteria Shower	N/A		N/A		
Rose Garden	TAP	38.5	12.9	NO	
Rose Garden Shower	N/A		N/A		
Room 10	TMV2	43.2	19.9	NO	
Room 11	TAP	40.3	11.1	NO	
Magnolia	TAP	41.1	11.5	NO	
Magnolia Shower	N/A		N/A		
Hurst Hill					ROOM LOCKED
Hurst Hill Shower	N/A		N/A		
Room 15	TAP	41.3	11.0	NO	
Room 45	TAP	41.8	10.3	NO	
Room 46	TAP	39.3	10.6	NO	
Room 16	TAP	38.7	11.4	NO	
Room 17	TAP	39.5	12.7	NO	
Room 17 Shower	N/A		N/A		
Room 18	TMV2	42.6	18.9	NO	
Room 18 Shower	N/A		N/A		
Room 19	TMV2	38.4	19.4	NO	
Room 19 Shower	N/A		N/A		
Room 20	TAP	41.3	15.5	NO	
Room 21	TMV2	42.3	16.0	NO	
Room 22	TAP	40.7	12.0	NO	
Room 23	TMV2	39.4	17.8	NO	
Room 23 Shower	N/A		N/A		
Room 25	TMV2	41.3	17.5	NO	
Room 26	TAP	40.2	13.3	NO	
Room 27	TAP	38.5	13.4	NO	
Room 28	TAP	39.0	13.0		
Room 29	TAP	39.6	13.2	NO	
Room 30					ROOM LOCKED
Room 32	TMV2	41.9	20.2	NO	
Room 33	TMV2	41.4	15.4	NO	
Room 34	TAP	38.4	13.2	NO	
Room 35	TAP	38.8	14.0	NO	
Room 36	TAP	39.5	13.9	NO	

Room 37	TAP	39.2	12.5	NO	
Room 38	TAP	38.0	12.9	NO	
Room 39	TAP	38.5	12.3	NO	
Room 40	TMV2	41.4	14.3	NO	
Room 42	TAP	38.2	15.5	NO	
Room 43	TMV2	40.2	19.3	NO	
Driver's	TAP	41.0	13.4	NO	
Driver's Shower	N/A		N/A		
Terrace	TAP	42.1	13.8	NO	
Terrace Shower	N/A		N/A		
June's	TMV2	40.8	10.9	NO	
June's Shower	N/A		N/A		
Willow Tree	TMV2	39.0	12.3	NO	
Willow Tree Shower	N/A		N/A		
Oakview	TMV2	38.2	17.5	NO	
Oakview Shower	N/A		N/A		
Hawthorn	TAP	38.1	15.2	NO	
Hawthorn Shower	N/A		N/A		
Lakeview	TMV2	38.0	12.9	NO	
Lakeview Shower	N/A		N/A		
Wey Bathroom	TMV2	43.0	14.6	NO	
Wey Bath Spray	N/A		N/A		
Arun Bathroom	TAP	42.6	12.9	NO	
Arun Bath Spray	N/A		N/A		
Derwent Bathroom	TMV2	39.2	11.3	NO	
Derwent Shower	N/A		N/A		
Coniston Bathroom	TAP	41.1	12.2	NO	
Coniston Shower	N/A		N/A		
Coniston Bath Spray	N/A		N/A		

DONE 12/12/18

S.M. Pichets.