

ARTICLE INFO

Keywords:

ABSTRACT

Here goes the abstract

1. Introduction

In recent years there has been a global expansion of renewable power generation Shahbaz, Siddiqui, Siddiqui, Jiao and Kautish (2023); Hassan, Algburi, Sameen, Al-Musawi, Al-Jiboory, Salman, Ali and Jaszczur (2024), driven by de-carbonization efforts and declining costs in renewable technologies Jäger-Waldau (2025); Joshi, Rao and Banerjee (2025); Manservigi, Castorino, Spina, Venturini and Gonzalez-Salazar (2026). This rapid deployment of renewable generation has been mostly due to additions in solar (at both utility and residential scale), hydro and wind capacity Shahbaz et al. (2023); Hassan et al. (2024). Currently, annual renewable capacity additions outpace conventional capacity additions IRENA (2025), and this upward trend will likely continue in the forecoming decades Agency (2019); Raturi (2021).

However, the rapid expansion of renewable generation is leading to grid integration difficulties due to inherent variability and uncertainty in the output Li, Shi, Cao, Wang, Kuang, Tan and Wei (2015); Liu and He (2023). Spatiotemporal mismatches between power supply and demand may arise if capacity planning and grid infrastructure development do not keep pace Ming, Kun and Jun (2013); Bird, Lew, Milligan, Carlini, Estanqueiro, Flynn, Gomez-Lazaro, Holttinen, Menemenlis, Orths et al. (2016); O'Shaughnessy, Cruce and Xu (2020); Li, Wang, Guo, Xin, Zhang, Liu and Feng (2024). Oversupply of renewable generation — occurring during periods of low demand or high wind and solar resource availability — can result in curtailment of a fraction of the generated energy Denholm, O'Connell, Brinkman and Jorgenson (2015); Bird et al. (2016); O'Shaughnessy et al. (2020). This issue is further compounded by the increasing penetration of residential-scale distributed generation, which is generally excluded from centralized dispatch scheduling owing to its negligible individual capacity Li et al. (2015); Bhattarai, Maraseni and Apan (2022). As a result, these challenges place increasing demands on power system flexibility and energy storage capacity, both of which are essential for

balancing supply and demand in high-penetration renewable energy systems Denholm and Mai (2019); Liu and He (2023); Nejla, Saidani and Besbes (2025).

In particular, South America has also experienced accelerated penetration of renewable generation in recent years, with wind and solar photovoltaic capacity accounting for more than half of annual capacity additions International Energy Agency (2023). Although renewable penetration has been uneven across countries, several are already experiencing increasing curtailment rates von Papp, Moraga and Henríquez (2022); Silva, Renolphi, Vieira, Lourenço, Salles and Monaro (2025). Chile has recorded curtailment rates of up to 20% of total annual renewable generation, driven mainly by a geographical mismatch between solar generation — concentrated in the northern Atacama region — and demand centers located farther south von Papp et al. (2022); Silva et al. (2025). In Brazil, by contrast, the rapid expansion of distributed generation has reshaped the load profile, also resulting in high curtailment rates da Ponte, Rego and Júnior (2025); Silva, Vieira, Rego, Simone, Lourenço and Salles (2026). Despite these challenges, the region's abundant hydroelectric capacity Farfan and Breyer (2017); International Energy Agency (2023) represents an advantage for renewable energy integration, offering flexible storage and dispatch capabilities that can help mitigate variability and curtailment Wan and Parsons (1993); Hingray, Favre, Sauquet and Anquetin (2014).

Bolivia's current power mix is dominated by hydro and thermal generation—accounting for approximately 70% and 20% of installed capacity, respectively — with only a small share of non-hydro renewables Autoridad de Fiscalización de Electricidad y Tecnología Nuclear (AETN) (2026) —. Efforts are underway to further decarbonize the electricity sector: national development plans Viceministerio de Electricidad y Energías Renovables (2025) and Bolivia's Nationally Determined Contributions (NDC) Ministerio de Medio Ambiente y Agua and Autoridad Plurinacional de la Madre Tierra (2021) foresee substantial growth in centralized renewable capacity. The accelerated uptake of distributed solar PV observed in the region Chueca, Weiss, Celaya, Ravillard, Ortega, Tolmasquim and Hallack (2023) suggests that distributed generation growth represents a plausible complementary pathway.

Given this growing complexity in power systems, energy modeling has become a crucial tool for exploring

★

*Corresponding author

✉ ebianchi@unrn.edu.ar (E. Bianchi)

ORCID(s):

1

supply and demand scenarios that support long-term policy decisions Huntington, Weyant and Sweeney (1982); Pfenninger, Hawkes and Keirstead (2014). However, few studies have modeled the impacts of renewable energy penetration on power systems in South America. In Bolivia, Fernandez-Vazquez et al. Fernandez Vazquez, Vansighen, Fernandez Fuentes and Quoilin (2022) developed a long-term optimization model of the Bolivian energy sector using OSeMOSYS, based on a trend-based projection of power demand; and analyzed policy-based scenarios to induce decarbonization of the power system. However, the specific impacts of renewable capacity expansion — particularly distributed generation — on transmission requirements, thermal fuel consumption, greenhouse gas (GHG) emissions, and energy curtailment remain unexplored. This study aims to analyze the impacts of exogenous renewable capacity additions — both centralized and distributed — on power transmission, fuel consumption in thermal power facilities, GHG emissions, and energy curtailment. An intraday hydroelectric dispatch strategy is also proposed to mitigate renewable energy curtailment. For this purpose, we constructed a regionalized model of the Bolivian energy sector using the LEAP and NEMO modeling tools.

The paper is structured as follows: Section 2 describes the particularities of Bolivia's energy and power system, the modeling approach implemented in this study, the characterization of energy and electricity demand, and the current power generation fleet along with their future scenarios. Section 3 presents the results of the scenario analysis and comparison in terms of their effects on overall power demand and supply, fuel savings, GHG emissions, regional electricity balances and flows, and total costs within the National Interconnected System (NIS).

2. Methodology

2.1. Case study

Electricity demand currently represents approximately 11% of Bolivia's overall energy demand and has grown at an annual rate of approximately 5.7% in recent years Ministerio de Hidrocarburos y Energías, Viceministerio de Planificación y Desarrollo Energético (2023, 2024). This demand is predominantly met by natural gas (NG) and hydroelectric generation. By the end of 2024, the installed capacity of the NIS totaled 3580 MW, of which 2573 MW corresponded to thermoelectric sources and 758 MW to hydroelectric sources, with the remaining 249 MW distributed across wind, solar, and biomass. Approximately 98% of thermoelectric capacity is NG-based, with the remainder corresponding to diesel engines; the NG-based fleet, in turn, is composed of 66% combined-cycle, 30% turbo-gas, and 4% turbo-vapor units.

Table 1
Power lines

Line	Nodes	Capacity [MW]
L1	Centro-Norte	390
L2	Centro-Sur	260
L3	Centro-Oriente	165
L4	Oriente-Norte	35
L5	Centro-Oriente	500

NG-based generation accounts for most of Bolivia's capacity expansion over the last three decades Ballivian Cabrera (2024). More recently, however, a steep decline in domestic NG production Ministerio de Hidrocarburos y Energías, Viceministerio de Planificación y Desarrollo Energético (2024) has motivated the development of national plans and policies aimed at decarbonizing the power sector Balderrama, Broad, Sevillano, Alejo and Howells (2017); Fernandez Vazquez et al. (2022). The capacity expansion plan assessed in this study, prepared by the Ministry of Energy, includes two ambitious scenarios of 100% renewable capacity additions up to 2037.

Bolivia's NIS has no current linkages with the national grids of bordering countries and can therefore be considered an isolated system; and it currently covers eight out of nine departments. Given this configuration, Bolivia's energy system was represented in this study as a multi-nodal system, consisting of five nodes or regions obtained by grouping the administrative divisions as follows:

- Pando
- Norte (La Paz + Beni)
- Centro (Cochabamba + Oruro)
- Oriente (Santa Cruz)
- Sur (Tarija, Potosí, and Chuquisaca)

This regionalization was based on prior energy modeling studies conducted in Bolivia that proposed this specific departmental aggregation (see Huallpara, Navia Orellana, Gomand, Balderrama, Pavičević and Quoilin (2023)). Accordingly, this structure was replicated in the present study to facilitate comparison with independently conducted modeling exercises.

Figure 1 shows the location of the nodes and the representation of the NIS, for which two power lines connecting Centro and Oriente, one line connecting Centro and Sur, one line connecting Centro and Norte, and one connecting Oriente and Norte were considered. Pando Region is not currently interconnected with the other regions. The main features of the power lines are detailed in Table 1.

2.2. Modelling approach

In this study, the Low Emissions Analysis Platform (LEAP) and the Next Energy Modeling System for Optimization (NEMO) were used to model Bolivia's energy




Figure 1: Regional nodes included in the model and power lines

sector. LEAP is a modeling tool developed by the Stockholm Environment Institute Heaps (2022). It has been widely used by researchers and organizations to project future energy demand and supply and greenhouse gas (GHG) emissions, and to assess energy policies and scenarios Emodi, Emodi, Murthy and Emodi (2017); Shahid, Ullah, Imran, Mahmood and Arentsen (2021); Handayani, Overland, Suryadi and Vakulchuk (2023). It supports the implementation of multiple modeling approaches within a single model, including bottom-up Fleiter, Worrell and Eichhammer (2011) and top-down methodologies Rogan, Cahill, Daly, Dineen, Deane, Heaps, Welsch, Howells, Bazilian and Ó Gallachóir (2014), and it allows the formulation and comparison of different energy scenarios. NEMO is an open-source tool for energy system optimization Stockholm Environment Institute (2026). Combined with LEAP, it enables additional modeling capabilities, such as least-cost optimization of energy supply and demand, multi-regional trade simulation, nodal network configuration, and energy storage modeling. In this study, we implemented a bottom-up approach and enabled NEMO's optimization module, together with the Cbc solver, for non-renewable capacity expansion, nodal simulation, and electricity dispatch.

The structure of both energy demand and supply — including regional features — was replicated in LEAP using information from national energy balances and inventories Ministerio de Hidrocarburos y Energías, Viceministerio de Planificación y Desarrollo Energético (2023, 2024); Autoridad de Fiscalización de Electricidad y Tecnología Nuclear (AETN) (2026), which provide annual energy demand volumes disaggregated by sector (industry, residential, transport, etc.) and by energy source (electricity, gasoline, diesel,

etc.), as well as an updated generation fleet inventory. The base year of the simulation was set to 2023, and the simulation covers the 2023–2050 period.

Both power load curves as well as maximum availability curves for hydroelectric, solar and wind plants were configured with two-hourly resolution grouped in a wet season (november to april) and a dry season (may to october), resulting in 24 time slices.

2.3. Demand

As mentioned before, energy demand was modeled for 5 geographical regions (Pando, Norte, Centro Oriente, Sur) and for 7 sectors: residential, transport, industry, commercial + public, agriculture + fishery + mining, and construction. For the residential sector, the number of households represents the unit of consumption. We used population projections from the national bureau of statistics (INE in spanish Instituto Nacional de Estadística de Bolivia (2024)) to calculate the projected number of households. Households were then disaggregated into urban and rural subsectors, and rural households were further divided into electrified and non-electrified. Final energy uses — such as cooking, water heating, food conservation, and lighting — were then characterized in terms of coverage, efficiency, fuel share, and energy intensity (*1 **en que trabajo previo se caracterizó esto?**). Miscellaneous thermal and electrical uses were also characterized. All electrical appliances were associated with a load curve (*2 **en que trabajo previo se caracterizó esto?**).

The transport sector was sub-divided into: road (light-duty, medium-duty, and heavy-duty), rail, air, waterway, and cable car. The vehicle fleet was regionalized according to inventories provided by INE.

The industrial sector was disaggregated into large-scale and small-scale units. For small-scale units, previous sectoral surveys (*3 **hay alguna referencia?**) allowed further disaggregation into seven categories: food, beverages and tobacco; non-metallic minerals; paper, wood and furniture; machinery and metals; textiles; clothing and leather; and chemicals, plastics and pharmaceuticals. Large-scale units were classified into seven categories according to a previous sectoral survey from INE: food and beverage; cement; bricks; metals; paper, cardboard and wood; chemicals and petrochemicals; and construction materials. For this disaggregation level, we included the consumption share of different fuel types for the years 2021–2023. The fuels considered are electricity, diesel, gasoline, jet fuel, biomass, NG, and liquefied petroleum gas (LPG).

Only one energy demand growth scenario was considered in this modeling exercise. For the transport; industry; commercial and public; agriculture, fishery and mining; and construction sectors, gross domestic product (GDP) was taken as the driver of energy demand. Sub-national reports from INE allowed the regional and sectoral disaggregation of GDP. An annual growth rate of 2.8%, based on historical trends, was considered for the simulation period. For the residential sector, the number of households was taken as the




Figure 2: Current (2023) annual electricity demand (a); thermal (b), hydro (c) and wind/solar (d) installed capacity

driver of energy demand. INE projects an overall population growth of 20%, reaching a total of 13.4 million inhabitants by 2050. Data from the last census allowed the regional and urban/rural disaggregation of population. For each region, both total population and number of households were extrapolated from the base year onward, assuming that the regional proportion remains constant — an assumption that held for the 2012–2024 period. In order to project the regional urban/rural share of households, the ratio of urban-to-rural growth rates was computed. Then, an objective function was included in the projection so that the overall projected national number of urban households matched CEPAL’s projection.

An analysis of the current energy demand structure shows that electricity represents approximately 11.8% of the overall energy demand. Electricity demand within the NIS is concentrated in the Oriente region (39%), followed by Centro, Norte (22% each), and Sur (17%) (Figure 2, panel a). The most electricity-consuming sector is residential (37%), followed by industry (24%); commercial and public (23%); agriculture, fishery and mining (11%); construction (3%); and transport (0.4%).

2.4. Power supply

As mentioned above, Bolivia’s current generation mix is predominantly thermal, with hydropower as a significant secondary source. Around 70% of installed capacity is fossil-fueled, concentrated mainly in the Oriente, Centro, and Sur regions (figure 2b)), while hydro capacity is located in the Centro and Norte regions (figure 2c)). Wind and solar capacity, which together account for less than 1% of installed capacity, is concentrated in the Oriente and Centro/Sur regions (figure 2d)). Against this backdrop, this modeling exercise aims to assess the impact of expanding both centralized and distributed renewable capacity in the NIS. To this end, two centralized capacity expansion scenarios were built on top of the demand growth base scenario: Business as Usual (BAU) and Alternative (ALT). Both scenarios represent the expansion of centralized renewable capacity (wind, hydro,

and solar) following the official capacity expansion schedule for the 2024–2050 period.

The BAU scenario contemplates a short-term capacity expansion that includes a 261 MW addition of wind capacity in the Oriente region (Figures 3 and 4). It proposes the development of two hydroelectric projects: Ivirizú (291 MW), located in the Centro region and comprising two hydroelectric plants (Sehuencas and Juntas); and Miguillas (210 MW) in the Norte region, comprising two cascade hydroelectric plants, Umopalca (86 MW) and Palillada (119 MW). It also includes the addition of 340.5 MW of solar capacity in the Centro and Norte regions. NEMO optimization assigns a total endogenous capacity of 160 MW of turbo-gas (TG) units for the simulation period for this scenario. The ALT scenario contemplates a medium-term capacity expansion that adds an additional 631 MW, 1525 MW, and 1220 MW of wind, hydro, and solar capacity relative to the BAU scenario. Wind capacity additions are concentrated in the Oriente (90%) and Centro (10%) regions, and are distributed in units ranging from 25 to 100 MW. Hydro capacity additions are associated with the exploitation of the Río Grande basin, and comprise the Rositas (600 MW), La Pesca (460 MW), Cañahuecal (380 MW), and Okitas (85 MW) facilities across the Centro and Oriente regions.

All centralized capacity additions were configured in LEAP as exogenous capacity additions. Maximum availability of wind, solar, and hydro was represented by availability curves derived from historical data that display daily fluctuations. A minimum reserve margin of 30% was assigned for the NIS, and differential NG production costs across regions were configured to represent the regional availability of this resource. NEMO optimization allowed for endogenous capacity expansion when needed to meet the reserve margin requirement.

Both scenarios (BAU and ALT) were then combined with two sub-scenarios representing different Distributed Solar (DS) capacity trajectories, resulting in four scenarios in total. BAU and ALT incorporate a total of 100 MW of DS capacity by 2050, whereas BAU-DS and ALT-DS incorporate a total of 1,000 MW by 2050. DS capacity was added




Figure 3: Centralized generation capacity additions for BAU and ALT scenarios (top row), and for DS generation (below)

following logistic growth curves Joshi et al. (2025) (figure 3). DS capacity was regionally disaggregated according to current regional shares of power demand and incorporated into LEAP as a negative electricity demand source, thereby bypassing transmission and distribution losses.




Figure 4: Regional centralized capacity additions [MW] according to BAU and ALT scenarios

For each region, we analyzed the evolution of primary and secondary energy sources within the power mix, as well as hourly power flows between regions. A regional balance of electricity generation by source and net trade was also compiled for 2050. GHG emissions were compared across scenarios using 100-year global warming potential (GWP) factors and the built-in Technology and Environmental Database, which contains emission profiles for different generation technologies from the Intergovernmental Panel on Climate Change (IPCC), the US Department of Energy, and the International Energy Agency.

Finally, a total cost analysis of the power system was performed, along with a comparison between scenarios. Total costs include capital and Operation and Maintenance

Table 2

Capital and O&M costs for different power generation technologies

Technology	Capital [USD/MW]	O&M [USD/MW-yr]
TG	855	8
TV	1,800	20
Diesel	1,200	15
CC	1,400	12
Solar	1,000	22
Solar (new)	850–940	20–22
SD	1,200	20–22
Wind	1,500	36–39
Wind (new)	1,300–1,450	39
Hydro	1,500	7
Rositas (hydro)	3,350	38.8
Cachuela (hydro)	1,880	40
Rio Grande (hydro)	3,446	39.5
Other hydro	2,029	29.6

(OM) costs for different generation technologies (see Table 2), along with differential costs associated with displacing NG-based generation and DS installation costs. Capital and OM costs are incorporated into the analysis through an annual payment function that amortizes investments over time. This function accounts for equipment lifetime and the interest rate — or systemic discount rate — which was set at 12% for the entire model. Installation and OM costs for new wind and solar capacity are assumed to decline over time ?.

Regarding the opportunity cost of NG — the main input for fossil-fueled generation — non-utilized NG was assumed to be available for export at a price of 5 US\$/million BTU. A price of 120 US\$/MWh was assigned to diesel-based generation. The installation cost of DS photovoltaic panels was set at 1200 US\$/kW, comprising total capital cost and distribution adequacy costs (i.e., costs associated with reinforcing distribution infrastructure to accommodate distributed generation). Capital costs are assumed to decrease over time, while distribution adequacy costs increase, resulting in an overall installation cost that declines to 584 US\$/kW by the end of the simulation period. All values were calculated at constant 2025 prices, using the 12% discount rate described above.

2.4.1. Alternative hydro operation scheme

....

3. Results

3.1. Demand

The addition of DS (distributed generation) reduces the net power demand observed in the NIS. Comparison between scenarios (BAU-DS/ALT-DS vs. BAU/ALT) shows that an additional capacity of 900 MW of DS reduces net demand by about 9% by 2050. The net accumulated energy savings over the simulation period amount to approximately

Table 3

Current (2025) and projected (2050) annual electricity generation according to BAU, BAU-DS, ALT and ALT-DS scenarios

	current	BAU	BAU-DS	ALT	ALT-DS
Generation (Gwh)	11,430	22,410	20,610	22,256	22,122
Fossil (%)	35.6	61.7	50.6	27.2	25.5
Solar (%)	0.1	4.3	4.7	14.8	14.9
DS (%)	0	0.8	8.6	0.8	8
Wind (%)	12	6.1	6.7	14.4	14.5
Hydro (%)	47.1	27.1	29.5	42.8	37.1

22,000 and 25,000 GWh, respectively, representing nearly twice the total annual demand of the base year.

3.2. Power supply

During the simulation period, NEMO assigned a total endogenous capacity of 160 MW of turbo-gas (TG) units under the BAU scenario, whereas no endogenous capacity expansion was observed under ALT.

Regarding power generation, the addition of DS capacity coincides with a decrease in thermal generation in both the BAU and BAU-DS scenarios. In the first scenario, DS generation represents less than 1% of annual generation by 2050, while thermal generation escalates from 36% in the base year to 61% (table 3). In the second scenario, by contrast, DS generation represents nearly 9% of annual generation by 2050, while thermal generation only escalates to 51%. For the ALT and ALT-DS scenarios, there is a marked reduction in thermal generation, reaching 27% and 26% of annual generation by 2050, respectively, though this reduction is mostly associated with the massive deployment of centralized renewable capacity. The addition of 900 MW of DS (comparing ALT and ALT-DS) coincides with a reduction in hydro generation (42% of annual generation in ALT vs. 37% in ALT-DS).

The addition of DS capacity produces positive externalities in terms of fuel savings and GHG emissions. An additional 900 MW of DS capacity produces greater fuel savings for the BAU scenario than for the ALT scenario. Fuel savings for the BAU-DS scenario reach 960 kBEP annually by 2050 compared to BAU, with accumulated savings of 15,000 kBEP over the simulation period — nearly the total inputs for power generation in the base year. For the ALT-DS scenario, by contrast, accumulated savings total only 1,930 kBEP compared to ALT. GHG emissions follow a similar pattern: accumulated emission savings are greater for the BAU-DS scenario compared to BAU (9,900,000 metric tonnes of CO₂-equivalent) than when comparing the ALT-DS scenario with ALT (1,170,000 metric tonnes of CO₂-equivalent).

Overall costs related to the NIS present differences across scenarios. Costs are higher for the ALT scenario (1,600 million USD) than for the BAU scenario. Fuel-related savings of around 1,000 million USD are exceeded by higher

Table 4

Costs (BAU ALT scenarios) and differential costs (BAU-DS ALT-DS scenarios). Values are expressed in MM USD

	BAU	(BAU-DS) -BAU	ALT	(ALT-DS) -ALT
Fuel	2,227	-171	1,192	-25
Capital + O&M	6,963	-1	11,605	-128
DS panels	39	360	39	360
Total	9,230	185	12,837	206

capital costs (see Table 4). The addition of DS capacity produces modest increases in overall costs: 185 and 206 million USD for BAU-DS and ALT-DS compared with BAU and ALT, respectively. Savings related to fuel replacement are higher for BAU-DS, since DS generation replaces thermal generation. In ALT-DS, by contrast, DS generation displaces a higher proportion of centralized renewable generation.

3.2.1. Regional power generation and trade projections

As mentioned earlier, the regionalized model of Bolivia's energy system includes electricity exchanges between regions, for which the main transmission lines have been represented. This section presents an hourly analysis of power flows between regions for three time slices (years 2030, 2040, and 2050), together with the evolution of power generation sources over the simulation period. Simulated power flows did not exceed the maximum transmission line capacities during the simulation period. Different capacity thresholds were configured and tested in sensitivity scenarios, and results showed no differences compared to the reference scenarios.

For the BAU scenario, in the first time slice it can be observed that the Centro region — where hydroelectric generation predominates (first row in figure 6) — is the main electricity exporter (first and third rows in figure 5), followed by the Oriente region during early morning hours in the dry season. Exports are directed toward the Sur region, except during dry-season early morning hours—when the Norte region becomes an importer—and during midday and afternoon periods—when Oriente becomes an importer. In both regions, generation is predominantly thermal.

The second time slice, 2040, shows similar daily export features, and the Sur region adds exports during nighttime and morning hours for both dry and humid seasons. The Norte region imports energy throughout the day, imports are greatly diminished in the Oriente region compared to the first time slice, and the Sur region imports around noon hours. This displacement of Sur by Norte as the main importer of energy responds to the fact that NEMO augments thermal-based generation in the Sur region (5,000 GWh) due to greater availability of NG and thermal generation capacity in this region, while overall capacity remains nearly unchanged in the Norte region. In this way, the Centro region acts as a transit node between Sur and Norte. An increase in thermal generation is also observed in the Oriente region (7,000




Figure 5: Daily profiles of inter regional exports and imports of power flow for BAU scenario (first and third row), and differences for BAU-DS scenario (second and fourth row)

to 10,000 GWh), which appears to be destined for local demand.

For 2050, almost all exports are made from the Centro region, while imports are directed mainly to Norte, followed by Oriente. Overall generation barely increases for this time slice in Norte. The observed increase in thermal generation in Oriente (from approximately 10,000 GWh to 15,000 GWh) does not appear sufficient to meet regional demand, which is instead covered by imports from Centro.

Additional 900 MW of DS capacity (BAU-DS scenario) translates into modifications in both daily exports/imports and generation features across regions. For 2030, there are marginal increases in exports during solar generation hours from the Norte region, whose generation is predominantly renewable (second and fourth rows in figure 5, and lower row in figure 6). There is also an increase in imports directed to Oriente, which coincides with a local decrease in thermal generation. Centro might be acting as a transit node between Norte and Oriente. Daily exports of around 200 MWh/day are observed from Sur to Centro during the dry season.

For 2040, the addition of extra DS capacity produces an increase in exports from the Centro region (hydro-dominated generation). Imports are diminished in the Norte region (also hydro-dominated), while increasing in Oriente and Sur, whose annual thermal generation is in turn reduced by approximately 1,500 and 1,000 GWh, respectively.

Finally, for the year 2050, the BAU-DS scenario foresees diminished thermal generation in the Centro, Oriente, and

Sur regions. Besides, imports during photovoltaic generation hours are diminished in the Norte and Oriente regions. These decreases in imports to Norte and Oriente are, in part, compensated by an increase in imports from Sur, whose generation share is entirely thermal.

For the ALT scenario, interregional power flows vary across seasons and time of day. For the year 2030, Oriente and Sur are the main electricity exporters during the dry season, (top row in figure 7), sending power to Norte region between 00:00 and 18:00 h. After 18:00 h, exports originate mainly from Oriente and are directed toward Sur region. During the wet season, energy flows from Oriente and Centro toward Sur region, except during solar production hours, when the high share of photovoltaic generation in Sur (top row in figure 8) produces a surplus that is instead exported toward Norte region. It is also worth noting the substantial hydro and wind generation output of Oriente region in this scenario, which underpins its role as a net exporter throughout the year.

For the year 2040 Oriente and Sur are still the main electricity exporting regions showing a similar daily scheme to 2030. Exports are directed towards the Norte region, whose overall generation barely varies since 2030 (Figure 8). Imports from the Sur region during nighttime hours in the humid season cease.

Distinct interregional trade patterns emerge during non-solar and solar generation hours at the end of the simulation period. During non-solar generation hours, energy flows




Figure 6: Evolution of regional projected annual electricity generation according to BAU scenario (upper row), and differences for BAU-DS scenario (lower row)




Figure 7: Daily profiles of inter regional exports and imports of power flow for ALT scenario (first and third row), and differences for ALT-DS scenario (second and fourth row)

from Centro and Oriente towards the Norte region. During solar generation hours, Centro and Sur—whose solar generation is the greatest among the regions—export electricity to Norte and Oriente, the latter having no centralized solar generation.

The additional 900 MW of DS capacity in the ALT-DS scenario, compared to BAU-DS, leads to different effects due to the overall higher renewable installed capacity. This produces greater temporal overlap between renewable generation sources, reducing hydro output (bottom row in figure 8). For 2030, exports from Oriente and imports from Centro and Sur decrease during solar production hours. During the dry season, morning imports shift from Sur to Oriente (bottom row in figure 7). Compared to the ALT scenario,

hydro generation is reduced in the Norte, Centro, and Oriente regions, while thermal generation is displaced in Sur.

During 2040, exports from the Centro region increase, while imports switch from Norte to Oriente during solar production hours. Hydro generation diminishes in the Oriente region compared to 2030. There are also small reductions in wind generation (Oriente) and centralized solar generation (Sur). Finally, during 2050, there is an overall decrease in imports from the Oriente and Norte regions during solar production hours. Hydro generation is further reduced in the Centro region, while the Oriente and Sur regions experience a reduction in thermal generation.




Figure 8: Evolution of regional projected annual electricity generation according to ALT scenario (upper row), and differences for ALT-DS scenario (lower row)




Figure 9: Difference in hourly power output of centralized generation units between BAU-DS/ALT-DS and BAU/ALT scenarios

3.3. Energy curtailment

One of the most salient results of the simulation is the impact of DS penetration on the output of centralized generation units in the ALT scenario. This scenario includes higher centralized renewable capacity than the BAU scenario, and the additional DS generation overlaps in time with that centralized renewable supply. Notably, total centralized capacity remains constant across the ALT and ALT-DS scenarios, but DS generation changes their utilization patterns.

In the BAU scenario, the addition of 900 MW of DS capacity (left side of Figure 9) leads to a reduction in thermal generation of approximately 760 GWh/year by 2050, whereas in the ALT-DS scenario, DS penetration instead displaces renewable generation. Total displaced energy amounts and the fuel share are similar between seasons. By 2030, curtailment of renewable generation (mostly hydro) reaches approximately 670 MWh/day, which increases to 1800 MWh/day from 2040 onwards. The percentage of curtailed renewable generation reaches a peak of 35% after 2030 and then gradually descends to 12% at the end of the simulation period (left panel in figure...)

These preliminary results motivated a more in-depth analysis of the NIS's dispatch and management of future

power generation considering that: a large share of the renewable capacity contemplated in the ALT scenario is planned to be installed within a 5-year horizon (Figure 3).

Current curtailment mitigation strategies include increased flexibility in power generation, demand-side management, regional complementarity and the use of energy storage in batteries or hydroelectric reservoirs Li et al. (2015); Bird et al. (2016); Denholm and Mai (2019), among others.

Hydroelectricity, in particular, provides excellent flexibility services along with low operational costs Liu and He (2023). In addition, reservoir hydroelectricity can further reduce renewable curtailment by allowing time-shifting generation. Therefore, power grids with a high penetration of reservoir hydroelectricity present additional advantages when dealing with the integration of variable renewable energies Wan and Parsons (1993); ?. Hydroelectricity represents around 50% of Bolivia's current electricity generation (Table 3), and important hydro capacity additions are contemplated in national expansion plans (Figures 3 and 4). An alternative daily dispatch scheme for hydroelectricity has been designed for Bolivia's power sector, and evaluated in terms of impacts in energy curtailment. As described in the

methodology section, this implied a thorough analysis of historical hydro generation profiles and stored water levels, and shifting from an existing load-demand oriented operation scheme to a balancing-oriented hydropower operation scheme.

4. Conclusions

This paper presents a modeling exercise of Bolivia's energy system using the LEAP model, with a particular focus on renewable penetration scenarios. Results provide valuable insights concerning long-term energy planning and power dispatch schemes. To begin with, the addition of 900 MW of extra DS capacity leads to reductions in annual electricity demand of around 8%. Positive externalities related to the expansion of DS capacity, which include reductions in CO₂e emissions and fossil fuel savings, are greater in the BAU-DS scenario-compared with ALT-DS scenario-, in which DS generation displaces thermal generation.

Overall accumulated costs associated with the power system are greater for the ALT scenario (+40%), which is explained by higher capital costs. The addition of 900 MW of extra DS capacity increases overall costs by 2% and 1.6% for the BAU and ALT scenarios, respectively. In both cases, installation costs exceed fuel, capital, and O&M related savings.

Another novel aspect of this work was the development, for the first time, of a regionalized LEAP/NEMO energy model for Bolivia. This allowed the study of regional power generation and power flows within the NIS, and their response to different renewable capacity addition scenarios. Transmission capacities considered in this study do not seem to represent bottlenecks for the evolution of inter-regional power trade throughout the simulation period. The Centro region stood out as the leading electricity exporter in the BAU scenario. Interannual trend-related growth in electricity demand drives increases in thermal generation in the Centro, Sur and Oriente regions, while generation in the Norte region remains nearly constant throughout the simulation period. Exports are directed towards the Oriente and Sur regions at the beginning of the simulation period, then shift towards the Norte region. In the BAU-DS scenario, imports from the Norte region are reduced during solar production hours, and thermal generation also diminishes in the Centro, Oriente and Sur regions. In the ALT scenario, the Oriente region becomes an electricity exporter (along with the Centro region) due to considerable renewable capacity additions. Exports are directed towards the Sur region. In the ALT-DS scenario, the addition of DS capacity results in a smaller reduction in thermal generation compared with the BAU-DS scenario, while causing a larger reduction in the share of hydro generation in the Centro and Oriente regions.

Results reveal that high levels of energy curtailment can arise in ambitious renewable capacity expansion plans. The hypothetical, but plausible, addition of DS capacity will further aggravate this problem. This issue is evident in the ALT-DS scenario, where an additional 900 MW of DS

capacity contributes to an overall oversupply and curtailment of around 30% of renewable output.

This motivated the formulation of an alternative hydro-electric operation scheme that, making use of Bolivia's high installed hydro capacity, shifts the current load-following-oriented paradigm to a balancing-oriented scheme.

CRedit authorship contribution statement

Emilio Bianchi: Formal analysis, Investigation, Methodology, Visualization, Writing 1–original draft. **Gonzalo Bravo:** Funding acquisition, Project administration. **Francisco Lallana:** Conceptualization, Funding acquisition, Investigation, Methodology, Supervision, Validation. **Gustavo Nadal:** Conceptualization, Funding acquisition, Investigation, Methodology, Supervision. **Ignacio Sagardoy:** Conceptualization, Formal analysis, Investigation, Methodology, Validation. **Ignacio Sagardoy:** Conceptualization of this study, Methodology, Software.

References

- Agency, I.R.E., 2019. Future of Solar Photovoltaic-Deployment Investment Technology Grid Integration and Socio-Economic Aspects. International Renewable Energy Agency IRENA.
- Autoridad de Fiscalización de Electricidad y Tecnología Nuclear (AETN), 2026. Datos y estadísticas. <https://aetn.gob.bo/datos-y-estadisticas/>. Accessed: 2026-06-30.
- Balderrama, J.G.P., Broad, O., Sevillano, R.C., Alejo, L., Howells, M., 2017. Techno-economic demand projections and scenarios for the bolivian energy system. *Energy strategy reviews* 16, 96–109.
- Ballvian Cabrera, M., 2024. Embracing the energy transition: Bolivia's challenges and opportunities, in: Kariuki, J.M. (Ed.), *Energía Progresiva*. Springer, Cham. doi:10.1007/978-3-031-68846-1_15.
- Bhattacharai, U., Maraseni, T., Apan, A., 2022. Assay of renewable energy transition: A systematic literature review. *Science of The Total Environment* 833, 155159.
- Bird, L., Lew, D., Milligan, M., Carlini, E.M., Estanqueiro, A., Flynn, D., Gomez-Lazaro, E., Holttinen, H., Menemenlis, N., Orth, A., et al., 2016. Wind and solar energy curtailment: A review of international experience. *Renewable and Sustainable Energy Reviews* 65, 577–586.
- Casella, G., 2020. Power flow constraints in open-source energy system modelling: application to the bolivian transmission network.
- Chueca, E., Weiss, M., Celaya, R., Ravillard, P., Ortega, B., Tolmasquim, M.T., Hallack, M., 2023. Early adopters of residential solar pv distributed generation: Evidence from brazil, chile and mexico. *Energy for Sustainable Development* 76, 101284.
- Denholm, P., Mai, T., 2019. Timescales of energy storage needed for reducing renewable energy curtailment. *Renewable energy* 130, 388–399.
- Denholm, P., O'Connell, M., Brinkman, G., Jorgenson, J., 2015. Overgeneration from solar energy in california. a field guide to the duck chart. Technical Report. National Renewable Energy Lab.(NREL), Golden, CO (United States).
- Emodi, N.V., Emodi, C.C., Murthy, G.P., Emodi, A.S.A., 2017. Energy policy for low carbon development in nigeria: A leap model application. *Renewable and Sustainable Energy Reviews* 68, 247–261.
- Farfan, J., Breyer, C., 2017. Structural changes of global power generation capacity towards sustainability and the risk of stranded investments supported by a sustainability indicator. *Journal of Cleaner Production* 141, 370–384.
- Fernandez Vazquez, C.A.A., Vansighen, T., Fernandez Fuentes, M.H., Quoilin, S., 2022. Energy transition in bolivia. modelling of the bolivian energy sector to achieve carbon neutrality by 2050, in: 3rd Latin American Conference on Sustainable Development of Energy, Water and Environment Systems—LA SDEWES, International Centre for Sustainable Development of Energy, Water and ...
- Fleiter, T., Worrell, E., Eichhammer, W., 2011. Barriers to energy efficiency in industrial bottom-up energy demand models—a review. *Renewable and sustainable energy reviews* 15, 3099–3111.
- Handayani, K., Overland, I., Suryadi, B., Vakulchuk, R., 2023. Integrating 100% renewable energy into electricity systems: a net-zero analysis for cambodia, laos, and myanmar. *energy rep* 10: 4849–4869.
- Hassan, Q., Algburi, S., Sameen, A.Z., Al-Musawi, T.J., Al-Jiboory, A.K., Salman, H.M., Ali, B.M., Jaszczur, M., 2024. A comprehensive review of international renewable energy growth. *Energy and built environment*.
- Heaps, C.G., 2022. Leap: The low emissions analysis platform. URL: <https://leap.sei.org>. software version 2020.1.64.
- Hingray, B., Favre, A.C., Sauquet, E., Anquetin, S., 2014. Integrating hydropower and intermittent climate-related renewable energies: a call for hydrology. *Hydrological Processes*.
- Huallpara, A., Navia Orellana, M.A., Gomand, I., Balderrama, S., Pavičević, M., Quoilin, S., 2023. Comparative analysis of dynamic and linear programming energy systems models applied to the bolivian power system, in: 36th International Conference on Efficiency, Cost, Optimization, Simulation and Environmental Impact of Energy Systems, ECOS 2023, Las Palmas de Gran Canaria, Unknown/unspecified.
- Huntington, H.G., Weyant, J.P., Sweeney, J.L., 1982. Modeling for insights, not numbers: the experiences of the energy modeling forum. *Omega* 10, 449–462.
- Instituto Nacional de Estadística de Bolivia, 2024. Censo de población y vivienda 2024 (cpv 2024). URL: <https://cpv2024.ine.gob.bo/>.
- International Energy Agency, 2023. Latin America Energy Outlook 2023. Technical Report. International Energy Agency (IEA). Paris. URL: <https://www.iea.org/reports/latin-america-energy-outlook-2023>. licence: CC BY 4.0.
- IRENA, 2025. Renewable Capacity Statistics 2025. Technical Report. International Renewable Energy Agency. Abu Dhabi. URL: https://www.irena.org/-/media/Files/IRENA/Agency/Publication/2025/Mar/IRENA_DAT_RE_Capacity_Statistics_2025.pdf.
- Jäger-Waldau, A., 2025. Snapshot of photovoltaics- march 2025. *EPI Photovoltaics* 16, 22.
- Joshi, P., Rao, A.B., Banerjee, R., 2025. Review of solar pv deployment trends, policy instruments, and growth projections in china, the united states, and india. *Renewable and Sustainable Energy Reviews* 213, 115436.
- Li, C., Shi, H., Cao, Y., Wang, J., Kuang, Y., Tan, Y., Wei, J., 2015. Comprehensive review of renewable energy curtailment and avoidance: A specific example in china. *Renewable and Sustainable Energy Reviews* 41, 1067–1079.
- Li, J., Wang, C., Guo, J., Xin, Y., Zhang, N., Liu, X., Feng, K., 2024. Promoting sustainable development goals by optimizing city-level solar photovoltaic deployment in china. *Environmental Science & Technology* 58, 5196–5209.
- Liu, Z., He, X., 2023. Balancing-oriented hydropower operation makes the clean energy transition more affordable and simultaneously boosts water security. *Nature Water* 1, 778–789.
- Manservigi, L., Castorino, G.A.M., Spina, P.R., Venturini, M., Gonzalez-Salazar, M., 2026. Unlocking the future of solar pv in europe: high-resolution supply curves for decarbonizing the energy sector. *Renewable Energy*, 125809.
- Ming, Z., Kun, Z., Jun, D., 2013. Overall review of china's wind power industry: Status quo, existing problems and perspective for future development. *Renewable and Sustainable Energy Reviews* 24, 379–386.
- Ministerio de Hidrocarburos y Energías, Viceministerio de Planificación y Desarrollo Energético, 2023. Balance Energético Nacional a Nivel Departamental 2023. Balance Energético Departamental. Ministerio de Hidrocarburos y Energías (MHE), Estado Plurinacional de Bolivia. La Paz, Bolivia. URL: <https://www.mhe.gob.bo/wp-content/uploads/2025/03/BED-2023-FINAL-1-low.pdf>. accessed: 2026-07-06.
- Ministerio de Hidrocarburos y Energías, Viceministerio de Planificación y Desarrollo Energético, 2024. Balance Energético Nacional 2020–2024. Balance Energético Nacional. Ministerio de Hidrocarburos y Energías (MHE), Estado Plurinacional de Bolivia. La Paz, Bolivia. URL: <https://www.mhe.gob.bo/wp-content/uploads/2025/10/Version-Final-BEN-2020-2024-low0.pdf>. accessed: 2026-07-06.

- Ministerio de Medio Ambiente y Agua, Autoridad Plurinacional de la Madre Tierra, 2021. Actualización de la Contribución Nacionalmente Determinada (CND) del Estado Plurinacional de Bolivia 2021-2030. Nationally Determined Contribution. Estado Plurinacional de Bolivia. URL: <https://unfccc.int/sites/default/files/NDC/2022-06/CND%20Bolivia%202021-2030.pdf>. submitted to UNFCCC.
- Nejla, E., Saidani, K., Besbes, M., 2025. Overcoming the integration bottleneck: a global review of renewable energy and grid adaptation strategies. *International Journal of Sustainable Energy* 44, 2569922.
- O'Shaughnessy, E., Cruce, J.R., Xu, K., 2020. Too much of a good thing? global trends in the curtailment of solar pv. *Solar Energy* 208, 1068–1077.
- von Papp, J., Moraga, F., Henríquez, A., 2022. Vertimiento de energía de centrales eólicas y solares fotovoltaicas del sistema eléctrico nacional (sen) en Chile durante 2022. Recuperado de: <https://www.fraunhofer.cl/es/publicaciones/whitepapers/vertimiento-energia-centrales-eolicas-y-solares-fotovoltaicas-delsistema-electrico-nacional-2022.html>.
- Pfenninger, S., Hawkes, A., Keirstead, J., 2014. Energy systems modeling for twenty-first century energy challenges. *Renewable and sustainable energy reviews* 33, 74–86.
- da Ponte, G.P., Rego, E.E., Júnior, F.A.d.A.P., 2025. Regulatory barriers to battery storage integration in Brazil: moving beyond curtailment challenges. *Academia Green Energy* 2.
- Raturi, A.K., 2021. Renewables 2021 global status report.
- Rogan, F., Cahill, C.J., Daly, H.E., Dineen, D., Deane, J., Heaps, C., Welsch, M., Howells, M., Bazilian, M., Ó Gallachóir, B.P., 2014. Leaps and bounds—an energy demand and constraint optimised model of the Irish energy system. *Energy Efficiency* 7, 441–466.
- Shahbaz, M., Siddiqui, A., Siddiqui, M., Jiao, Z., Kautish, P., 2023. Exploring the growth of sustainable energy technologies: A review. *Sustainable Energy Technologies and Assessments* 57, 103157.
- Shahid, M., Ullah, K., Imran, K., Mahmood, A., Arentsen, M., 2021. Leap simulated economic evaluation of sustainable scenarios to fulfill the regional electricity demand in Pakistan. *Sustainable Energy Technologies and Assessments* 46, 101292.
- Silva, W.N., Renolphi, I.B., Vieira, G.G., Lourenço, L.F., Salles, M.B., Monaro, R.M., 2025. Wind and solar curtailment in Brazil: Quantifying grid constraints in the energy transition, in: 2025 16th IEEE International Conference on Industry Applications (INDUSCON), IEEE, pp. 01–08.
- Silva, W.N., Vieira, G.G., Rego, E.E., Simone, L.F., Lourenço, L.F., Salles, M.B., 2026. Curtailment pressures and grid flexibility in Brazil: Lessons from the fast-rising distributed generation. *Utilities Policy* 99, 102148.
- Stockholm Environment Institute, 2026. Nemo: The next energy modeling system for optimization. URL: <https://github.com/sei-international/NemoMod.jl>. software version 2.6.
- Suárez, W., 2025. Reducing Curtailment in Chile: Key to Unlocking the Full Potential of Renewable Energy. Technical Report. Ember.
- Viceministerio de Electricidad y Energías Renovables, 2025. Plan Eléctrico Referencial del Estado Plurinacional de Bolivia 2025-2035. Technical Report. Ministerio de Hidrocarburos y Energía (MHE). URL: <https://www.mhe.gob.bo/wp-content/uploads/2025/10/PLAN-ELECTRICO-REFERENCIAL-2035-FINAL.pdf>.
- Wan, Y.h., Parsons, B.K., 1993. Factors relevant to utility integration of intermittent renewable technologies. Technical Report. National Renewable Energy Lab., Golden, CO (United States).