



ADDENDUM # 2

DATE: **September 11, 2026**

PROJECT: Green Road Community Center HVAC Renovations
IMEG #25007326.01
City of Raleigh # 274-ESIFS-GRHVR-2021

BID DUE DATE: **September 22, 2026 at 1:00 PM**

ENGINEER: IMEG Consultants Corp.
3221 Blue Ridge Road, Suite 113
Raleigh, NC 27612

TO: All Contract Document Holders of Record.



This Addendum forms a part of the bidding and construction documents. This Addendum supersedes and supplements all portions of the original bidding and construction documents dated **August 13, 2026**, with which it conflicts. Please attach this Addendum to the Project Manual(s) in your possession.

ACKNOWLEDGE RECEIPT OF THIS ADDENDUM IN THE SPACE PROVIDED ON THE BID FORM. FAILURE TO DO SO MAY SUBJECT BIDDER TO DISQUALIFICATION.

1. Ligated damages will be assessed at \$500 per calendar day for any portion of day that work is not substantially complete by May 14, 2027.
2. Controls points listed on the BAS drawings are a combination of field mounted devices and internal control points. External and Internal control points are to be visible thru BACnet IP controller. The contractor shall provide material and labor required to field mount devices as required for complete and operational system.
3. BACnet MSTP connection will only be allowed for the existing AC-4 unit to be reused and connected to the new BAS. All other integration shall utilize BACnet IP.
4. Existing unit AC-4 shall have coils cleaned, fan checked and filters replaced as part of the project.
5. Brand of the Fabric ductwork in the gym to be removed, cleaned and reinstalled is unknown. It was originally specified to be Ductsox, Air Sox or KE Fibertec. Contractor shall provide labor necessary to remove, clean and reinstall ductwork as required.

6.
END OF ADDENDUM 2

\\files\Active\Projects\2025\25006703.00\BidPhase\20260320 Addendum 1.docx

Attachments: None