Bicknell Builds

Weekly Jobsite Inspection Form

Project: **Supervisor:** **Date:**

Inspection Item	Details Verified	Condition Acceptable
Power lines	Minimum 10’ clearance required from working area.	◯ Yes ◯ No ◯ N/A
Trench/excavation	Any trench four feet or must be sloped, shored or braced.	◯ Yes ◯ No ◯ N/A
Guardrails	All openings four feet or more above ground level must be guarded	◯ Yes ◯ No ◯ N/A
Standard guardrail	Top rail = 39” to 45” above working surface. Midrail = halfway between top rail and floor. Toeboard = 4”.	◯ Yes ◯ No ◯ N/A
Scaffold	Fully planked with fall protection for fall hazards over 10 feet.	◯ Yes ◯ No ◯ N/A
Stairs	Four or more risers must have handrails.	◯ Yes ◯ No ◯ N/A
Fall Protection	All fall hazards greater than 4' secured.	◯ Yes ◯ No ◯ N/A
Miter/Chop Saws	Cutting head returns to starting position, guard in working order.	◯ Yes ◯ No ◯ N/A
Table Saws	Anti-kickback, push stick, guard in working order.	◯ Yes ◯ No ◯ N/A
Circular Saws	Blade guard instantly returns to covering position.	◯ Yes ◯ No ◯ N/A
Angle Grinders	180-degree guard in working order.	◯ Yes ◯ No ◯ N/A
Ladders	Extended 36" above landing and secured.	◯ Yes ◯ No ◯ N/A
Floor Holes & Openings	Covered and secured; be sure no tripping hazards in the area.	◯ Yes ◯ No ◯ N/A
Extension Cords & Power Tools	All cords undamaged.	◯ Yes ◯ No ◯ N/A

Hard Hats	Readily accessible at all times; worn when overhead hazard exists.	◯ **Yes**	◯ **No**	◯ **N/A**
PPE	Head, eye, ear, respiratory, and leg protection – high visibility vests when required.	◯ **Yes**	◯ **No**	◯ **N/A**
Housekeeping	Worksite in orderly condition.	◯ **Yes**	◯ **No**	◯ **N/A**
First Aid Kit & Fire Extinguishers	Readily accessible and in good working order.	◯ **Yes**	◯ **No**	◯ **N/A**
First Aid Trained Personnel	Minimum of one person on-site at all times with First Aid/CPR training.	◯ **Yes**	◯ **No**	◯ **N/A**
Site Specific Safety Plan	Complete & accessible by all workers on site.	◯ **Yes**	◯ **No**	◯ **N/A**
Weekly Safety Meetings	Orientation & weekly meeting minutes present and up to date.	◯ **Yes**	◯ **No**	◯ **N/A**

Corrections Needed:

Supervisor Signature/Date:	