

Application for Permit

Pool Data Sheet

General Pool Information			
Name of Pool:			
Civic Address:			
Pool Type: ☐ public ☐ commercial ☐ hot tub ☐ spray pool ☐ wading pool			Location: ☐ indoor ☐ outdoor
Owner Information			
Name (Legal):			
Address:			
Phone Number:		Email Address:	
General Pool Design Parameters			
Water Depth Minimum (m):	Water Depth Maximum (m):	Pool Area (m ²):	Deck Area (m ²):
Pool Volume (m ³):	Pool Basin Colour:	Design Flow Rate (L/min):	Turnover Rate (hours):
Maximum Bathing Load (persons): Shallow: Deep: Total:			
Recirculation Pumps			
RECIRCULATION PUMP	Make and Model:	Flow (L/min): at m TDH	
HOT TUB JET PUMP	Make and Model:	Flow (L/min): at m TDH	
PUMP (specify):	Make and Model:	Flow (L/min): at m TDH	
PUMP (specify):	Make and Model:	Flow (L/min): at m TDH	
PUMP (specify):	Make and Model:	Flow (L/min): at m TDH	

Note: A preliminary version of the pool data sheet (Appendix B) should be submitted with the Application for Construction Permit. If parameters change, the pool data sheet should be resubmitted with the updated actual operating information and recalculations if required when applying for an Operating Permit.

Application for Permit

Pool Data Sheet

Filtration System				
Filter Type: ☐ sand ☐ diatomaceous earth ☐ pressure ☐ vacuum ☐ gravity			NSF Approved: ☐ yes ☐ no	NSF Standard:
Filter Make and Model:			Number of Filters:	Number of Elements:
Surface Area of Each Filter (m ²):	Total Area of All Filters (m ²):	Surface Area of Each Element (m ²):	Total Area of All Elements (m ²):	
Rate of Filtration (L/min/m ²):		Total Filter Capacity (L/min) (<i>Rate of filtration x total area</i>):		
FILTER BACKWASH	Filter Backwash Pump Make and Model:			
	Flow (L/min): at m TDH	Backwash Rate (L/min/m ²):	Backwash Rate per Filter (L/min):	
Gauges				
Pressure Gauges (#):		Vacuum Gauges (#):	Temperature Gauges (#):	
Flow Meter Make and Model:			Flow Meter Range (L/min): to	
Disinfection				
Primary Disinfectant: ☐ hypochlorite ☐ chlorine gas ☐ stabilized chlorine ☐ saltwater chlorination ☐ bromine ☐ other:				
Disinfectant Feeder Make and Model:				
Disinfectant Feeder Capacity (kg/24 hrs):		Point of Injection: ☐ filter influent ☐ filter effluent	Maximum Dosing Rate (mg/L):	
Chemical Feeders				
FEEDER #1	Make and Model:			
	Chemical/Slurry Fed:	Capacity (kg/24 hrs):	Injection Point:	
FEEDER #2	Make and Model:			
	Chemical/Slurry Fed:	Capacity (kg/24 hrs):	Injection Point:	

Application for Permit

Pool Data Sheet

Pool Inlets					
Inlet Type:	Inlet Size (cm):	Number of Inlets: at m spacing	Depth Below Water Level (cm):		
Drains					
Total Number of Drains:					
MAIN DRAIN	Make and Model:				
	Number:	Size of Free Opening (cm ²):	Velocity through Grate Opening (m/sec):		
JET PUMP DRAIN (if separate from main drain)	Make and Model:				
	Number:	Size of Free Opening (cm ²):	Velocity through Grate Opening (m/sec):		
OTHER DRAIN (specify)	Make and Model:				
	Number:	Size of Free Opening (cm ²):	Velocity through Grate Opening (m/sec):		
OTHER DRAIN (specify)	Make and Model:				
	Number:	Size of Free Opening (cm ²):	Velocity through Grate Opening (m/sec):		
OTHER DRAIN (specify)	Make and Model:				
	Number:	Size of Free Opening (cm ²):	Velocity through Grate Opening (m/sec):		
Overflow (Skimmers/Gutters)					
Overflow Type: ☐ skimmer ☐ raised-edge gutter ☐ roll-out gutter ☐ deck-level gutter ☐ other:					
GUTTERS	Number of Gutter Drains (m spacing):		Gutter Drain Size (cm):		
SKIMMERS	Make and Model:				
	Quantity:	NSF Approved: ☐ yes ☐ no	Total Weir Length (cm):	Maximum Overflow Capacity (L/min):	Normal Flow Through Capacity (L/min):

Application for Permit

Pool Data Sheet

Make Up Water Source

Source: ☐ public ☐ private	Size of Makeup Line (cm):	Control: ☐ manual ☐ automatic	Air Gap: ☐ yes ☐ no
Backflow Preventer: ☐ yes ☐ no	Backflow Preventer Make and Model:		

Piping (Add extra pages if needed)

SYSTEM #1	System/Liquid Carried:	Material: ☐ copper ☐ carbon steel ☐ PVC ☐ HDPE ☐ other:		
	Maximum Velocity (m/sec):	Return piping to pool:	Supply piping to pool:	
SYSTEM #2	System/Liquid Carried:	Material: ☐ copper ☐ carbon steel ☐ PVC ☐ HDPE ☐ other:		
	Maximum Velocity (m/sec):	Return piping to pool:	Supply piping to pool:	
SYSTEM #3	System/Liquid Carried:	Material: ☐ copper ☐ carbon steel ☐ PVC ☐ HDPE ☐ other:		
	Maximum Velocity (m/sec):	Return piping to pool:	Supply piping to pool:	

Data Sheet Revision History

Version	Prepared By	Company	Date	Revision Details