

Application for Permit

Pool Data Sheet

General Pool Information			
Name of Pool: Sunstone Leisure Pool			
Civic Address: 10720 Delsom Crescent, Delta, BC, V4C 2L2			
Pool Type: ☐ public ☒ commercial ☐ hot tub ☐ spray pool ☐ wading pool			Location: ☐ indoor ☒ outdoor
Owner Information			
Name (Legal):			
Address:			
Phone Number:		Email Address:	
General Pool Design Parameters			
Water Depth Minimum (m): 1	Water Depth Maximum (m): 1.52	Pool Area (m ²): 111	Deck Area (m ²):
Pool Volume (m ³): 126	Pool Basin Colour: White	Design Flow Rate (L/min): 4013	Turnover Rate (hours): 5.22
Maximum Bathing Load (persons): Shallow: 119 Deep: Total: 119			
Recirculation Pumps			
RECIRCULATION PUMP	Make and Model:	Flow (L/min): at m TDH	
HOT TUB JET PUMP	Make and Model:	Flow (L/min): at m TDH	
PUMP (specify):	Make and Model:	Flow (L/min): at m TDH	
PUMP (specify):	Make and Model:	Flow (L/min): at m TDH	
PUMP (specify):	Make and Model:	Flow (L/min): at m TDH	

Note: A preliminary version of the pool data sheet (Appendix B) should be submitted with the Application for Construction Permit. If parameters change, the pool data sheet should be resubmitted with the updated actual operating information and recalculations if required when applying for an Operating Permit.

Application for Permit

Pool Data Sheet

Filtration System				
Filter Type: ☒ sand ☐ diatomaceous earth ☐ pressure ☐ vacuum ☐ gravity			NSF Approved: ☒ yes ☐ no	NSF Standard: 50
Filter Make and Model: Pentair/TR140C			Number of Filters: 1	Number of Elements: 1
Surface Area of Each Filter (m²): 0.66	Total Area of All Filters (m²): 0.66	Surface Area of Each Element (m²): 0.66	Total Area of All Elements (m²): 0.66	
Rate of Filtration (L/min/m²): 607		Total Filter Capacity (L/min) (<i>Rate of filtration x total area</i>): 401		
FILTER BACKWASH	Filter Backwash Pump Make and Model: test			
	Flow (L/min): 300 at 20 m TDH	Backwash Rate (L/min/m²): 400	Backwash Rate per Filter (L/min): 400	
Gauges				
Pressure Gauges (#): 4		Vacuum Gauges (#): 2	Temperature Gauges (#): 1	
Flow Meter Make and Model: FM-101: Flovis FV3, Range: 10-110 FM-102/103: Flovis FV2, Range: 90-220			Flow Meter Range (L/min): to	
Disinfection				
Primary Disinfectant: ☐ hypochlorite ☐ chlorine gas ☐ stabilized chlorine ☒ saltwater chlorination ☐ bromine ☐ other: test				
Disinfectant Feeder Make and Model: Hayward HCSC60				
Disinfectant Feeder Capacity (kg/24 hrs): 2.26		Point of Injection: ☐ filter influent ☒ filter effluent	Maximum Dosing Rate (mg/L): 5000	
Chemical Feeders				
FEEDER #1	Make and Model: Becsys/CO2 Controller			
	Chemical/Slurry Fed: Chemical	Capacity (kg/24 hrs): 2.6	Injection Point: Filter Effluent	
FEEDER #2	Make and Model:			
	Chemical/Slurry Fed:	Capacity (kg/24 hrs):	Injection Point:	

Application for Permit

Pool Data Sheet

Pool Inlets					
Inlet Type: Hayward wall	Inlet Size (cm): 2.54	Number of Inlets: 6 at 8 m spacing	Depth Below Water Level (cm): 61		
Drains					
Total Number of Drains:	2				
MAIN DRAIN	Make and Model: Hayward WG1032BHF 12"x12"				
	Number: 2	Size of Free Opening (cm ²): 530	Velocity through Grate Opening (m/sec): 0.126		
JET PUMP DRAIN (if separate from main drain)	Make and Model:				
	Number:	Size of Free Opening (cm ²):	Velocity through Grate Opening (m/sec):		
OTHER DRAIN (specify)	Make and Model:				
	Number:	Size of Free Opening (cm ²):	Velocity through Grate Opening (m/sec):		
OTHER DRAIN (specify)	Make and Model:				
	Number:	Size of Free Opening (cm ²):	Velocity through Grate Opening (m/sec):		
OTHER DRAIN (specify)	Make and Model:				
	Number:	Size of Free Opening (cm ²):	Velocity through Grate Opening (m/sec):		
Overflow (Skimmers/Gutters)					
Overflow Type: ☒ skimmer ☐ raised-edge gutter ☐ roll-out gutter ☐ deck-level gutter ☐ other: test					
GUTTERS	Number of Gutter Drains (m spacing): test		Gutter Drain Size (cm): test		
SKIMMERS	Make and Model: Pentair U3				
	Quantity: 4	NSF Approved: ☒ yes ☐ no	Total Weir Length (cm): 20	Maximum Overflow Capacity (L/min): 600	Normal Flow Through Capacity (L/min): 201

Application for Permit

Pool Data Sheet

Make Up Water Source

Source: ☒ public ☐ private	Size of Makeup Line (cm): 1.9	Control: ☒ manual ☐ automatic	Air Gap: ☐ yes ☒ no
Backflow Preventer: ☒ yes ☐ no	Backflow Preventer Make and Model: Watts 007		

Piping (Add extra pages if needed)

SYSTEM #1	System/Liquid Carried: Pool Filtration	Material: ☐ copper ☐ carbon steel ☒ PVC ☐ HDPE ☐ other: test		
	Maximum Velocity (m/sec): Return piping to pool: 1.82 Supply piping to pool: 2.16			
SYSTEM #2	System/Liquid Carried: Pool Water Feature	Material: ☒ copper ☐ carbon steel ☐ PVC ☐ HDPE ☐ other: test		
	Maximum Velocity (m/sec): Return piping to pool: 1.82 Supply piping to pool: 1.54			
SYSTEM #3	System/Liquid Carried:	Material: ☐ copper ☒ carbon steel ☐ PVC ☐ HDPE ☐ other:		
	Maximum Velocity (m/sec): Return piping to pool: Supply piping to pool:			

Data Sheet Revision History

Version	Prepared By	Company	Date	Revision Details
1	Taio Waldhaus	AME Group	11/6/2025	Initial Version