




## innovmetric

## 木型验收报告

Report Author: 卓有成 Date: 2024/6/12







Organization:

Operator:

E-mail:

Workspace: 工作区 1

Project: Inspector项目 - 工件 1

Part name:


Part number:

Drawing #:

Serial #:

Device:







## 特征表格

长度单位 毫米

坐标系 图纸坐标系

**数据**对齐 最佳拟合测量对**象** 3

名称	控制	名义的	测量 <b>的</b>	公差	偏差	测试	超差
• point c	Х	0.000	-0.053	±0.500	-0.053	<b>通</b> 过	
	Υ	85.000	85.911	±0.500	0.911	失败	0.411
	Z	0.000	-0.401	±0.500	-0.401	<b>通</b> 过	
• point d	X	130.000	130.017	±0.500	0.017	<b>通</b> 过	
	Υ	85.000	85.467	±0.500	0.467	<b>通</b> 过	
	Z	40.000	39.601	±0.500	-0.399	<b>通</b> 过	
• point e	X	130.000	129.605	±0.500	-0.395	<b>通</b> 过	
	Υ	-5.000	-4.761	±0.500	0.239	<b>通</b> 过	
	Z	40.000	39.766	±0.500	-0.234	<b>通</b> 过	
• point f	X	85.000	84.625	±0.500	-0.375	<b>通</b> 过	
	Υ	-115.000	-115.744	±0.500	-0.744	失败	-0.244
	Z	57.000	57.405	±0.500	0.405	<b>通</b> 过	
• point g	Х	65.000	65.016	±0.500	0.016	<b>通</b> 过	
	Υ	-115.000	-115.775	±0.500	-0.775	失败	-0.275
	Z	130.000	130.309	±0.500	0.309	<b>通</b> 过	
• point h	Х	105.000	104.795	±0.500	-0.205	<b>通</b> 过	
	Υ	-16.500	-15.454	±0.500	1.046	失败	0.546
	Z	136.000	136.134	±0.500	0.134	<b>通</b> 过	



