NOTES:

1. REFER TO 2000-F24-PID-PR-10034 FOR GLAND WATER DETAIL.
2. MINSUP POINT TO BE SITUATED CLOSE TO DENSITY GAUGE FOR COMMISSIONING.

TIP-1601
2000-F75-PID-PR-10001
POTABLE WATER
30-3109-POT-SS4-25
25VB03S5
F30-14141
F30-SE-596
CONCENTRATE THICKENER SAFETY SHOWER

30-TH-61 BED PRESSURE
PIC30607
2000-F30-PID-PR-10001
SIGNAL
HS 30607

GLAND WATER HEADER
2000-F75-PID-PR-10007
GLAND WATER
30-3051-GW-SS3-25
GLAND
NOTE 1

CONCENTRATE THICKENER UNDERFLOW
2000-F30-PID-PR-10001
CONCENTRATE
SP SS-015
30-3022-CON-RL1-200
SP MC-002
50VB03S1 F30-12547
SP SC-018
SP SS-016
200x180
VSD
M
F30-PP-417
CONCENTRATE THICKENER UNDERFLOW PUMP 1
150x80
SP MC-002
50VB03S1 F30-12549
SP SS-017
SP HS-001
30-3017-CON-RL1-150
DETAIL 3
HS 30446
XV 30446
150VKGD1L2 FL
FI 30456
HH H L LL
FIT 30456
FE 30456
WI 30455
f(x)
DIC 30455
DIT 30455
DE 30455
S
DX 30455
SP MC-002
50VB03S1 F30-12947
PI 30459
PT 30459
50VBD1S1 F30-12551
DETAIL 3
HS 30458
XV 30458
150VKGD1L2 FL
RL1
PE16
30-3011-CON-PE16-160
FILTER FEED TANKS FEED BOX
2000-F35-PID-PR-10001
CONCENTRATE

DETAIL 3
HS 30477
XV 30477
80VKGD1L1 FL
RL1
SS1
DETAIL 4
HS 30445
XV 30445
80VKGD1L1 FO
TO GRADE

DETAIL 4
HS 30475
XV 30475
50VKGD1L1 FO
RL1
PE10
30-3054-FD-PE10-63
TO GRADE

30-3052-GW-SS3-25
GLAND
NOTE 1
80VCD1S1 F30-12546
80VBFD1S2 F30-12545
25VB03S1 F30-12948
SP MC-002
50VB03S1 F30-12548
SP SC-018
SP SS-016
VSD
M
SP MC-002
50VB03S1 F30-12550
SP SS-017
SP HS-001
DETAIL 3
HS 30451
XV 30451
150VKGD1L2 FL
CONCENTRATE THICKENER UNDERFLOW
2000-F30-PID-PR-10001
CONCENTRATE
SP SS-015
30-3023-CON-RL1-200
200x180
F30-PP-418
CONCENTRATE THICKENER UNDERFLOW PUMP 2
150x80
30-3018-CON-RL1-150

DETAIL 3
HS 30457
XV 30457
150VKGD1L2 FL
30-3024-CON-RL1-150
CONCENTRATE THICKENER
2000-F30-PID-PR-10001
CONCENTRATE

DETAIL 4
HS 30476
XV 30476
50VKGD1L1 FO
RL1
PE10
30-3055-FD-PE10-63
TO GRADE

DETAIL 3
HS 30478
XV 30478
80VKGD1L1 FL
RL1
SS1
80VCD1S1 F30-12544
80VBFD1S2 F30-12543
25VB03S1 F30-12949
DETAIL 4
HS 30450
XV 30450
80VKGD1L1 FO
TO GRADE
30-3084-PW-SS1-80
30-3083-PW-SS1-80

FLUSHING WATER HEADER
2000-F30-PID-PR-10001
PROCESS WATER
PE8
SS1
30-3074-PW-PE8-160
30-3087-PW-SS1-150

DRG No.	REFERENCES
2000-F00-PID-PR-10007	LEGEND SHEET 7 - PIPING AND INSTRUMENTATION DIAGRAM
2000-F00-PID-PR-10006	LEGEND SHEET 6 - PIPING AND INSTRUMENTATION DIAGRAM
2000-F00-PID-PR-10005	LEGEND SHEET 5 - PIPING AND INSTRUMENTATION DIAGRAM
2000-F00-PID-PR-10004	LEGEND SHEET 4 - PIPING AND INSTRUMENTATION DIAGRAM
2000-F00-PID-PR-10003	LEGEND SHEET 3 - PIPING AND INSTRUMENTATION DIAGRAM
2000-F00-PID-PR-10002	LEGEND SHEET 2 - PIPING AND INSTRUMENTATION DIAGRAM
2000-F00-PID-PR-10001	LEGEND SHEET 1 - PIPING AND INSTRUMENTATION DIAGRAM

REV	DATE	DESCRIPTION	DRAW	CHECK	DESIGN	TECH APP	PROJ APP
2	05SEP25	HS-30607B DELETED	AH	LV	JBe	LV	DM
1	10JUL25	GENERAL REVISIONS AS NOTED	AH	MM	JBe	LV	DM
0	14MAR25	APPROVED FOR CONSTRUCTION	AH	JB	LV	LV	DM

NORTHERN STAR RESOURCES LIMITED

PRIMERO
primero.com.au | DESIGN | CONSTRUCT | OPERATE

PRIMERO PROJECT NUMBER: 23517

INFORMATION AND REPRESENTATIONS ON THIS DRAWING ARE THE INTELLECTUAL PROPERTY OF PRIMERO UNLESS SPECIFICALLY IDENTIFIED OTHERWISE. ALL RIGHTS INCLUDING USE RESERVED

PROJECT: NORTHERN STAR RESOURCES LTD
KCGM GROWTH PROJECT

TITLE: CONCENTRATE THICKENING AREA
CONCENTRATE THICKENER UNDERFLOW PUMPS
PIPING AND INSTRUMENTATION DIAGRAM

SHEET	SCALE	DRG No.	REVISION
A1	NTS	2000-F30-PID-PR-10002	2

O:\CAD PROJECTS\235 NORTHERN STAR RESOURCES LTD\23517 KCGM GROWTH PROJECT\03 DELIVERABLES\PRI\PID\2000-F30-PID-PR-10002_2.DWG 05SEP25 9:22AM ANNE.HOYNE